Facility: Examina	TMI Unit 1 tion Level (circle one)	RO/SRO	Date of Examination: July 23, 2001 Operating Test Number:
	Administrative Topic/Subject Description	Describe method of 1. ONE Administration 2. Two Administrations	rative JPM, OR ative Questions
A.1	Conduct of Operations Ability to obtain and interpret station reference materials. KA 2.1.25 CFR 41.10/43.5/45.12 RO 2.9 SRO 3.1		ill be tasked with determining the amount of Boric Acid from Hot Standby to Cold Shutdown conditions.
	Ability to locate and use procedures and directives related to shift staffing and activities. KA 2.1.5 CFR 43.2/43.5/45.3 SRO 3.4 TMI Task: 3410180303 TIF 2.93	JPM: Candidate w staffing issues.	ill be tasked with determining actions required for shift
A.2	Equipment Control Tagging and clearance. K/A 2.2.13 CFR 41.10/45.13 RO 3.6 SRO 3.8 TMI Task 1190120301 TIF 3.86		tasked with determining the clearance points for a leak on the n. Recent TMI event.
A.3	Radiation Control Knowledge of the requirements for reviewing and approving release permits. KA 2.3.6 CFR 43.4/45.10 RO 2.1 SRO 3.1 TMI Task 068C010101 TIF 2.5	JPM: Candidate w	ill be tasked with approving a liquid release permit.
A.4	Emergency Procedures/Plan Emergency Action Level and Classification KA 2.4.41 CFR 43.5/45.11 SRO 4.1 TMI Task 5001045001 TIF 3.35		ill be tasked with classifying an event, provide a PAR and notification process.

TMI-1 OPERATOR TRAINING

JOB PERFORMANCE MEASURE

A.1-1

	SIGNATURE	DATE
Submitted By:	1 & Camery	6-3-01
Validated By:	James Athan	6-3-01
Reviewed by: Lead Exam Developer	N.L. Offer	6/3/01
		:
Approved By: Facility Representative	Rand S. Canpbell	6-3-01

BORATION TO COLD SHUTDOWN CALCULATION TASK TITLE:

TASK NUMBER:

0008150401

TIF: 3.0

K/A REFERENCE:

POSITION:

System:

NA

K/A: Rating(RO/SRO): 2.1.25 2.9/3.1

SRO ⊠RO ⊠

NLO 🗌

EVALUATION METHOD: PERFORM 🛛

SIMULATE

EVALUATION LOCATION: SIMULATOR

IN-PLANT ☐ CONTROL ROOM ☐ OTHER ☒

TASK STANDARDS: Examinee calculates the required makeup volumes from the BAMT and RCBT within the

tolerances described within this JPM.

APPROXIMATE COMPLETION TIME: 20 minutes

TIME-CRITICAL TASK COMPLETION TIME: NA minutes

REQUIRED TOOLS OR MATERIALS: Calculator and Ruler / OP 1103-4 Soluble Poison Control.

REFERENCES: OP 1103-4 Soluble Poison Control

ALTERNATE PATH JPM? NO

SIMULATOR SETUP: NA

INITIALIZATION: NA

EVENT TRIGGERS: N/A

MALFUNCTIONS: N/A

REMOTE FUNCTIONS: N/A

OVERRIDES: N/A

MONITOR: N/A

READ TO STUDENT

When I tell you to begin, you are to CALCULATE THE REQUIRED AMOUNT OF MAKEUP FROM THE BAMT AND RCBT 'C' IN ORDER TO COOLDOWN FROM 540°F TO 150°F. Before you start, I will describe the general plant conditions, state the initiating cues, and answer any questions. Perform procedure steps and make notifications as if you were actually performing the task.

INITIAL CONDITIONS:

The reactor has been shutdown for 5 days.

500 EFPD

RCS temperature is 540°F

RCS Boron: 400 ppmB.

RCBT 'C' boron concentration is 1120 ppmB.

BAMT boron concentration is 17500 ppmB.

The Plant must be cooled down to 150°F in order to repair the Pressurizer PORV.

INITIATING CUE:

The Shift Manager directs you to calculate the required amount of makeup from the BAMT and RCBT 'C' in order to cooldown from 540°F to 150°F.

ARE THERE ANY QUESTIONS?

JPM INSTRUCTION SHEET

DIRECTIONS TO STUDENT:

When I tell you to begin, you are to CALCULATE THE REQUIRED AMOUNT OF MAKEUP FROM THE BAMT AND RCBT 'C' IN ORDER TO COOLDOWN FROM 540°F TO 150°F. Before you start, I will describe the general plant conditions, state the initiating cues, and answer any questions. Perform procedure steps and make notifications as if you were actually performing the task.

INITIAL CONDITIONS:

The reactor has been shutdown for 5 days.

500 EFPD

RCS temperature is 540°F

RCS Boron: 400 ppmB.

RCBT 'C' boron concentration is 1120 ppmB.

BAMT boron concentration is 17500 ppmB.

The Plant must be cooled down to 150°F in order to repair the Pressurizer PORV.

INITIATING CUE:

The Shift Manager directs you to calculate the required amount of makeup from the BAMT and RCBT 'C' in order to cooldown from 540°F to 150°F.

*Denotes Critical Elements #Denotes Sequential Step

STEP	STANDARD	S/U
Examinee obtains a copy of OP 1103-4 and using Enclosure 5 calculates the required amount of makeup from the	The examinee calculates the makeup volumes within the allowable tolerances provided below.	
BAMT and RCBT 'C'.	V _{BAMT} = 3749 to 3864 gals.	
	V _{RCBT} = 15886 to 17001 gals.	
	NOTE: Allowances used to determine calculation.	
	Fig. 1: 1260 ± 12 ppmB Fig. 2 70250 ± 250 gals. 90500 ± 250 gals	
	Examinee obtains a copy of OP 1103-4 and using Enclosure 5 calculates the	Examinee obtains a copy of OP 1103-4 and using Enclosure 5 calculates the required amount of makeup from the BAMT and RCBT 'C'. 1. The examinee calculates the makeup volumes within the allowable tolerances provided below. V _{BAMT} = 3749 to 3864 gals. V _{RCBT} = 15886 to 17001 gals. NOTE: Allowances used to determine calculation. Fig. 1: 1260 ± 12 ppmB Fig. 2 70250 ± 250 gals.

END TASK

JPM CHANGE HISTORY PAGE

REVISION	DATE	REFERENCE TITLE	DESCRIPTION (Include AI # if Appropriate)
0	5/30/01	NA	New JPM.

TMI-1 OPERATOR TRAINING

JOB PERFORMANCE MEASURE

A.1.2

	SIGNATURE	DATE
Submitted By:	Robien Jane	1/16/01
Validated By:	Aflany	7/16/01
Reviewed by: Lead Exam Developer	N.S.O.	7/23/01
Approved By:	000111	
Facility Representative	R. S. Compbell	7-23-01

TASK TITLE:

ADMINISTRATIVE REQUIREMENTS FOR SHIFT MANNING ACTIVITIES - WORKING HOUR

LIMITATIONS

TASK NUMBER:

3410180303

TIF: 2.93

K/A REFERENCE:

System: K/A:

2.1.5

Rating:

3.4

POSITION:

SRO 🛛

RO □ NLO 🗆

EVALUATION METHOD: PERFORM 🖂

SIMULATE [

EVALUATION LOCATION: SIMULATOR ☐ IN-PLANT ☐ CONTROL ROOM ☐ OTHER ☑

TASK STANDARDS: Examinee determines working hour limitations would be exceeded. Examinee completes

Enclosure 1 of AP 1031.

APPROXIMATE COMPLETION TIME: 15 minutes

TIME-CRITICAL TASK COMPLETION TIME: NA

REQUIRED TOOLS OR MATERIALS: AP 1031, Nuclear Plant Staff Working Hours.

REFERENCES: AP 1031, Nuclear Plant Staff Working Hours.

ALTERNATE PATH JPM? NO

SIMULATOR SETUP:

INITIALIZATION: NA

EVENT TRIGGERS: NA

MALFUNCTIONS: NA

REMOTE FUNCTIONS: NA

OVERRIDES: NA

MONITOR: NA

READ TO STUDENT

When I tell you to begin, YOU ARE TO EVALUATE A WORKERS HOURS FOR MINIMUM STAFFING REQUIREMENTS. Before you start, I will describe the general plant conditions, state the initiating cues, and answer any questions. Perform procedure steps and make notifications as if you were actually performing the task.

INITIAL CONDITIONS:

You are the Shift Manager for the off-going shift.

The time is 1600 Thursday afternoon.

The oncoming Shift Manager has just informed you that he will need one CRO from your shift to holdover for up to 4 hours in order to maintain minimum shift manning requirements. One of the oncoming CROs has a broken leg. Another CRO from his shift has been recalled from vacation, but can't return to the plant until at least 2200.

One CRO from your shift, John Doe, has volunteered to holdover. His work history for the current shift (0700 to 1900) is as follows:

Saturday - OFF Sunday - OFF

Monday - 0700 - 1900, excluding shift turnover time

Tuesday - 0700 - 1900, excluding shift turnover time

Wednesday - 0700 - 1900, excluding shift turnover time

Thursday - 0700 - 1600, excluding shift turnover time

Friday - Scheduled off.

INITIATING CUE:

DETERMINE WHETHER JOHN DOE IS ABLE TO HOLDOVER FOR FOUR HOURS AFTER SHIFT WITHOUT **VIOLATING WORKING HOUR LIMITATIONS.**

ARE THERE ANY QUESTIONS?

JPM INSTRUCTION SHEET

DIRECTIONS TO STUDENT:

When I tell you to begin, **DETERMINE WHETHER JOHN DOE IS ABLE TO HOLDOVER FOR FOUR HOURS AFTER SHIFT WITHOUT VIOLATING WORKING HOUR LIMITATIONS.** Before you start, I will describe the general plant conditions, state the initiating cues, and answer any questions. Perform procedure steps and make notifications as if you were actually performing the task.

INITIAL CONDITIONS:

You are the Shift Manager for the off-going shift.

The time is 1600 Thursday afternoon.

The oncoming Shift Manager has just informed you that he will need one CRO from your shift to holdover for up to 4 hours in order to maintain minimum shift manning requirements. One of the oncoming CROs has a broken leg. Another CRO from his shift has been recalled from vacation, but can't return to the plant until at least 2200.

One CRO from your shift, John Doe, has volunteered to holdover. His work history for the current shift (0700 to 1900) is as follows:

Saturday - OFF

Sunday - OFF

Monday - 0700 - 1900, excluding shift turnover time

Tuesday - 0700 - 1900, excluding shift turnover time

Wednesday - 0700 - 1900, excluding shift turnover time

Thursday - 0700 - 1600, excluding shift turnover time

Friday - Scheduled off.

*Denotes Critical Elements #Denotes Sequential Step

*Dello	tes Sequential Step		
#	STEP	STANDARD	S/U
EX	AMINER CUE: DETERMINE WHETHER JOH AFTER SHIFT WITHOUT VIOI	IN DOE IS ABLE TO HOLDOVER FOR FOUR HOURS LATING WORKING HOUR LIMITATIONS.	3
1.	Examinee obtains/requests a copy of AP 1031, Nuclear Plant Staff Working Hours.	NOTE: Provide a copy of AP 1031, Nuclear Plant Staff Working Hours if requested. Examinee may request a procedure list in order to determine appropriate course of action.	
*2.	Examinee evaluates holdover time to determine if working hour limitations are exceeded.	Examinee determines that requirements of section 4.1.2.2 are exceeded, specifically, working more than 24 hours in a 48-hour period.	
CUE THE	E: DIRECT EXAMINEE TO TAKE THE APPI E ADDITIONAL FOUR HOURS.	ROPRIATE ACTION TO PERMIT JOHN DOE TO WOR	RK
3	Examinee obtains copy of Enclosure 1 from AP 1031.	CUE: Provide copy of Enclosure 1 to examinee.	1
4	Examinee enters Plant Manager name on enclosure 1 in the "TO:" area.	Examinee enters "George Gellrich" or "Gellrich" on enclosure 1 in the "TO:" area.	
*5.	Examinee checks off "Request for Deviation"	"Request for Deviation" is checked or X'ed off.	<u> </u>
*6.	Examinee enters date of violation.	Enters today's date.	
*7.	Examinee enters name AND position of individual.	Enters John Doe and CRO or Reactor Operator.	
*8.	Describe deviation/violation.	Enters section 4.1.2.2. (Required for critical task) May provide amplifying information, ie, exceeding 24 hours in a 48 hour period, but not required.	
*9.	Circumstances surrounding the deviation requested or violation.	"Individual required to meet minimum manning requirements for oncoming shift due to medical emergency" or words to that effect.	
*10	Duties performed and potential effect on safety.	Reactor Operator (CRO), responsible for operation of safety related equipment. (Or words to that effect. Must relate safety significance.)	
11.	Actions to be taken to prevent recurrence	No response required. This is an emergent medical condition that could not be foreseen.	
12.	Examinee enters name and date.	Name and date entered.	
		END TASK	

JPM CHANGE HISTORY PAGE

REVISION	DATE	REFERENCE TITLE	DESCRIPTION (Include AI # if Appropriate)
0	6/26/01	NA	New JPM.
			:
	4.1		

TMI-1 OPERATOR TRAINING

JOB PERFORMANCE MEASURE

A.2

1	SIGNATURE	DATE
Submitted By:	JL Carny	6-3-01
Validated By:	Jeime a Irleba	6-3-01
Reviewed by: Lead Exam Developer	N.L. Offe	6/3/01
		·
Approved By: Facility Representative	Randy 5. Campbell	6-3-01

TASK TITLE: CLEARANCE APPROVAL AND AUTHORIZATION PROCESS

TASK NUMBER:

1190120301

TIF: 3.86

K/A REFERENCE:

System:

K/A: Rating: 2.2.13 3.8/3.6

POSITION:

SRO ⊠RO □

NLO 🗌

EVALUATION METHOD: PERFORM 🖂

SIMULATE [

EVALUATION LOCATION: SIMULATOR

IN-PLANT ☐ CONTROL ROOM ☐ OTHER ☐

TASK STANDARDS: Authorization is not granted based on the following errors: 1. Approver and Preparer are

identified as same person. 2. Clearance points are inadequate for job.

APPROXIMATE COMPLETION TIME: 20 minutes

TIME-CRITICAL TASK COMPLETION TIME: NA

REQUIRED TOOLS OR MATERIALS:

AP 1002, Clearance and Tagging

302 Prints

1107-4, Electrical Distribution Listing

REFERENCES: AP 1002, Clearance and Tagging

ALTERNATE PATH JPM? NO

SIMULATOR SETUP: NA

INITIALIZATION: NA

EVENT TRIGGERS: NA

MALFUNCTIONS: NA

REMOTE FUNCTIONS: NA

OVERRIDES: NA

MONITOR: NA

READ TO STUDENT

When I tell you to begin, you are to **REVIEW AND AUTHORIZE APPLICATION OF TAGS FOR CLEARANCE NUMBER 01000354.** Before you start, I will describe the general plant conditions, state the initiating cues, and answer any questions. Perform procedure steps and make notifications as if you were actually performing the task.

INITIAL CONDITIONS:

The Plant is at 100% power.

Work Order C2000318 was issued to replace the check valve on the discharge of Screen Wash Pump 1B (SW-P-1B).

SW-P-1B is secured.

SW-P-1A is in operation, providing flow to the Screen Wash System.

INITIATING CUE:

The Job Foreman is ready to work the job, and requests that you authorize the clearance for tagging application.

ARE THERE ANY QUESTIONS?

JPM INSTRUCTION SHEET

DIRECTIONS TO STUDENT:

When I tell you to begin, you are to **REVIEW AND AUTHORIZE APPLICATION OF TAGS FOR CLEARANCE NUMBER 01000354.** Before you start, I will describe the general plant conditions, state the initiating cues, and answer any questions. Perform procedure steps and make notifications as if you were actually performing the task.

INITIAL CONDITIONS:

The Plant is at 100% power.

Work Order C2000318 was issued to replace the check valve on the discharge of Screen Wash Pump 1B (SW-P-1B).

SW-P-1B is secured.

SW-P-1A is in operation, providing flow to the Screen Wash System.

INITIATING CUE:

The Job Foreman is ready to work the job, and requests that you authorize the clearance for tagging application.

*Denotes Critical Elements #Denotes Sequential Step

#	STEP	STANDARD	S/U
INIT	TATING CUE: AS JOB FOREMAN, PROVIDENCE THAT THE TAGGING APPLICATION	E CLEARANCE 01000354 TO THE EXAMINEE AND N BE AUTHORIZED IN ORDER TO COMMENCE WOR	K.
1	Examinee obtains copy of AP 1002, Clearance and Tagging, and begins reviewing the clearance.	Examinee verifies that the revision of AP 1002 is the most recent revision. CUE: Inform examinee that the copy of AP 1002 is the most recent revision.	
*2	The person approving the Clearance shall not be the same person that created the Clearance.	Examinee identifies that the clearance is approved, but that Preparer and Approver are the same person, which is not permitted.	
*3	Examinee verifies that the clearance points are adequate to support the job.	Examinee identifies that the clearance points are inadequate. Discharge valve SW-V-1B is not identified on the clearance.	
*4	Examinee identifies that they would not authorize the Clearance based on errors.	Shift Management shall authorize equipment removal from service by completing the "Authorized By" line in accordance with specific station procedures. NOTE: Errors preclude this step from being	97.
		completed. Examinee should NOT authorize this clearance.	

END TASK

JPM CHANGE HISTORY PAGE

REVISION	DATE	REFERENCE TITLE	DESCRIPTION (Include AI # if Appropriate)
0	5/30/2001	N/A	NEW JPM.
÷			

TMI-1 OPERATOR TRAINING

JOB PERFORMANCE MEASURE

A.3

	SIGNATURE	DATE
Submitted By:	11 Canny	6-3-01
Validated By:	Jamo attubb	6/3/01
Reviewed by: Lead Exam Developer	W. & Offe	6/3/01
Approved By: Facility Representative	Randy 5. Campbell	6-3-01

TASK TITLE: LIQUID RELEASE PERMIT APPROVAL

TASK NUMBER:

068C010101

TIF: 25

K/A REFERENCE:

System:

Generic

K/A: Rating: 2.3.6 2.1/3.1

POSITION:

SRO ⊠RO □

NLO 🗌

EVALUATION METHOD: PERFORM 🖂

SIMULATE |

EVALUATION LOCATION: SIMULATOR

IN-PLANT ☐ CONTROL ROOM ☐ OTHER ☑

TASK STANDARDS: Examinee identifies the following errors: (1) Radiological analysis not performed by GRCS. (2) no written evaluation and approval by the Chemistry Supervisor for pH and conductivity outside the normal band.

APPROXIMATE COMPLETION TIME: 30 minutes

TIME-CRITICAL TASK COMPLETION TIME: NA

REQUIRED TOOLS OR MATERIALS: ODCM, 6610-ADM-4250.01, Releasing Radioactive Liquid Waste.

REFERENCES:

1029-S, Liquid Radioactive Release; ODCM; 6610-ADM-4250.01, Releasing Radioactive

Liquid Waste.

ALTERNATE PATH JPM? NO

SIMULATOR SETUP:

INITIALIZATION: NA

EVENT TRIGGERS: NA

MALFUNCTIONS: NA

REMOTE FUNCTIONS: NA

OVERRIDES: NA

MONITOR: NA

READ TO STUDENT

When I tell you to begin, you are to REVIEW AND APPROVE A LIQUID RELEASE PERMIT. Before you start, I will describe the general plant conditions, state the initiating cues, and answer any questions. Perform procedure steps and make notifications as if you were actually performing the task.

INITIAL CONDITIONS:

The plant is stable at 100% power.

Waste Evap. Condensate Storage Tank WDL-T11A is isolated and tagged "DO NOT OPERATE".

The previous Shift Manager has initiated a Liquid Release Permit for WDL-T11A.

WDL-T11A level is 7.8 feet.

The current time is 2000.

INITIATING CUE:

Review and approve the Liquid Release Permit for WDL-T11A.

ARE THERE ANY QUESTIONS?

JPM INSTRUCTION SHEET

DIRECTIONS TO STUDENT:

When I tell you to begin, you are to **REVIEW AND APPROVE A LIQUID RELEASE PERMIT.** Before you start, I will describe the general plant conditions, state the initiating cues, and answer any questions. Perform procedure steps and make notifications as if you were actually performing the task.

INITIAL CONDITIONS:

The plant is stable at 100% power.

Waste Evap. Condensate Storage Tank WDL-T11A is isolated and tagged "DO NOT OPERATE".

The previous Shift Manager has initiated a Liquid Release Permit for WDL-T11A.

WDL-T11A level is 7.8 feet.

The current time is 2000.

INITIATING CUE:

Review and approve the Liquid Release Permit for WDL-T11A.

*Denotes Critical Elements #Denotes Sequential Step

#	STEP	STANDARD
INIT	FIATING CUE: (As Group Radiological Co Release Permit and direct i	ontrols Supervisor, GRCS) Provide the examinee a Liqu
Acc	companying documents are:	
Cor	nputer generated site dose history.	
For	ms 1621-1 and 1621-2	
*1	Examinee reviews the Liquid Release Permit for approval IAW 6610-ADM- 4250.01.	The examinee determines that the following errors exist:
		GRCS has not reviewed the Radiological Analysis.
		Required written evaluation and approval for release from the Chemistry Supervisor is not with the permit.
		CUE: Role play as necessary to respond to examinee questions.
*2	The Shift Manager signs the form to approve the release IAW 6610-ADM-4250.01 step 4.10.4.	The examinee does NOT sign for approval unless all discrepancies are corrected.

END TASK

JPM CHANGE HISTORY PAGE

REVISION	DATE	REFERENCE TITLE	DESCRIPTION (Include Al # if Appropriate)
0	5/30/2001	NA	Initial issue.

LIQUID	RELEASE		PERMIT
RELEASE	NUMBER:	L	106005

FOR TRAINING USE ONLY

1	
ı	DEDI ACEC ECONO 4004 O 4 AND E
1	
ı	REPLACES FORMS 1621-3, 4, AND 5.
ı	PRINTENIT
ı	PRINTOLIT

INCLUDE FORM 1621-1 AND 2 WITH THIS

RELEASE INFORMATION COMPLETED	D BY: JOHN DOE -	RADIOLOGICAL CONTROLS TECH A
RELEASE RECOMMENDED B'SUPERVISOR	Jeh Nov - RADO	ONTROLS TECH A SIGNATURE - GROUP RADIOLOGICAL CONTROLS
RELEASE APPROVED BY	Y:	- SHIFT SUPERVISOR (FINAL APPROVAI
CONTROL ROOM OPERATOR CONTAC	CTED: JAMES SMITH	
FR-146 (LOW MDCT FLOW) FR-84 ALARM SETPOINT AT: 3 FR-84 (HIGH LIQUID RELEASE TEST SATISFACTORY. RML-6 OPERABLE PER 1301-1 VALVE WDL-V124 (🔀) OR WDL	EASE : 193. MINUTES 1.47E+05 CPM. INITIA 1.10E+05 CPM. INITIA TORY. 1.2.43E+04 GPM. 3.50E+01 MGD. INITIA TEST SATISFACTORY 3.00E+01 GPM: INITIA EFLOW) INITIA	_ INITIALS _ INITIALS ALS INITIALS LS

	NT READINGS:	READING AT START	READING AFTER 1/4 COMPLETE	READING AFTER 1/2 COMPLETE	READING AFTER 3/4 COMPLETE	READING AFTER RELEASE COMPLETE
FR-84	2.70E+01 GPM					
RML-6	7.36E+04 CPM					
FR-146	2.43E+04 GPM 3.50E+01 MGD					
RML-7	2.05E+02 CPM					

RELEASE	VILLIMID IS D.
バロロロロロロ	MOMDER:

L 106005

FOR TRAINING USE ONLY

RAD	IOLOGICAL A	ANALYSIS REVIEWE	D BY:	(GRCS)	
				DATE/TIME _	
EST	MATED VOLU	UME IN TANK	5200 GALLONS		
	ANALYSIS	SPECIFIC ACTIVITY MICRO CI/ML	CONTROLLING MICRO CI/ML	SPECIFIC ACTIVITY /CONTROLLING	
Н	3	3.45E-04	2.00E-03	1.72E-01	
cs	137	6.82E-04	1.00E-06	6.82E+02	
		NUMBER L010600		6.82E+02 REQUIRED DF	
CONDUCTIVITY					
SUMI	RML-6 BAC	CKGROUNDS CKGROUND CKGROUND		2000 100	٠
VALU	CONTROL MDCT FLO RIVER FLC ESTIMATE	D ROOM OPERATOR W (GPM) W (GPM) D RELEASE DURAT D VOLUME (GALLON	NAME	JAMES SMITH	
DILUT	TEN PERCI BORON DI	RS CALCULATED ENT MPC DILUTION LUTION FACTOR JTION FACTOR	FACTOR	6.82E+02 7.14E+00 1.40E+02	
RML-6	MONITOR F	RESPONSE	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	7.16E+04	

FACSIMILE OF LIQUID RELEASE FORM GENERATED BY LAGER PROGRAM

TMI - Unit 1 Radiological Controls Procedure

6610-ADM-4250.01

Title

Revision No.

Releasing Radioactive Liquid Waste

14

EXHIBIT 4 Form 1621-1 (Example) Page 1 of 5

	OPERATIONS INPUT TO LIQUID RELEASE PERMIT					
	L106005					
	(4) Release Number					
(1) D	ate/Time: 6/1/01 /1255 Reque	ster (Signature):	flung		(Shift Mgr.)	
(2) 'g			lation (min. of 8 hours) Tir		Date: 4/01	
<u> </u>			Do Not Operate" Tagged: Tir		Date: 6/1/01	
	WDL-T-11B Tank B Ta		gallons 5219 Re		HMS	
		Signed	1/Date f. Smid 1 G	1/107	· ·	
(32)	(Record all start and stop date ti	mes) Tani	Level at Start of Release	ft.	gal.	
	Time Release Stopped		Level at End of Release			
	Time		Volume Released (Actual)			
	Time Release Started		T Effluent Totalizer at Stop			
	Time		T Effluent Totalizer at Start		gal.	
	Total Time of Release		Total Dilution Flow		gal.	
	Minu .		·	·		
(33)	Actual Release Rate = Actual Ga		•			
	· · · · · · · · · · · · · · · · · · ·	ninutes	gpr	n		
(34)	Cancelled or Partial Release		·			
	State reason this release was ca	incelled or only pa	rtially released:			
					·	
	·					
(35)	Release data completed and che	emistry notified of	actual gallons released:			
			Signature Dat	e/Time		
	AH 1 (1 11 1				•	
	All data required on this form has	been completed.				
			Shift Manager I	Date/Time		

TMI - Unit 1 Radiological Controls Procedure

6610-ADM-4250.01 Revision No.

14

Title

Releasing Radioactive Liquid Waste

Form 1621-2 (Example)

Page 2 of 5

Chemistry Data Sheet for Releasing Radioactive Liquid Waste

(4) RELEASE NUMBER

L106005

NOTE

AFTER COMPLETION FORWARD THIS DATA SHEET ALONG WITH COPIES OF THE GAMMA AND TRITIUM ANALYSIS TO RADIOLOGICAL CONTROLS FOR INCLUSION IN THE RELEASE PERMIT.

SIGNATURE (PRINT/SIGN)

(5)	TANK RECIRCULATED ≥ 8 HRS.	BY: J. Smith / & Smith	_DATE/TIME _ 1/1/01/1800
(6)	RELEASE SAMPLE(S) COLLECTED	BY: J. DUE / JPac	_DATE/TIME 6/, 1/1200
(7)	RELEASE GAMMA SCAN	BY: J. DOE / Doe	DATE/TIME 6/1/01/1800
	RELEASE TRITIUM ANALYSIS	BY: J. DUE/ Jour	_DATE/TIME 6/1/01 / 18 00
	WEEKLY COMPOSITE SAMPLES	BY: J. DUE / A Pur	DATE/TIME C/1/4/1800

	RESULT	LIMIT .
pH	9.50	4.5 - 9.5 (NOTE 1)
CONDUCTIVITY	1.10E+01	<10 uMHO (NOTE 2)
BORON	5	PPM

NOTE

- The limit of 4.5 9.5 will ensure that the NPDES limit of 6 9 is not exceeded at the main station discharge to the Susquehanna River.
- 2. Must be <10 uMHO to consider water with pH less than 6 or greater than 9. If conductivity is >10 uMHO and pH is less than 6.0 or greater than 9.0, release must be approved by Chemistry Supervisor or his designee with a written evaluation attached to release form.

TMI-1 OPERATOR TRAINING

JOB PERFORMANCE MEASURE

A.4

	SIGNATURE	DATE
Submitted By:	A. L. Carren	6-3-01
Validated By:	games a Soulles	6-3-01
Reviewed by: Lead Exam Developer	W. L. Off.	6/3/01
Approved By: Facility Representative	Randy 5. Campbell	6-3-01

TASK TITLE:

EVENT CLASSIFICATION. OFF SITE NOTIFICATION AND PROTECTIVE ACTION

RECOMMENDATION

TASK NUMBER:

5001045001

TIF: 3.35

K/A REFERENCE:

System: Generic

K/A: 2.4.41

Rating:

2.3/4.1

POSITION:

SRO ⊠RO □

NLO 🗌

EVALUATION METHOD: PERFORM

SIMULATE [

EVALUATION LOCATION: SIMULATOR

IN-PLANT ☐ CONTROL ROOM ☐ OTHER ☒

TASK STANDARDS: Examinee classifies the event as a General Emergency under G7.1 within 15 minutes of direction to classify the event. Direction to ECC Communications Coordinator to notify off site agencies is given within 15 minutes of event classification. PAR of Sheltering the 10 mile radius around the plant is delivered to the State within 15 minutes of event classification.

APPROXIMATE COMPLETION TIME: 30 minutes

TIME-CRITICAL TASK COMPLETION TIME: Classification: 15 minutes

PAR: 15 minutes

REQUIRED TOOLS OR MATERIALS: None.

REFERENCES:

EPIP-TMI-.01, EPIP-TMI-.02 and Emergency Report Form

ALTERNATE PATH JPM? NO

SIMULATOR SETUP:

INITIALIZATION: NA

EVENT TRIGGERS: NA

MALFUNCTIONS: NA

REMOTE FUNCTIONS: NA

OVERRIDES: NA

MONITOR: NA

READ TO STUDENT

When I tell you to begin, you are to CLASSIFY THE EVENT AND TO INITIATE INITIAL NOTIFICATIONS AS REQUIRED. Before you start, I will describe the general plant conditions, state the initiating cues, and answer any questions. Perform procedure steps and make notifications as if you were actually performing the task.

INITIAL CONDITIONS:

The plant was stable at 100% power when the following sequence of events occurred:

1600: Security reported an armed hostile force penetrated the Control Tower carrying what appeared to be grenades. This was identified as a valid Code Red.

A.4 Revision 0 06/03/2001

1602: An explosion occurred in the Control Tower, immediately followed by loss of the 1E 4160V Bus. Numerous fire alarms consistent with the location of the 1E 4160V Bus are received.

1603: Security reports all hostile force members have been neutralized, and that there is a fire on the third Floor of the Control Tower.

1605: Security reports that the fire is out and that the 1E 4160V Bus is severely damaged. The plant is stable at 100% power.

The current time is 1605.

Wind Speed 12 mph.

Wind direction is from 295.

The EOF is NOT activated.

INITIATING CUE:

Classify the event based on current plant conditions AND initiate initial notifications as required.

ARE THERE ANY QUESTIONS?

TIME CRITICAL: YES

JPM INSTRUCTION SHEET

DIRECTIONS TO STUDENT:

When I tell you to begin, you are to **CLASSIFY THE EVENT AND TO INITIATE INITIAL NOTIFICATIONS AS REQUIRED.** Before you start, I will describe the general plant conditions, state the initiating cues, and answer any questions. Perform procedure steps and make notifications as if you were actually performing the task.

INITIAL CONDITIONS:

The plant was stable at 100% power when the following sequence of events occurred:

1600: Security reported an armed hostile force penetrated the Control Tower carrying what appeared to be grenades. This was identified as a valid Code Red.

1602: An explosion occurred in the Control Tower, immediately followed by loss of the 1E 4160V Bus. Numerous fire alarms consistent with the location of the 1E 4160V Bus are received.

1603: Security reports all hostile force members have been neutralized, and that there is a fire on the third Floor of the Control Tower.

1605: Security reports that the fire is out and that the 1E 4160V Bus is severely damaged. The plant is stable at 100% power.

The current time is 1605.

Wind Speed 12 mph.

Wind direction is from 295.

The EOF is NOT activated.

INITIATING CUE:

Classify the event based on current plant conditions AND initiate initial notifications as required.

TIME CRITICAL: YES

*Denotes Critical Elements #Denotes Sequential Step

#	STEP	STANDARD S/U				
INI	INITIATING CUE: Classify the event base on current plant conditions AND initiate initial notifications as required.					
NO	NOTE: Record time that direction to classify the event is given.					
*1	Examinee obtains a copy of EPIP-TMI01, Emergency Classification and Basis and classifies the event.	The examinee determines that a General Emergency exists IAW G7.1, Security Event resulting in inability to reach or maintain Cold Shutdown as indicated by: Loss of physical control of remote shutdown capability.				
		NOTE: This determination must be made within 15 minutes from the time the examiner provides direction to classify the event.				
		Time of Classification:				
2	Examinee implements EPIP-TMI02 and performs section 1.0 of Exhibit 1.	The examinee declares the event and identifies himself as the ED. (Examinee may indicate to the examiner that they would make the announcement.)				
3	Examinee obtains an Emergency Report	Examinee enters correct information in the ERF.				
	Form (ERF) and begins to fill it out.	CUE: If requested, role play as necessary and provide the following information:				
	NOTE: If LOTUS Notes is available, the examinee may use the LOTUS Notes notification program to develop	There is NO abnormal radiation release (provided by the Radiological Assessment Coordinator).				
	required forms.	There are no restrictions on personnel movement for Mustering and Evacuation (provided by Security Manager).				
*4	Direct the ECC Communicator to perform the following:	Direct the ECC Communicator to perform the following:				
	 Initiate CALL OUT and NOTIFICATION using Page 1 of the ERF. 	 Initiate CALL OUT and NOTIFICATION using Page 1 of the ERF. 				
	Initiate CONTACT via an ECC Communicator using Page 2 of the ERF.	Initiate CONTACT via an ECC Communicator using Page 2 of the ERF.				
		NOTE: This notification must be made within 15 minutes from the time of classification noted in Step 2.				
		Time of Notification:				

	06/03/20				
#	STEP	STANDARD	S/U		
*5	Develop a PAR and personally notify the STATE EOC using either of the three methods identified in Exhibit 8A.	PAR is to SHELTER to 10 miles. PAR must be personally delivered to the STATE within 15 minutes of event classification using either of the three methods identified in Exhibit 8A.			
		CUE: Role play as necessary as STATE EOC representative. Provide name when answering as state representative.			
		NOTE: This notification must be made within 15 minutes from the time of classification noted in Step 2.			
		Providing Basis for PAR is NOT required.			
		Time of Notification:			

END TASK

JPM CHANGE HISTORY PAGE

REVISION	DATE	REFERENCE TITLE	DESCRIPTION (Include AI # if Appropriate)
0	5/30/2001	NA	Initial issue.