

CP
SI

DIST:
Document Control (5C 5)
NRC PDR
L PDR
TERA
NSIC

OCT 20 1982

Docket No.: 50-395

LB#1 Rdg.	MPA
WKane	TBarnhart (4 cys)
MRushbrook	WMiller
JYoungblood	IDinitz
Attorney, OELD	WJones, OA
JRutberg, OELD	ACRS (16)
DEisenhut/RPurple	BPCotter, ASLBP
TNovak	ARosenthal, ASLAP
ATOalston, AIG	FPagano, OIE
JSouder	
JMTaylor, OIE	
ELJordan, OIE	

Mr. O. W. Dixon, Jr.
Vice President Nuclear Operations
South Carolina Electric & Gas Company
Post Office Box 764
Columbia, South Carolina 29218

Dear Mr. Dixon:

Subject: Issuance of Amendment No. 3 to Facility Operating License NPF-12
Virgil C. Summer Nuclear Station, Unit No. 1

The Nuclear Regulatory Commission has issued Amendment No. 3 to Facility Operating License NPF-12 for the Virgil C. Summer Nuclear Station, Unit No. 1 located in Fairfield County, South Carolina.

This amendment is in response to your letter dated October 19, 1982. This amendment provides for a range on the content of hydrogen in the sample gas used in the channel calibration of the containment hydrogen monitors as required by the Technical Specifications.

A copy of the related safety evaluation supporting Amendment No. 3 to Facility Operating License NPF-12 is enclosed. Also enclosed is a copy of a related notice which has been forwarded to the Office of the Federal Register for publication.

Sincerely,

15/

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

- Enclosures:
1. Amendment No. 3
 2. Safety Evaluation
 3. Federal Register Notice

cc w/enclosure:
See next page

OFFICE	DL:LB#1	OELD	DL:LB#1				
SURNAME	WKane	MYoung	BJYoungblood				
DATE	10/19/82	10/19/82	10/19/82				

8211060430 821020
NF PDR ADOCK 05000395
P PDR

OFFICIAL RECORD COPY

OCT 20 1982

Mr. O. W. Dixon, Jr.
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Post Office Box 764 (Mail Code F-04)
Columbia, South Carolina 29218

cc: Mr. Henry Cyrus
Senior Vice President
South Carolina Public Service Authority
223 North Live Oak Drive
Moncks Corner, South Carolina 29461

J. B. Knotts, Jr., Esq.
Debevoise & Liberman
1200 17th Street, N. W.
Washington, D. C. 20036

Mr. Mark B. Whitaker, Jr.
Group Manager - Nuclear Engineering & Licensing
South Carolina Electric & Gas Company
Post Office 764
Columbia, South Carolina 29218

Mr. Brett Allen Bursey
Route 1, Box 93C
Little Mountain, South Carolina 29076

Resident Inspector/Summer NPS
c/o U. S. NRC
Route 1, Box 64
Jenkinsville, South Carolina 29065

Mr. James P. O'Reilly
U. S. NRC, Region II
101 Marietta Street
Suite 3100
Atlanta, Georgia 30303

OCT 20 1982

Chairman, Fairfield County Council
Post Office Box 293
Winnsboro, South Carolina 29180

State Clearinghouse
Office of the Governor
Division of Administration
1205 Pendleton Street, 4th Floor
Columbia, South Carolina 29201

Attorney General
Box 11549
Columbia, South Carolina 29211

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Director, Criteria & Standards (ANR-460)
Office of Radiation Programs
U. S. Environmental Protection Agency
Washington, D. C. 20460

Director, Eastern Environmental Radiation
Facility
U. S. Environmental Protection Agency
Post Office Box 3009
Montgomery, Alabama 36193

EIS Review Coordinator
U. S. Environmental Protection Agency
Region IV
345 Courtland Street
Atlanta, Georgia 30308

SOUTH CAROLINA ELECTRIC & GAS COMPANY

SOUTH CAROLINA PUBLIC SERVICE AUTHORITY

DOCKET NO. 50-395

VIRGIL C. SUMNER NUCLEAR STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 3
License No. NPF-12

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Virgil C. Sumner Nuclear Station, Unit No. 1 (the facility) Facility Operating License No. NPF-12 filed by the South Carolina Electric & Gas Company acting for itself and South Carolina Public Service Authority (the licensees), dated October 19, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public;
 - E. The issuance of this license amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is hereby amended by page change to the Technical Specifications as indicated in the attachments to this license amendment. Paragraph 2.C(2) of Facility Operating License No. NPF-12 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 3, are hereby incorporated into this license. South Carolina Electric & Gas Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

OFFICE
SURNAME
DA	8211060437	821020
NRC FOR	PDR	ADDOCK	05000395	PDR

OFFICIAL RECORD COPY

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

15/

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

Attachment:
Technical Specification
Changes

Date of Issuance: OCT 20 1982

FRN and amendment

OFFICE ▶	DL:LB#1	OELD <i>BY</i>	DL:LB#1				
SURNAME ▶	WYoung	MYoung	BJYoungblood				
DATE ▶	10/17/82	10/19/82	10/20/82				

ATTACHMENT TO LICENSE AMENDMENT NO. 3

FACILITY OPERATING LICENSE NO. NPF-12

DOCKET NO. 50-395

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the area of the changes.

Amended
Page

3/4 6-21

OFFICE ▶
SURNAME ▶
DATE ▶

CONTAINMENT SYSTEMS

3/4.6.5 COMBUSTIBLE GAS CONTROL

HYDROGEN MONITORS

LIMITING CONDITION FOR OPERATION

3.6.5.1 Two independent containment hydrogen monitors shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTION:

With one hydrogen monitor inoperable, restore the inoperable monitor to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours.

SURVEILLANCE REQUIREMENTS

4.6.5.1 Each hydrogen monitor shall be demonstrated OPERABLE by the performance of an ANALOG CHANNEL OPERATIONAL TEST at least once per 31 days, and at least once per 92 days on a STAGGERED TEST BASIS by performing a CHANNEL CALIBRATION using sample gas containing 19.8 ± 0.1 volume percent hydrogen, balance nitrogen.

CONTAINMENT SYSTEMS -

ELECTRIC HYDROGEN RECOMBINERS

LIMITING CONDITION FOR OPERATION

3.6.5.2 Two independent post accident hydrogen recombiner systems shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTION:

With one hydrogen recombiner system inoperable, restore the inoperable system to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours.

SURVEILLANCE REQUIREMENTS

4.6.5.2 Each hydrogen recombiner system shall be demonstrated OPERABLE:

- a. At least once per 6 months by verifying, during a recombiner system functional test, that the minimum heater sheath temperature increases to greater than or equal to 700°F within 90 minutes. Upon reaching 700°F, increase the power setting to maximum power for 2 minutes and verify that the power meter reads greater than or equal to 60 Kw.
- b. At least once per 18 months by:
 1. Performing a CHANNEL CALIBRATION of all recombiner instrumentation and control circuits,
 2. Verifying through a visual examination that there is no evidence of abnormal conditions within the recombiner enclosure (i.e., loose wiring or structural connections, deposits of foreign materials, etc.), and
 3. Verifying the integrity of all heater electrical circuits by performing a resistance to ground test following the above required functional test. The resistance to ground for any heater phase shall be greater than or equal to 10,000 ohms.

SAFETY EVALUATION BY THE
OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 3
TO LICENSE NPF-12
SOUTH CAROLINA ELECTRIC & GAS COMPANY
SOUTH CAROLINA PUBLIC SERVICE AUTHORITY

INTRODUCTION

By letter, dated October 19, 1982, the South Carolina Electric & Gas Company (SCE&G) requested a change to the Technical Specifications to provide for a tolerance on the hydrogen content of the sample gas used in the calibration of the containment hydrogen monitors.

EVALUATION

The surveillance requirements for containment hydrogen monitors on page 3/4 6-21 require in part the conduct of a periodic channel calibration of the containment hydrogen monitors using sample gas containing 19.8 volume percent hydrogen with the balance nitrogen. The licensee in its letter of October 19, 1982 requested that this surveillance requirement be changed to 19.8 ± 0.1 volume percent hydrogen, balance nitrogen to provide acceptable tolerances to be used in the procurement of the sample gases used for calibration of the instruments.

We have reviewed the above change and conclude that it is administrative in nature and consistent with the basis for our approval of the design of the containment hydrogen monitors during the operating license stage of review.

ENVIRONMENTAL CONSIDERATION

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR Section 51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) because the amendment does not involve a significant increase in the probability or consequences of accidents previously considered and does not involve a significant decrease in a safety margin, the amendment does not involve a

OFFICE
SURNAME	8211060441	821020
DATE	PDR ADDCK	05000395
	P	PDR

significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

DATE: OCT 20 1982

OFFICE	DL:LB#1	DL:LB#1					
SURNAME	W. K. Kelly	B. J. Youngblood					
DATE	10/19/82	10/20/82					

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-395VIRGIL C. SUMNER NUCLEAR STATION, UNIT NO. 1NOTICE OF ISSUANCE OF AMENDMENT TOFACILITY OPERATING LICENSE NO. NPF-12

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 3 to Facility Operating License No. NPF-12, issued to South Carolina Electric & Gas Company and South Carolina Public Service Authority (the licensees) for the Virgil C. Sumner Nuclear Station, Unit No. 1 (the facility) located in Fairfield County, South Carolina. This amendment modifies the Technical Specifications to provide for a tolerance on the hydrogen content of the sample gas used in the calibration of the containment hydrogen monitors. The amendment is effective as of its date of issuance.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. The Commission has made appropriate findings as required by the Act and the Commission's regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5 (d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

OFFICE							
SURNAM	8211060444	821020					
DAT	PDR	ADOCK	05000395				
	P	PDR					

For further details with respect to this action, see (1) South Carolina Electric & Gas Company letter, dated October 19, 1982, (2) Amendment No. 3 to Facility Operating License No. NPF-12 with Appendix A Technical Specifications page changes, and (3) the Commission's related safety evaluation.

All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. 20555 and the Fairfield County Library, Garden and Washington Streets, Winnsboro, South Carolina 29180. A copy of Amendment No. 3 may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this ^{20th} day of October 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

15/

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

FR Notice only

OFFICE	DL:LP#1	OELD	DL:LP#1				
SURNAME	W. K. ...	M. Young	B. J. Youngblood				
DATE	10/19/82	10/19/82	10/19/82				