

June 30, 1986

Docket No. 50-395

Mr. D. A. Nauman
Vice President Nuclear Operations
South Carolina Electric & Gas Company
P.O. Box 764 (Mail Code 167)
Columbia, South Carolina 29218

Dear Mr. Nauman:

DISTRIBUTION

<u>Docket File</u>	B. Grimes	Gray File
NRC PDR	J. Partlow	
Local PDR	T. Barnhart (4)	
PAD#2 Rdg	W. Jones	
T. Novak	V. Benaroya	
D. Miller	Tech Branch	
J. Hopkins	ACRS (10)	
OELD	C. Miles, OPA	
L. Harmon	N. Thompson, DHFT	
E. Jordan	L. Tremper, LFMB	
E. Butcher, AR-5221A		

On May 20, 1986, the Commission issued Amendment No. 50 to Facility Operating License NPF-12 for the Virgil C. Summer Nuclear Station, Unit No. 1. The amendment revised Technical Specification 3/4 8.1 "A.C. Sources," and its bases. The amendment was the result of NRC Generic Letter 84-15, "Proposed Staff Actions to Improve and Maintain Diesel Generator Reliability."

Your staff has brought to our attention an administrative error made on Technical Specification (TS) page 3/4 8-8. Specifically, under "Surveillance Requirements," Section 4.8.1.2, third sentence requirement 4.8.1.1.2.a.5 should have been changed to requirement 4.8.1.1.2.a.4. Enclosed is the TS page marked as "corrected." Other follow-up action relating to your June 10, 1985, submittal will be subject to a subsequent amendment. We have verified that the error does not affect the amendment, the supporting safety evaluation, and the correction is consistent with the amendment.

Please accept our apologies for any inconvenience that the error may have caused.

Sincerely,

/s/
 Jon B. Hopkins, Project Manager
 PWR Project Directorate #2
 Division of PWR Licensing-A
 Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc: See next page

LA:PAD#2
DM Miller
6/5/86

PM:PAD#2
JHopkins:hc
6/26/86

D:PAD#2
Rubenstien
6/26/86

~~OELD
6/ /86~~

Mr. D. A. Nauman
South Carolina Electric & Gas Company

Virgil C. Summer Nuclear Station

cc:

Mr. William A. Williams, Jr.
Technical Assistant - Nuclear Operations
Santee Cooper
P.O. Box 764 (Mail Code 167)
Columbia, South Carolina 29218

J. B. Knotts, Jr., Esq.
Bishop, Liberman, Cook, Purcell
and Reynolds
1200 17th Street, N.W.
Washington, D. C. 20036

Resident Inspector/Summer NPS
c/o U.S. Nuclear Regulatory Commission
Route 1, Box 64
Jenkinsville, South Carolina 29065

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Chairman, Fairfield County Council
P.O. Box 293
Winnsboro, South Carolina 29180

Attorney General
Box 11549
Columbia, South Carolina 29211

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

TABLE 4.8-1

DIESEL GENERATOR TEST SCHEDULE

<u>Number of Failures in Last 20 Valid Tests*</u>	<u>Number of Failures in Last 100 Valid Tests*</u>	<u>Test Frequency</u>
<u><1</u>	<u><4</u>	Once per 31 days
<u>>2**</u>	<u>>5</u>	Once per 7 days

*Criteria for determining number of failures and number of valid tests shall be in accordance with Regulatory Position C.2.e of Regulatory Guide 1.108, but determined on a per diesel generator basis.

For the purposes of determining the required test frequency, the previous test failure count may be reduced to zero if, in conjunction with the manufacturer a complete diesel overhaul to like-new conditions is completed, and if acceptable reliability has been demonstrated. The reliability criterion shall be the successful completion of 14 consecutive tests in a single series. Ten of these tests shall be in accordance with Surveillance Requirement 4.8.1.1.2.a.3; four tests, in accordance with Surveillance Requirement 4.8.1.1.2.d. If this criterion is not satisfied during the first series of tests, any alternate criterion to be used to transvalue the failure count to zero requires NRC approval.

**The associated test frequency shall be maintained until seven consecutive failure free demands have been performed and the number of failures in the last 20 valid demands has been reduced to one.

8607030393 860630
PDR ADOCK 05000395
P PDR

ELECTRICAL POWER SYSTEMS

A.C. SOURCES

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system, and
- b. One diesel generator with:
 1. A day fuel tank containing a minimum volume of 300 gallons of fuel,
 2. A fuel storage system containing a minimum volume of 30,000 gallons of fuel, and
 3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS positive reactivity changes, movement of irradiated fuel, or crane operation with loads over the fuel storage pool. In addition, when in MODE 5 with the Reactor Coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible.

SURVEILLANCE REQUIREMENTS

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the Surveillance Requirements of 4.8.1.1.1, 4.8.1.1.2 (except for requirement 4.8.1.1.2.a.4) and 4.8.1.1.3.