


Hope Creek Generating Station Main Steam Isolation Valve Sealing System Deletion Meeting

NRC – PSEG
Nuclear, LLC
July 18, 2001



Agenda

- Overview – Robert DeNight (10 min)
- X/Q Methodology – John Duffy (10 min)
- Meteorological Data – Bob Yewdall (5 min)
- Dose Analysis – NUCORE – Gopal Patel (15 min)
- Containment Water PH – Barry Barkley (10 min)
- Summary – Robert DeNight (5 min)

MSIV Sealing System Deletion Background

- Original MSIVSS Deletion LCR submitted Dec. 28, '98
- Staff issued a draft SER dated November 14, '00, with identification of open issue – control room habitability.
- PSEG withdrew LCR based on concerns with Control Room (CR) inleakage basis and upcoming Generic Letter 99-02 – Charcoal filter testing Methods.
- PSEG submitted revised LCR for deletion of KP system employing the use of the Alternate Source Term (AST) methodology May 16, '01.

Current Licensing Basis

- **Control Room Habitability – UFSAR 6.4**
- **MSIVSS (Leakage Control System) – UFSAR 6.7**
- **FRVS (Filtration, Recirculation & Ventilation System) – UFSAR 6.8**
- **MSIV System Testing per Tech. Spec. 4.7.2.e.1, 4.7.2.e.2 & 4.7.2.e.3**
- **SLC (Standby Liquid Control) System Description – UFSAR 9.3.5**

Licensing Background

- Control room dose initially evaluated in NRC SER, October 1984
 - design met SRP 6.4 Guidelines
- Amendment No. 30 granted August 7, 1989
 - Tech Spec Surveillance and Testing Requirements for the Filtration, Recirculation, and Ventilation System (FRVS) recirculation filter efficiencies.
- PSEG recalculated Amendment No. 30 control room doses based on TID 14844 Source Term as follows:
 - < 1 Rem Thyroid
 - <<1 Rem Whole Body
 - <1 Rem Skin

MSIV Sealing System Current Design Basis

- Limits fission product leakage through Main Steam lines during DBA / LOCA scenarios.
 - Tech. Spec Limit for MSIV Leakage = 46 scfh
- MSIVSS manual initiation within 20 mins. post LOCA
- Pressurizes MS lines between inboard-outboard MSIVs and outboard MSIVs-MSSVs.
- Sealing system supplied by Primary Containment Instrument and Gas (PCIG) System
- Seismic / Single Failure Proof / 1E power

MSIVSS Deletion LCR

- Deletion of the MSIV steam sealing system
 - Delete MSIVSS from T.S. Section 3.6.1.4 & Table 3.6.3-1
- **Revise T.S. Section 3.6.1.2 for an MSIV leak rate**
 - Currently 46 scfh total
 - New value – total of 250 scfh for all four main steam lines with no one line exceeding 150 scfh.
- Reconstituted Post-LOCA on-site and off-site dose analyses using new methodology.

MSIVSS System Deletion LCR

- SR MSIV-Leakage Treatment Path not credited
- MS Stop Valves Not Closed
- MSs Beyond the MSSV Credited
 - Safety Related / Seismically Qualified
- Main Steam Lead Drain provides defense-in-depth
 - Continuous, passive line
 - Non-safety-related / non-seismic drain to condenser
 - Not credited in the analyses

Revised Dose Calculation Methodology

- DBA dose calculations reconstituted
 - Release pathways conservative
 - System response times validated
 - Limiting single failures investigated
 - Verified limiting flow rates, volumes
 - Met GL 99-02 requirements
 - X/Q values reconstituted
- AST versus TID source term assumed
- Calculation Methodology – RADTRAD V 3.02

Use of Regulatory Guide 1.183

- Full Scope Application
 - Non-LOCA Accidents reviewed
 - LOCA scenario shown to be bounding
 - EQ Dose Profile Reviewed
 - Equipment Qualified life not impacted by change.
 - Vital Access areas being reviewed
 - Several areas are being reconstituted.
- No exceptions to Reg Guide 1.183

X/Q Value Reconstitution

John Duffy



X/Q Methodology

- **Current methodology – Modified-Halitsky**
- **Updated methodology – ARCON96**
 - $\chi/Q_{\text{ARCON96}} > 10 \chi/Q_{\text{modified-Halitsky}}$

Relative Location of MSIV Leakage Release and Control Room Air Intake

- Center Turbine Building air intake louver selected for conservatism
 - On the west side of the building
 - Nearest to control room air intake
 - 28 ft wide X 6 ft high
- Mixing within the Turbine Building is not credited

MS Valve Locations

- Inboard MSIVs - inside drywell
- Outboard MSIVs - in Reactor Building steam tunnel
- Main steam stop valves - in Auxiliary Building steam tunnel
- Main stop valves - in Turbine Building (release location)

Roof Vents

Turbine Building roof vents are further from the control room air intake than the center air intake louver (release to environment location)

ARCON96

- ARCON96 directional inputs are based on plant north
- True North is $5^{\circ}-30'-01''$ east of Plant North
 - $\theta_{\text{true}} = \theta_{\text{plant}} - 5^{\circ}-30'-01''$
 - $\chi/Q_{\text{true}} < \chi/Q_{\text{plant}}$
- No stack flow was assumed

Diffuse Release

- Center louver: 28 ft wide X 6 ft high (columns H and 23)
 - $\sigma_y = (28 \text{ ft})/4.3 = 6.512 \text{ ft} = 1.985 \text{ m}$
 - $\sigma_z = (6 \text{ ft})/2 = 3 \text{ ft} = 0.914 \text{ m}$
- Vent area = $(28 \text{ ft})(6 \text{ ft}) = 168 \text{ ft}^2$

Release Locations

- 4 main stop valves (columns F and 24)
 - 6'-6" separation
- Equivalent release area $\sim 4\pi(3.25 \text{ ft})^2 = 133 \text{ ft}^2$
- Other release points are farther from the control room air intake with larger wake areas

Meteorological Data

Bob Yewdall




Meteorological Monitoring Program Data Quality

- Meets the guidance of Regulatory Guide 1.23 “Onsite Meteorological Programs”
- Incorporates recommendations of ANSI/ANS 3.11-2000 “Determining Meteorological Information at Nuclear Facilities”
- System calibration / PMs performed quarterly

Meteorological Monitoring Program Data Quality

- **Data quality is assured by collecting both analog and digital meteorological data.**
- **Past evaluation of reasonableness of data collection program with respect to regional data performed as part of the initial Salem Unit 2 licensing process.**
- **Only validated meteorological data was used within ARCON96 dispersion calculations.**
- **All units were verified.**

Met Tower



On-site / Off-site Dose Analyses

Gopal Patel



Calculation Methodology

- RADTRAD 3.02 Utilized
- Parametric Studies Performed
 - Determined Compatibility With Current Design Inputs
 - Determined variation of design inputs/ESF functions with respect to dose consequences and variation of doses from current to proposed licensing basis analyses
- Inputs Validated and Verified
- Release Paths Verified
 - Only safety related ESF components credited for dose mitigation
 - SSE design based MS piping credited for MSIV leakage and single active component failures and limiting design values used to maximize dose consequences

Analysis Parameters

- Core isotopic source inventory
 - ORIGEN 2.1
 - 1.05 times licensed power level
- Release Fractions & Timing
 - By radionuclide group
 - Gap and Early In-Vessel releases
- Chemical Form
 - Iodines (A = 95%, E = 4.85%, O = 0.15%)
 - Sump pH >7 (including radiolysis of hypalon)
- Atmospheric Dispersion Factors (χ/Qs)
 - CR χ/Qs from reconstitution effort
 - Site boundary per RG 1.145

Dose Calculation Critical Inputs / Assumptions

- Control Room unfiltered inleakage value of 900 cfm used versus previously assumed 10 cfm.
- GL 99-02 charcoal filter efficiencies assumed
- Plate-out within seismically qualified MS lines, no plate-out assumed in condenser

Release Pathways

- **Containment Leakage**
 - TS Leak Rate (0.5 V%/day) reduced after 24 Hrs
 - Directly released to environment before drawdown
 - Released to Reactor Building after drawdown
 - 50% Mixing in Reactor Building
 - Ground Level Release via FRVS Vent
- **ESF Leakage**
 - Two times administrative limit
 - Directly released to environment before drawdown
 - Released to Reactor Building after drawdown
 - Ground Level Release via FRVS Vent
 - 10% Iodine Flashing Factor per RG 1.183

Release Pathways (Continued)

- **MSIV Leakage**

- 150 scfh In MSIV Failed Line
- 100 scfh In Other Lines
- Aerosol Deposition Based on 40% Monte Carlo Distribution of Settling Velocity Used For Perry Plant
- Elemental Iodine Deposition Based JE Cline Model For Deposition & Re-suspension Rates
- Post-LOCA Containment Airborne Activity Released
- Ground Level Release Via Turbine Building Louvers

- **Containment Purge Release**

- Containment Not Purged During Full Power
- Purge Release Path Not Analyzed

Single Failure Assumptions

- **Four Out of Six FRVS Recirc Trains Maximize Dose / One of Two FRVS Vent Units Utilized**
 - Remove Activity From Reactor Building Slower
 - Reduce Mixing of Activity In Reactor Building (100% to 50%)
- **One Out of Two CREFS Trains Maximizes Dose**
 - Removal of CR Airborne Residual Activity By Recirculation Filter Is Faster Than Increase In Activity From Intake Flow
 - CR Activity Equilibrium Reaches Faster With Higher Recirc Filter Removal Rate

HCGS Dose Results

Post-LOCA Activity Release Path	Post-LOCA TEDE Dose (Rem)		
	Receptor Location		
	Control Room	EAB	LPZ
Containment Leakage	4.50E-01	3.41E-01	1.10E-01
ESF Leakage	2.85E-01	3.51E-02	1.19E-02
MSIV Leakage	3.48E+00	1.92E+00	3.67E-01
CR Filter Shine	2.46E-03	0.00E+00	0.00E+00
Total	4.22E+00	2.30E+00	4.89E-01
Allowable TEDE Limit	5.00E+00	2.50E+01	2.50E+01

pH Calculation Results

Barry Barkley

pH Methodology

- **STARpH code (Polestar) used for pH calculation**
- **HNO₃ from radiolysis of water calculated per NUREG/CR-5732**
 - Radiation field in pool based on energy deposition rates of fission product groups excluding noble gases; fission product group releases based on Reg. Guide 1.183
 - Include decay of fission products with time after reactor shutdown
- **HCl from radiolysis of cable insulation calculated per NUREG/CR-5950**
 - Gamma and beta radiation fields based on energy release rates per unit reactor thermal power as a function of time after reactor shutdown from NUREG/CR-2367, modified to reflect Reg. Guide 1.183 source term
 - Gamma radiation leakage from containment taken into account
 - Shielding of beta radiation by cable tray and conduit taken into account

pH Methodology (Continued)

- **pH calculated taking into account total HNO_3 and HCl added as a function of time and buffer strength in pool (from SLCS actuation) using NUREG/CR-5950**
 - Effect of pool temperature on buffer dissociation constants taken into account

pH Calculation Inputs

- **Material type, mass, and dimensions of chloride-bearing cable insulation (both the hypalon jacket and the EPR insulation contain chloride)**
 - 12,000 lbs total
 - 75% of mass attributed to non-copper (i.e., 9000 lbs)
- **Extent and dimensions of conduit materials**
 - 38% in conduit
- **Buffer content of SLCS**

pH Calculation Assumptions

- Organic acids from paints can be neglected as the $[H^+]$ added from this source is a small fraction of that from HNO_3 and HCl
- No credit is taken for cesium in the buffer calculation
- Unbuffered pH of the pool should remain above 7 for at least several hours even if it is assumed that no cesium exists as $CsOH$ and that only a portion of the cesium exists as $CsBO_2$
- Hypalon jacket and EPR insulation are modeled as a single unit with a thickness of 0.401 cm and a density of 1.40 g/cm^3 (NUREG 1081)

pH Results

- pH of the containment water pool for the Hope Creek plant radiological DBA LOCA is above 8 over a period of 30 days following accident initiation

pH results vs. time

Time	pH
1 h	>8
2h	>8
5h	8.4
12h	8.4
1d	8.4
3d	8.3
10d	8.3
20d	8.3
30d	8.3

SLC Operation

- SAG-1, “Primary Cont. Flooding”
 - Entered Upon Failure to Maintain Adequate Core Cooling in Emergency Ops Procedures
- SAG-1 Initiates SLCS
- SAG-1 Re-established Full Core Submergence

Schedule

- **LCR Submittal - Complete**
- **CR Boundary Envelope Integrity Walkdown - Complete**
- **Tracer Gas Testing - July 23-28**
- **Complete RF-10 Mods. – Oct 29**

KP System Deletion LCR

Question / Answers