ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001 AREA CODE 716 546-2700

August 7, 2001

US Nuclear Regulatory Commission
Document Control Desk
Attn: Robert Clark
Project Directorate I-1
Washington, DC 20555

Subject: Monthly Report for July, 2001
Operating Status Information
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Clark:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of July, 2001.

Very truly yours,

Joseph A. Widay
Plant Manager

xc: U.S. Nuclear Regulatory Commission
Mr. Robert Clark (Mail Stop O-8E9)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

IE24

OPERATING DATA REPORT

50-244

August 7, 2001

COMPLETED BY: John V. Walden

John V. Walden

TELEPHONE (716) 771-3588

OPERATING STATUS

1. Unit Name: **R.E. GINNA NUCLEAR POWER PLANT** **Notes:**
2. Reporting Period: July, 2001
3. Design Electric Rating (Net MWe): 470
4. Maximum Dependable Capacity (Net MWe): 480

	This Month	Yr.-to-Date	Cumulative**
5. Number of hours Reactor Was Critical	744.0	5087.0	227349.2
6. Hours Generator On-line	744.0	5087.0	224233.1
7. Unit Reserve Shutdown Hours	0.0	0.0	8.5 *
8. Net Electrical Energy Generated (MWH)	359116.0	2486826.0	101686107.8

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

DOCKET NO: 50-244
UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT
DATE: August 7, 2001
COMPLETED BY: John V. Walden
TELEPHONE: (716) 771-3588

UNIT SHUTDOWN

REPORTING PERIOD: July, 2001
(Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON(1)	METHOD OF SHUTTING DOWN(2)	CAUSE/CORRECTIVE ACTIONS COMMENTS

SUMMARY:

The unit experienced a downpower to 50% on July 28, 2001 for condenser waterbox cleaning. The unit operated at full power for the remainder of the month of July. Average power for the month of July was 98.8%.

(1) Reason
- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method
- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)