# APPENDIX D DISPOSITION OF QUAD CITIES PRA PEER REVIEW

## HIGH PRIORITY FACT AND OBSERVATIONS

1

<sup>&</sup>lt;sup>1</sup> Quad Cities PRA had no "A" Facts and Observations

#### **Disposition of Quad Cities PRA Peer Review**

As part of the Option 2 implementation, the "A" and "B" Facts and Observations (F&Os) (i.e., the highest priority items) developed by the PRA Peer Review Team during the NEI 00-02 Quad Cities review were examined to assess their impact on the PRA for application to the Option 2 program with respect to Core Spray, SBGTS, and Feedwater.

There are no "A" Fact and Observations (F&Os) findings from the PRA Peer Review. These types of F&Os would have required immediate attention to address before applications are undertaken. Appendix C includes the "B" F&Os for Quad Cities compiled from the PRA Peer Review Report, and for each F&O a summary of the planned resolution is presented. While these resolutions have not been implemented, they are entered into the Exelon tracking systems for commitments, i.e., the URE database, for resolution as part of the next PRA update.

The results of this examination are summarized in Table D-1 by including the intent of the observation and its proposed resolution by Exelon and the potential impact of the item's resolution on the PRA results for Option 2.

#### D-2

#### Table D-1

#### SUMMARY OF THE IMPACT ON THE OPTION 2 PILOT PROGRAM DUE TO A&B FACTS AND OBSERVATIONS FROM THE QUAD CITIES PRA PEER REVIEW

Facts and Observations Description

**Evaluation Notes** 

F & O Impact on Option 2 Pilot Progra m<sup>11)</sup> IE-5

It may be beneficial to include the loss of one DC division as a separate initiator since even though it may not trip the plant, it would lead to a manual plant shutdown with degraded components if the DC division were not recovered.

The documentation states that this would be a low contributor to CDF based on the conditional core damage probability for the loss of feedwater events, but it would probably be best to verify this by including it as its own initiator to eliminate any uncertainty. This is a difficult event to classify. The loss of a single DC division does not cause a scram or turbine trip. Therefore, it logically is not included as a transient initiator. However, the Quad Cities Technical Specifications, Item 3.9.(E) - Distribution - Operating, p. 3/4.9-17 Action (2), specifies that if one of the required <u>distribution systems</u> are not energized, re-energize the system within <u>2 hours</u> or be in <u>hot</u> shutdown within the next <u>12 hours</u> and in <u>cold</u> shutdown within the following <u>24 hours</u>.

This would indicate that it is prudent to consider the loss of a DC bus and a demand to reach safe shutdown as part of the PRA. Therefore, this will be added to the list of initiators. It is found in other studies of BWRs that the common cause loss of DC buses, which is already included in the Quad Cities Negligible

PRA, is by far the largest contributor to risk associated

		with DC bus unavailability.	
		Thus, no substantial change in the risk profile or the importance of SSCs is anticipated from the addition of the single DC bus "initiating event."	
IE-14	The on-line surveillance testing of interfacing system valves has not been included in the development of the ISLOCA initiating event frequency analysis. This could be a dominant contributor to the frequency analysis.	A review of the latest Quad Cities Technical Specifications has been performed to identify the surveillance test interval for the Pressure Isolation Valves (PIVs) involved in the assessment of the ISLOCA contributors. The results of this evaluation indicate that these valves are leak tested and cycled every refueling. (See Section 3/4-7.) In addition, work control has identified that these tests are performed while the unit is shutdown. These results support a minimal impact on the ISLOCA frequency based on the NSAC-154, NUREG/CR-5603 and NUREG/CR-5124 evaluation guidelines.	Negligible
		The ISLOCA evaluation will be revised consistent with NSAC-154 guidelines to ensure that there are no other changes that may influence the ISLOCA frequency contribution to risk.	
AS-14	The end state for %DLOOP tree, DLOP-17, DLOP-20, DLOP-26 and DLOP-27 do not reflect the appropriate	This is a documentation item. The event tree figure and documentation will be updated to reflect this	Negligible

plant damage class (as indicated in the LOOP presentation by the utility.)

TH-10 There is conflicting information regarding the need for room cooling for RCIC. Calculation BSA-Q-97-04 seems to indicate that it is not required, but BSA-Q-96-01 would indicate that it is required. (See QC-PSA-006, Note 4 to Table 2-12)

TH-12 The success criteria notebook (QC-PSA-003) documents the ATWS criteria in Tables 3-1b. However, the success criteria description or supporting text has not been provided. This makes it difficult to trace the bases for the modification. However, the change has no impact on the quantitative results. The Level 1 and Level 2 computer model and its results reflect the appropriate plant damage class. Therefore, the quantification of the risk and its contributors is accurate as is.

There is no conflict in the Quad Cities documentation. The two calculations clearly state when there is a need for room cooling.

RCIC room cooling is only required in the event of a gland seal leakoff failure. This is modeled in the PSA and is supported by calculation BSA-Q-97-04. Gland seal leakoff failure is modeled probabilistically. The RCIC room coolers may be required if both RCIC and Core Spray (which are co-located) are operating at the same time (see calculation BSA-Q-96-01). However, no accident sequences require simultaneous RCIC and CS operating. The operator would terminate CS because it is not required. Therefore, the RCIC room cooling is found to be appropriately modeled.

The modeling assumptions made in the success criteria documentation is reflective of a BWR with limited SRV/SV capacity such as Pilgrim (less than 50% of full power steam flow). This is such that even with successful

Negligible

Negligible

ATWS success criteria.

Subsequent to this observation, written description of ATWS success criteria (draft) was provided to the Certification team. The write-up is and the success criteria tables are slightly inconsistent in terms of the need for FW Trip or runback. It appears that based on new information, the PRA team has decided that FW trip is not required. The success criteria Tables still indicate that FW runback is needed. It is not clear how this issue was modeled in the PRA. RPT, the RPV pressure will continue to rise over the 1 to 2 minute time frame following an MSIV closure isolation. The Quad Cities plant has substantial combined SRV/SV capacity (more than 70% of full power steam flow); and therefore it is found that there is no need for a FW pump trip to prevent overpressure failure as long as RPT is successful. As a result, the current PRA model is slightly conservative because it introduces a failure mode that has been assessed as inapplicable to Quad Cities. The ATWS model is slightly

conservative in the existing model used for the Option 2 analysis; however, the assumed failure results in an insignificant numerical impact. Therefore, the decision-making input from the PRA is unaffected.

The excess discussion of the ATWS success criteria and the associated tables will be modified in the PRA documentation (QC-PSA-003) to reflect the above information and to remove the excess conservatism in the model.

The overpressure effect of continuing FW (motor driven) injection under ATWS conditions has been found to be acceptable.

SY-6 Various piping attached to the CCSTs (i.e. RCIC suction line) is not protected against inadvertent collision with forklifts or other small vehicles. The presence of a vehicle and tire tracks indicate that this is a real probability. This is a vulnerability that could cause a common cause failure of the CST and suction source for several systems

The model does not require FW trip to ensure success for ATWS events with ARI failure. The suggestion is considered a viable insight and has been included in the PRA insights.

The identified event is not an initiating event, and its coincidental failure within the 24 hour mission time of an accident mitigation is considered to be probabilistically insignificant.

Mitigation is approximately 1E-3

SY-26 There is a procedure that requires PSA Engineering to be interfaced with for changes made to the plant. There is not a procedural requirement to include PSA Engineering in the changes made to procedures, surveillances, instructions, etc. that could affect the CDF. CDF ~ 8E-10/yr The On-Site Risk Management Engineer monitors the on-going changes to the plant, procedures, surveillances, and instructions. These are part of the periodic PRA update. A continuous monitoring of these changes is not considered consistent with the recognized periodic PSA update process that is being implemented throughout the industry.

Negligible

Negligible

As part of the Option 2 Pilot PRA application, the Quad Cities Risk Management Engineer

DA-6	The component probabilities data used in the evaluation are based on accumulated plant specific experience. However, the last three years experience has not been included in the accumulated data.	reviewed changes to the plant since the update freeze date and confirmed that one plant modification has been made that would influence the calculations. The modification reduced the importance of FW SSCs. The next periodic update will include the incorporation of plant specific maintenance rule data. In the meantime, a check of the data indicates that the only SSC that have operating experience showing higher unavailability than accounted for is the PRA in the HPCI system.	Negligible
HR-14	The Human Reliability Analysis relied on the analysts' review and interpretation of the QGAs and other procedures. A major enhancement to the scrutability of the analysis would be to factor a structured interview or question process into the analysis and documentation. This could also help to support the cases where execution time was estimated.	The impact on the PSA is that The operator interview questions and results were not available to the PRA Peer Review Team at the time of their review. The operating crew interviews performed to support the HRA included a structured set of questions, the answers to which were used in the evaluation of each of the HEPs in the model. The results of the information gained from the interview process is included in the updated HRA analysis, Section 3. This documentation item is considered resolved. The addition of the documentation to the HRA document did not alter the risk profile.	Negligible
DE-9	Flooding is an important issue that merits further investigation by the Quad Cities PSA staff. At least two	As suggested, internal flooding has been the subject of an on-going update. The internal flood evaluation will	Negligible

potential vulnerabilities exist at the Quad Cities Station in respect to internal flooding. 1) A rubber boot secured by hose clamps on the RCIC suction line (torus room side). 2) Ventilation penetrations below the maximum postulated torus room flood zone.

DE-10 The lack of documented walkdowns provides for a level of uncertainty.

QU-8 In the top 100 sequences, cutset 96 is an ATWS scenario with mechanical scram failure, following loss of feedwater event. Core damage occurs when operator fails to inhibit ADS due to low water level. The HEP credited is for "failure to inhibit ADS w/feedwater injecting." This HEP appears to be misapplied for this sequence, since loss of feedwater

then be incorporated into the PRA. The two specific items cited in the Peer Review comment have been investigated as part of the internal flood update, and it is found that they contribute a negligible degree to the CDF and LERF.

The Observation addresses a documentation issue related to the walkdowns performed on the Quad Cities plant. Currently, although multiple walkdowns were performed, no walkdown notes are available except those developed as part of: (a)the internal flood walkdowns in 1992 and 2001 (b)the RI-ISI project (c)the fire events PRA Update.

The dependency analysis itself was not criticized and is judged by Exelon to be at the state-of-the-technology. The incorporation of walkdown notes would further enhance the dependency documentation but is not believed to affect the model quantification. ADS inhibit during ATWS events is modeled with two HEPs as follows: ADS inhibit with FW initially available (event 1ADOP-INHIBHPH--; HEP = 1.4E-2) ADS inhibit will FW unavailable (event 1APOPINHIBIT-H--; HEP = 3.4E-2)

Nealiaible

QU-15	is the initiator.	This anomaly is related to the use of the ONE4ALL model. Cutset 96 is a non-minimal cutset that should be removed from the model. Cutset 44 provides a similar scenario with FW unavailable and uses the appropriate HEP of 3.4E-2. Therefore, the current model provides conservative results. However, the quantitative impact is judged to be minor (less than 1%). The model, flag files, and mutually exclusive files, should be reviewed to ensure that for sequences with FW failure, additional cutsets with ADS inhibit for FW success are not included in the final cutsets. In addition, the ONE4ALL model should be updated to explicitly account for all event tree success paths. This will eliminate the potential for including HEPs for FW success even though FW previously failed. The EDG capacity is 2850 kw rated (2000 hrs/yr). The load for SBO Response on 2 units with RHR and RHRSW pumps is 1290 kw/unit = 2580 kw total. Therefore a single EDG could carry the RHR/RHRSW loads of both units. Alternatively, the loads do not need to be continuously present but rather could be switched back and forth as necessary to maintain plant conditions. Quad Cities has a procedure to allow powering both units for safe shutdown from the swing EDG QCOA 6100-03 (Rev 9).	Negligible
QU-26	An uncertainty analysis was not performed as part of D-9	An uncertainty evaluation was performed in	Negligible

	the evaluation of the model results.	response to this F&O. The evaluation references the parametric uncertainty analysis performed on similar plants and reviews the types of uncertainty along with the practical insights to be derived from the uncertainty analysis.	
QU-26	No special sensitivity or uncertainty cases have been performed. Typically sensitivity studies accompany the dominant sequences, initiators or other modeling feature (such as vessel rupture initiating event) which may dominate the uncertainty of the CDF point estimate of CDF. This information is needed to establish the acceptability of the final results.	See the Uncertainty Evaluation for the results. Sensitively evaluations were performed in response to this F&O. See the Uncertainty Evaluation for the results.	Negligible
L1-7, 13 The transfer from L1 to L2 PRA is done by	The current conditional LERF probability is close to 0.7. The system dependencies are overwhelmed by the conservative treatment of the Level 2 phenomenological dependencies.	Negligible	
carryin g the plant	Incorporation of a more realistic assessment, including the incorporation of the Level 1		

damag e state frequen cies. The	dependencies in a less conservative mann would result in reducing the LERF frequen and LERF conditional probability.	ner Icy
The depend ency of system s examin ed in the L2 PRA on the support system s that might have been disable d in the L1 PRA cannot be accoun ted for	(See L2, 7, 20)	
ely.		
L2- 7, 20		
The	The LERF model is recognized as	Negligible

Level 2 evaluati on is	conservative and potentially limiting for certain applications.	
on is not directly linked with the Level 1 results. Instead , LERF multipli ers are applied to each of the sequen ces from the Level 1. A more detaile d linking approa ch may be desirab le, especia lly with	It has not been limiting for the Option 2 PSA evaluation.	

the
currentl
y high
conditio
nal
LERF
value
of (~0.7
with
Class 2
events
include
d, ~0.4
without
Class 2
events
include
d). The
conser
vatisms
include
d by
not
directly
linking
the
cutsets
may be
severel
y Vissities
limiting
TOP
Intende

d applicat ions.		
L2-24		
The simplif ied appro ach of focusi ng only of LERF seque nces by using factor s	See L2-7, 13 and L2-7, 20	Negligible
ies		
the		
appro		
ach		
SIGUIU		

cantly
and
nossih
p03310
IY
make
s it
conse
rvativ
e.
Becau
se of
thic
UIIS alimana lif
simplif
ication
, the
appro
ach
mav
he too
CONSE
rvativ
e for
Risk-
inform
ed
applic
ations
allong

•

MU-1, 3

The existin g guida nce in	The Exelon PRA Programs have been drawn together with a single focal point, Dr. W.E. Burchill. Under his leadership, the Exelon PRAs and the programmatic directions are being updated and upgraded.
17-04	At the time of the Quad Cities PRA Peer
is at a	Review, the PRA Program guidance and
progra	procedures were in the final stages of
mmati	completion. The PRA Peer Review Team did
С,	not review either the upgraded program
conce	procedures or their implementation.
ptual	
level.	Approximately, one year later, the Dresden
There	PRA received a PRA Peer Review. This Peer
are	Review Team had access to the updated
very	Exelon program procedures and guidance,
tew	i.e., the same guidance that is now used for
workin	Quad Cities.
gievei	The results of the DDA Deer Deview of the
aocu	I ne results of the PRA Peer Review of the
ments	Maintenance and Update Program for
III nlaac	Dresden (Identical to that now in force for
place	Quad Cilles) were the following:
ιΟ	

Negligible

allow the	The grades were all 3 and 4 except one 2 related to in-house independence of the
updat	checker
е	An overall grade of 3 was assigned to the
team	Maintenance and Update Element consistent
to	with the Option 2 expectation
perfor	No Fact and Observations were identified for
m	Dresden
PSA	Qualitatively, the Team stated:
updat	
es	The guidance for model maintenance and
withou	update at Dresden is superior. Inputs for the
t	MU process are described in Dresden
relyin	procedure ER-AA-600. Changes that impact
g	the PRA model are tracked in a computerized
solely	database. This is a superior practice.
on the	Computer program update and maintenance
"skill	is controlled by procedures. Training is
of the	performed after PRA updates, but not
craft".	necessarily on software revisions. A list of
	applications to be re-evaluated is contained in
	a computerized database. This is a superior
	practice.

Based on the Dresden PRA Peer Review results and similar results for the Byron and Braidwood PRA Peer Reviews, it is judged that the Maintenance and Update process at

MU-4	Exelon is superior and that the Quad Cities F&Os are resolved by virtue of the subsequent program changes and implementation efforts.	
Enhan ce the data collect ion phase of the updat e proce ss to includ e the followi ng eleme nts that the "Monit oring and	This is resolved—see MU 1,3 resolution, but the following have not yet been included: Industry studies Operator training programs	Negligible

Collec		
ting		
New		
Inform		
ation"		
sub-		
eleme		
nt		
sugge		
sted		
was		
missin		
a from		
the		
updat		
e		
proce		
dure:		
duro.		
Onera		
ting		
experi		
ence		
New		
maint		
enanc		
nolicia		
policie		

S			
Opera			
tor			
Traini			
ng			
Progr			
am			
Emer			
gency			
Plan			
chang			
es			
Accid			
ent			
Mana			
geme			
nt			
Progr			
ams			
Indust			
ry			
Studie			
S			
_			
Espec			
ially			
import			
ant in			

this proce ss will be the true integr ation of the syste m engin eers and operat ions perso nnel into the updat e proce ss. MU-6	
The updat e of	Currently the models are stored in at least three separate locations. This is not considered to practically affect the technical assessments of current or future applications. (See also Response to MU 1,3)

Negligible

PSA		
model		
files is		
menti		
oned		
in		
NEP-		
17-04,		
but		
the		
contro		
l of		
these		
model		
s is		
not		
addre		
ssed.		
The		
contro		
l of		
the		
FORT		
E and		
EOOS		
codes		
have		
been		

addre		
ssed		
in		
draft		
form		
to		
compl		
y with		
NSP-		
CC-		
3021,		
but		
the is		
no		
guida		
nce		
for the		
safeg		
uard		
of the		
PSA		
model		
files.		
<b>D</b>		
PSA		
model		
s and		
sensiti		

vity		
studie		
s are		
not		
stored		
in a		
contro		
lled		
mann		
er,		
and		
the		
official		
copies		
of the		
PSA		
model		
s are		
limited		
tO		
tnose		
avalla		
ble on		
the		
analys		
l S norae		
perso		
l iai		

comp			
uter's			
hard			
drive			
and			
floppy			
disk			
box.			
These			
two			
storag			
e			
locatio			
ns do			
not			
provid			
e the			
safeg			
uards			
neede			
d to			
ensur			
е			
model			
fidelity			

MU-7,

11

Sectio n 5 2 2	See Response to MU 1,3. The Program now includes:
of F NEP- I 17-04 descri bes the period ic updat	Re-evaluation of past PRA applications. n addition, the implementation of the Plan has resulted in a precedence set for each plant of a Risk Insights document that compiles the practical insights found during the PRA that can be implemented. A definition of "vulnerability" has not been established. This is not considered necessary.
proce ss. The followi ng findin gs apply to this sectio n of the proce	Finally an uncertainty analysis has been prepared for Quad Cities. This analysis is an addendum to the Quantification Notebook (QC-PSA-014).

Negligible

S				
R				
	thio			
St				
IS	a			
n	W			
p	oce			
d	ire,			
tr	е			
re	sult			
S	of			
th	e			
u	e of			
th	S			
р	oce			
d	Ire			
Ca	inno			
t	e			
re	view			
e	l.			
Н	owe			
Ve	er,			
th	е			
e	eme			
n	s of			
th	е			
р	oce			
St				

outlin			
outini			
ea			
can			
be			
comp			
ared			
to the			
certific			
ation			
criteri			
2			
а.			
There			
are			
throo			
aspec			
ts of			
the			
updat			
е			
proce			
SS			
that			
are			
not			
adequ			
ately			
addre			
addre			

ssed.			
The			
first is			
the re-			
evalu			
ation			
of			
Past			
PSA			
applic			
ations			
. The			
proce			
dure			
briefly			
menti			
ons			
that			
past			
PSA			
applic			
alions			
d bo			
ed			
and			
undat			
apuur			

ed as			
appro			
priate.			
This			
needs			
to be			
streng			
thene			
d,			
especi			
ally if			
past			
PSA			
applic			
ations			
have			
serve			
d as			
the			
bases			
TOP			
risk informa			
Inform			
ea Tach			
rech Spoo			
or			
Ui			

ng basis submi ttals. It is vital to deter mine if PSA model chang es will invalid ate the bases for submi ttals made			
to the			
NRC.			
The secon d			
aspec t is			

uncert			
ainty			
analys			
is.			
The			
undat			
Δ			
nroce			
dure			
ie			
silont			
on the			
nood			
te de			
lo do			
anny			
analys			
es for			
PSA			
model			
and			
result			
S			
updat			
e.			
Ine			
review			
ers			

have			
noted			
that in			
order			
to be			
succe			
ssful			
with			
risk			
inform			
ed			
applic			
ations			
in the			
future,			
uncert			
ainty			
needs			
to be			
addre			
ssed.			
The			
third			
aspec			
t IS			
handlı			
ng of			

the			
insight			
s from			
the			
updat			
e,			
especi			
ally in			
terms			
of			
identifi			
cation			
of			
vulner			
abilitie			
s and			
enhan			
ceme			
nts.			
Detail			
ed			
guida			
nce is			
neede			
d for			
the			
identifi			
cation			

of			
vulner			
abilitie			
S			
discov			
ered			
durina			
the			
undat			
e			
proce			
ss as			
well			
as			
enhan			
ceme			
nts for			
statio			
n			
proce			
dures			
and			
other			
plant			
progra			
ms			
such			
as the			

emerg ency plan. MU-9		
Proce dure NEP- 17-04, as it is writte n, does not meet the intent of this sub- eleme nt to have knowl edgea ble peopl e review	See Response to MU 1,3.	Negligible

the			
result			
s of			
the			
analys			
is			
Dartic			
raitic			
laakin			
g is			
Input			
from			
Opera			
tions,			
Opera			
tor			
Traini			
ng,			
and			
possib			
ly			
from			
outsid			
е			
indust			
ry			
expert			

S. MU-12

This F&O	This has been completed (see ER-AA-600).	Negligible
sses		
the deficie		
ncies obser		
ved in		
tne Maint		
enanc		
Updat		
e Proce		
SS		
seen at the		
Down		
er's Grove		
corpor		
ate		
offices		

Com
monw
ealth
Ediso
n
wrote
NEP-
17-04
to
codify
the
Maint
onanc
e anu Undot
Opdat
e
Proce
ss for
the
entire
Nucle
ar
Opera
tions
Divisi

•

on.
As of
this
Certifi
cation
visit,
this
proce
dure
has
not
been
imple
mente
d for
the
Quad
Cities
PSA,
and is
oniy
begin nin n
ning to bo
mente
d for

PSA			
Group			
•			
The			
followi			
ng are			
oboor			
Obser			
vation			
s that			
pertai			
n to			
activiti			
es			
perfor			
med			
solely			
SUCTY			
at the			
corpor			
ate			
offices			
emeee			
The sec			
They			
are			
listed			
by the			
otopo			
sieps			
in			

	NEP- 17-04 that apply.		
5.1.1.3	The PSA super visor/ desig nee does not maint ain a histori cal record of PSA updat		
5.1.1.4	es The super visor/ desig nee does		

not
maint
ain an
appro
ved
listing
of the
proper
softwa
re/cod
e for
PSA
applic
ation.
The
corpor
ate
offices
do,
howev
er,
abide
by the
requir
ement
s of
NSP-
CC-

	3021		
	for		
	contro		
	l of		
	softwa		
	re		
	codes		
	, but		
	this		
	applie		
	s only		
	to the		
	EOOS		
	/OSP		
	RE		
	codes		
	that		
	are		
	run		
	from		
	the		
	LAN/		
	WAN.		
5.1.1.5	The		
	super		
	visor/		
	desig		
	nee		

	does not maint ain a record of the qualifi cation of perso nnel	
	assign ed to the	
	updat e	
5.1.2.2	tasks. The PSA	
	analys ts are not	
	perfor ming	
	analys is of	
	plant	

	chang es for the Quad Cities PSA model				
5.1.2.4	The				
	PSA				
	analys				
	ts are				
	not				
	review				
	ing				
	the				
	NFS				
	calcul				
	ation				
	logs				
	on a				
	quarte				
	rly				
	basis.				
	MU-12,				
	13				

Com monw ealth Ediso	This procedure is currently being revised, but the current procedure or changes do not influence the on- going applications. Future PRA updates could be affected by the final resolution of these procedures.	Negligible
n		
wrote		
NEP-		
17-04 to		
codify		
the		
PSA		
Maint		
enanc		
e and		
Updat		
e Proce		
ss for		
the		
entire		
Nucle		
ar		
Opera		
tions		
on		
As of		

this			
Certifi			
cation			
visit,			
this			
proce			
dure			
has			
not			
been			
imple			
mente			
d for			
the			
Quad			
Cities			
PSA,			
and is			
only			
begin			
ning			
to be			
Imple			
mente			
d for			
r JA Craun			
Group			

The
followi
ng are
obser
vation
s that
pertai
n to
activiti
es
perfor
med
at the
sites.
They
are
listed
by the
steps
in
NEP-
17-04
that
apply.

•

5.1.3.1 The

	Quad		
	Cities		
	site		
	PSA		
	analys		
	tis		
	not		
	activel		
	у		
	involv		
	ed		
	with		
	the		
	PSA		
	updat		
	es as		
	part of		
	the		
	updat		
	e		
	team.		
5.1.3.2	The		
	Quad		
	Cities		
	site		
	PSA		
	analys		
	t does		

	not
	perfor
	m
	indep
	enden
	t
	review
	s of
	PSA
	updat
	es
	perfor
	med
	for
	other
	statio
	ns.
5.1.3.4/ 5.2	.3.3
	The
	Quad
	Cities
	site
	PSA
	analys
	t does
	not
	review
	the

site calcul ation logs on a quarte rly basis for impac							
ts to the PSA model							
The syste m engin eers do not receiv e trainin g on the PSA,							
	site calcul ation logs on a quarte rly basis for impac ts to the PSA model The syste m engin eers do not receiv e trainin g on the PSA, and	site calcul ation logs on a quarte rly basis for impac ts to the PSA model The syste m engin eers do not receiv e trainin g on the PSA,	site calcul ation logs on a quarte rly basis for impac ts to the PSA model The syste m engin eers do not receiv e trainin g on the PSA,	site calcul ation logs on a quarte rly basis for impac ts to the PSA model The syste m engin eers do not receiv e trainin g on the PSA,	site calcul ation logs on a quarte rly basis for impac ts to the PSA model	site calcul ation logs on a quarte rly basis for impac ts to the PSA model The syste m engin eers do not receiv e trainin g on the PSA, and	site calcul ation logs on a quarte rly basis for impac ts to the PSA model The syste m engin eers do not receiv e trainin g on the PSA, and

	theref			
	ore			
	canno			
	t be			
	held			
	respo			
	nsible			
	for			
	beina			
	knowl			
	edgea			
	ble for			
	inform			
	ation			
	contai			
	ned in			
	the			
	PSA			
	svste			
	m			
	noteb			
	ooks.			
5.1.5.2	The			
	svste			
	m			
	engin			
	eers			
	(or the			
	•			

desig			
nees)			
do not			
receiv			
e			
trainin			
a on			
the			
PSA			
and			
theref			
ore			
canno			
t he			
held			
respo			
nsible			
for			
consid			
erina			
the			
impac			
tof			
the			
PSA			
model			
when			
the			

	syste			
	m			
	engin			
	eer			
	initiate			
	s or is			
	made			
	aware			
	of			
	plant			
	chang			
	es.			
5.1.6.1	The			
	proce			
	dure			
	writer			
	S,			
	operat			
	ing			
	proce			
	dure/p			
	olicy			
	review			
	ers,			
	and			
	EOP			
	writer			
	s do			

not			
rece	eiv		
е			
train	in		
a or	1		
the			
PSA			
and	•,		
ther	ef		
ore			
cani	no		
t he			
held			
resr	0		
neih			
for			
cone	bid		
orin	a		
the	9		
imn	20		
t of			
t UI	20		
pioc			
or	5		
	2) /		
polic	by and		
cnai	ig		
es o	n		
tne			

PSA model			
The lack of quality input from			
the plant preve nts the kind			
of indep enden t			
review expec ted in eleme nt			
MU- 13.			

MU-12

The	The on-site PRA engineer is familiar with plant	Negligible	
PRA	hardware, procedural, and Technical Specification		
engine	changes. These changes are factored into the PRA		
er is	on a periodic update basis. Other more extraordinary		
automa	measures are not considered warranted.		
tically			
not in			
the			
loop for			
change			
s to			
plant			
proced			
ures			
and			
Techni			
cal			
specific			
ations			
that			
could			
impact			
the			
PRA			
results.			
lt			
appear			
s that			
PRA			
engine			
eris			
consult			
ed on			

plant	
modific	
ations	
though	
it is not	
clear	
that	
there is	
d formali	
zed	
proced	
ure for	
this.	
Assessed impact on Core Spray, SBGTS, and Feedwater Safety Significance determination.	

<sup>1</sup>1)