



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

April 10, 1991

MEMORANDUM FOR: Sholly Coordinator

FROM: George F. Wunder, Project Manager
Project Directorate II-1
Division of Reactor Projects I/II

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE
(TAC NO. 79682)

South Carolina Electric & Gas Company, South Carolina Public Service Authority,

Docket No. 50-395, Virgil C. Summer Nuclear Station, Unit No. 1,

Fairfield County, South Carolina

Date of application for amendment: February 4, 1991

Brief description of amendment: The amendment changes the Technical Specifications to allow a one-time extension of the test interval for the third Type A test in the first 10-year service period, provided the unit shutdown occurs by June 1, 1993, and provided the Type A test is performed before restart from Refueling Outage No. 7.

Date of issuance: April 10, 1991.

Effective date: April 10, 1991.

Amendment No.: 97

Facility Operating License No. NPF-12. Amendment revises the Technical Specifications.

Date of initial notice in FEDERAL REGISTER: March 6, 1991 (56 FR 9385)

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 10, 1991.

No significant hazards consideration comments received: No

Local Public Document Room location: Fairfield County Library, Garden and Washington Streets, Winnsboro, South Carolina 29180.

Original signed by:

George F. Wunder, Project Manager
Project Directorate II-1
Division of Reactor Projects I/II

OFC	:LA:PD21:DRPE	:PM:PD21:DRPE	:OGC	:D:PD21:DRPE	:
NAME	:PAnderson	:GWunder	:CPW	:EAdensam	:
DATE	:3/12/91	:3/12/91	:3/12/91	:3/18/91	:

OFFICIAL RECORD COPY

Document Name: SUMMER SHOLLY ISSU 79682