

DO NOT REMOVE

Docket No. 50-395

Mr. John L. Skolds
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
P.O. Box 88
Jenkinsville, South Carolina 29065

Posted
Collection to
Amdt. 94 to NPF-12

Dear Mr. Skolds:

SUBJECT: AMENDMENT NO. 94 TO FACILITY OPERATING LICENSE NO. NPF-12
REGARDING TECHNICAL SPECIFICATIONS 3/4.4.2 VIRGIL C. SUMMER
NUCLEAR STATION, UNIT NO. 1 (TAC NO. 76867)

By letter dated January 10, 1991, Amendment No. 94 to Facility Operating License No. NPF-12 for the Virgil C. Summer Nuclear Station, Unit No. 1, was issued. The amendment consists of changes to the Technical Specifications in response to your application dated May 16, 1990, as supplemented August 13, 1990.

In a telephone call on February 11, 1991, David Haile of your staff pointed out that an asterisk following Limiting Condition for Operation 3.4.2.1 had inadvertently been left in. This letter forwards the corrected Technical Specification page.

Sincerely,

Original Signed By:

George W. Wunder, Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

OFC	:LA:PD21:DRPE	:PM:PD21:DRPE	:D:PD21:DRPE	:	:
	:PAnderson	:G Wunder	:EAdensam	:	:
DATE	:2/14/91	:2/14/91	:2/14/91	:	:

Mr. John L. Skolds
South Carolina Electric & Gas Company

Virgil C. Summer Nuclear Station

cc:

Mr. R. J. White
Nuclear Coordinator
S.C. Public Service Authority
c/o Virgil C. Summer Nuclear Station
P. O. Box 88 (Mail Code 802)
Jenkinsville, South Carolina 29065

J. B. Knotts, Jr., Esq.
Bishop, Cook, Purcell
and Reynolds
1400 L Street, N.W.
Washington, D. C. 20005-3502

Resident Inspector/Summer NPS
c/o U.S. Nuclear Regulatory Commission
Route 1, Box 64
Jenkinsville, South Carolina 29065

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Chairman, Fairfield County Council
P. O. Box 293
Winnsboro, South Carolina 29180

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

South Carolina Electric & Gas Company
Mr. A. R. Koon, Jr., Manager
Nuclear Licensing
Virgil C. Summer Nuclear Station
P. O. Box 88
Jenkinsville, South Carolina 29065

REACTOR COOLANT SYSTEM

3/4.4.2 SAFETY VALVES

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.4.2.1 A minimum of one pressurizer code safety valve shall be OPERABLE with a lift setting of 2485 PSIG \pm 3%.*

APPLICABILITY: MODES 4 and 5.

ACTION:

With no pressurizer code safety valve OPERABLE, immediately suspend all operations involving positive reactivity changes and place an OPERABLE residual heat removal loop into operation in the shutdown cooling mode.

SURVEILLANCE REQUIREMENTS

4.4.2.1 The Surveillance Requirements of Specification 4.0.5 shall be met, or; the pressurizer code safety valve shall have its lift set pressure verified under cold conditions.