

December 14, 1988

DISTRIBUTION

Docket File
NRC PDR
Local PDR
PD21 r/f
S. Varga (14E4)
G. Lainas
E. Adensam
P. Anderson
J. Hayes
OGC
D. Hagan (MNBB 3302)
E. Jordan (MNBB 3302)
B. Grimes (9A2)
T. Barnhart (4) (P1-137)
W. Jones (P-130A)
E. Butcher (11F23)
W. Hodges (8E23)
ACRS (10)
GPA/PA
ARM/LFMB

Docket No. 50-395

Mr. O. S. Bradham
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, South Carolina 29065

Dear Mr. Bradham:

SUBJECT: CORRECTION TO AMENDMENT NO. 75 REGARDING VANTAGE 5 IMPROVED
FUEL DESIGN - VIRGIL C. SUMMER NUCLEAR STATION (TAC NO. 68644)

Amendment 75 to the Virgil C. Summer Nuclear Station License NPF-12 was transmitted to you by letter dated October 28, 1988. This transmittal contained an error on page 3/4 2-16. The pressurizer pressure limits for three loop operation should have read greater than or equal to 2206 psia and not less than or equal to as indicated in our October 28, 1988 transmittal. A corrected page for the Amendment is included.

Sincerely,

John J. Hayes, Jr., Project Manager
Project Directorate II-1
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

8812210044 881214
PDR ADDCK 05000395
P PNU

Enclosure:
Corrected pages

cc w/enclosure:
See next page

SUM LTR TAC 677811

DFD1

CP-1 cc

OFC	: LA: PD21: DRPR: PM: PD21: DRPR: D: PD21: DRPR :	:	:	:	:	:	:	:
NAME	: P. Anderson : J. Hayes: jfw: E. Adensam :	:	:	:	:	:	:	:
DATE	: 12/12/88 : 12/12/88 : 12/12/88 :	:	:	:	:	:	:	:

Mr. O. S. Bradham
South Carolina Electric & Gas Company

Virgil C. Summer Nuclear Station

cc:

Mr. William A. Williams, Jr.
Technical Assistant - Nuclear Operations
Santee Cooper
P.O. Box 764 (Mail Code 153)
Columbia, South Carolina 29218

J. B. Knotts, Jr., Esq.
Bishop, Cook, Purcell
and Reynolds
1400 L Street, N.W.
Washington, D. C. 20005-3502

Resident Inspector/Summer NPS
c/o U.S. Nuclear Regulatory Commission
Route 1, Box 64
Jenkinsville, South Carolina 29065

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Chairman, Fairfield County Council
P.O. Box 293
Winnsboro, South Carolina 29180

Attorney General
Box 11549
Columbia, South Carolina 29211

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

South Carolina Electric & Gas Company
Mr. A. R. Koon, Jr., Manager
Nuclear Licensing
Virgil C. Summer Nuclear Station
P. O. Box 88
Jenkinsville, South Carolina 29065

ENCLOSURE

ATTACHMENT TO LICENSE AMENDMENT NO. 75
TO FACILITY OPERATING LICENSE NO. NPF-12
DOCKET NO. 50-395

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. This page contained an error.

Remove Pages

3/4 2-16

Insert Pages

3/4 2-16

TABLE 3.2-1
DNB PARAMETERS

<u>PARAMETER</u>	<u>LIMITS</u>	
	<u>3 Loops In Operation</u>	<u>2 Loops in Operation</u>
Reactor Coolant System T _{avg}	≤ 591.7°F	**
Pressurizer Pressure	≥ 2206 psia*	**

* Limit not applicable during either a THERMAL POWER ramp in excess of 5% of RATED THERMAL POWER per minute or a THERMAL POWER step in excess of 10% of RATED THERMAL POWER.

** These values left blank pending NRC approval of two-loop operation.

8812210050 881214
PDR ADOCK 05000395
P PNU