

November 3, 1988

Docket No. 50-395

DISTRIBUTION

Mr. O. S. Bradham  
Vice President, Nuclear Operations  
South Carolina Electric & Gas Company  
Virgil C. Summer Nuclear Station  
P. O. Box 88  
Jenkinsville, South Carolina 29065

Docket File  
NRC PDR  
Local PDR  
PD21 r/f  
S. Varga (14E4)  
G. Lainas  
E. Adensam  
P. Anderson  
J. Hayes  
OGC

D. Hagan (MNBB 3302)  
E. Jordan (MNBB 3302)  
B. Grimes (9A2)  
T. Barnhart (4) (P1-37)  
W. Jones (P-130A)  
E. Butcher (11F23)  
W. Hodges (8E23)  
ACRS (10)  
GPA/PA  
ARM/LFMB

Dear Mr. Bradham:

SUBJECT: CORRECTION TO AMENDMENT NO. 74 REGARDING VANTAGE 5 IMPROVED FUEL DESIGN - VIRGIL C. SUMMER NUCLEAR STATION (TAC NO. 677811)

Amendment 74 to the Virgil Summer Nuclear Station License NPF-12 was transmitted to you by letter dated October 28, 1988. This transmittal indicated that page 5-7(a) was to be deleted. That was incorrect. A correct page for the Amendment is included as is a copy of page 5-7(a).

Sincerely,

John J. Hayes, Jr., Project Manager  
Project Directorate II-1  
Division of Reactor Projects I/II

Enclosure:  
Corrected pages

cc w/enclosure:  
See next page

|      |  |   |          |   |          |   |   |   |
|------|--|---|----------|---|----------|---|---|---|
| OFC  | :LA:PD21:DRPR:PM:PD21:DRPR:D:PD21:DRPR     | : | :        | : | :        | : | : | : |
| NAME | :P. Anderson : J. Hayes : jfw : E. Adensam | : | :        | : | :        | : | : | : |
| DATE | :11/3/88                                   | : | :11/3/88 | : | :11/3/88 | : | : | : |

OFFICIAL RECORD COPY

8811080247 881103  
PDR ADOCK 05000395  
PDC

DF01  
11

Mr. O. S. Bradham  
South Carolina Electric & Gas Company

Virgil C. Summer Nuclear Station

cc:

Mr. William A. Williams, Jr.  
Technical Assistant - Nuclear Operations  
Santee Cooper  
P.O. Box 764 (Mail Code 153)  
Columbia, South Carolina 29218

J. B. Knotts, Jr., Esq.  
Bishop, Cook, Purcell  
and Reynolds  
1400 L Street, N.W.  
Washington, D. C. 20005-3502

Resident Inspector/Summer NPS  
c/o U.S. Nuclear Regulatory Commission  
Route 1, Box 64  
Jenkinsville, South Carolina 29065

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission,  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30323

Chairman, Fairfield County Council  
P.O. Box 293  
Windsboro, South Carolina 29180

Attorney General  
Box 11549  
Columbia, South Carolina 29211

Mr. Heyward G. Shealy, Chief  
Bureau of Radiological Health  
South Carolina Department of Health  
and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

South Carolina Electric & Gas Company  
Mr. A. R. Koon, Jr., Manager  
Nuclear Licensing  
Virgil C. Summer Nuclear Station  
P. O. Box 88  
Jenkinsville, South Carolina 29065

ATTACHMENT TO LICENSE AMENDMENT NO. 74  
TO FACILITY OPERATING LICENSE NO. NPF-12  
DOCKET NO. 50-395

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

| <u>Remove Pages</u> | <u>Insert Pages</u> |
|---------------------|---------------------|
| 3/4 9-15            | 3/4 9-15            |
| 3/4 9-16            | 3/4 9-16            |
| 5-6                 | 5-6                 |
| 5-7                 | 5-7                 |

8811080256 881103  
PDR ADOCK 05000395  
P PDR

## DESIGN FEATURES

---

### CAPACITY

5.6.3 The spent fuel pool is designed and shall be maintained with a storage capacity limited to no more than 1276 fuel assemblies, 242 in Region 1, 99 in Region 2, and 935 in Region 3.

### 5.7 COMPONENT CYCLIC OR TRANSIENT LIMIT

5.7.1 The components identified in Table 5.7-1 are designed and shall be maintained within the cyclic or transient limits of Table 5.7-1.