

September 1, 1993

Docket No. 50-395

DISTRIBUTION
See attached page

Mr. John L. Skolds, Vice President
Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, South Carolina 29065

Dear Mr. Skolds:

SUBJECT: CORRECTION PAGE FOR AMENDMENT NO. 114 TO FACILITY OPERATING LICENSE NO. NPF-12 FOR VIRGIL C. SUMMER NUCLEAR STATION, UNIT NO. 1

On August 19, 1993, the Nuclear Regulatory Commission issued Amendment No. 114 to change the Technical Specifications (TS) to Facility Operating License NPF-12 for the Virgil C. Summer Nuclear Station, Unit No. 1. Page 3/4 7-4 issued with the amendment did not reflect the change made in Amendment No. 112 to TS 4.7.1.2.a.1.

The enclosed TS page reflects the change.

We regret any inconvenience this may have caused.

Sincerely,

Original signed by:
Brenda Mozafari for:

George F. Wunder, Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
TS page 3/4 7-4

cc w/enclosure:
See next page

NRC FILE CENTER COPY

OFFICE	LA: PD21:DRPE	PM: PD21:DRPE	D: PD21:DRPE	
NAME	PAnderson	GWunder:dt	SBajwa	
DATE	8/31/93	8/31/93	8/31/93	

Document Name: SUM86930.COR

9309090424 930901
PDR ADOCK 05000395
PDR

CP-1

DFD1

Mr. John L. Skolds
South Carolina Electric & Gas Company

Virgil C. Summer Nuclear Station

cc:

Mr. R. J. White
Nuclear Coordinator
S.C. Public Service Authority
c/o Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 802
Jenkinsville, South Carolina 29065

J. B. Knotts, Jr., Esquire
Winston & Strawn Law Firm
1400 L Street, N.W.
Washington, D.C. 20005-3502

Resident Inspector/Summer NPS
c/o U.S. Nuclear Regulatory Commission
Route 1, Box 64
Jenkinsville, South Carolina 29065

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., N.W., Ste. 2900
Atlanta, Georgia 30323

Chairman, Fairfield County Council
Drawer 60
Winnsboro, South Carolina 29180

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. R. M. Fowlkes, Manager
Nuclear Licensing & Operating Experience
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, South Carolina 29065

PLANT SYSTEMS

EMERGENCY FEEDWATER SYSTEM

LIMITING CONDITION FOR OPERATION

3 7.1.2 At least three independent steam generator emergency feedwater pumps and flow paths shall be OPERABLE with:

- a. Two motor-driven emergency feedwater pumps, each capable of being powered from separate emergency busses, and
- b. One steam turbine driven emergency feedwater pump capable of being powered from an OPERABLE steam supply system.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

- a. With one emergency feedwater pump inoperable, restore the required emergency feedwater pumps to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- b. With two emergency feedwater pumps inoperable, be in at least HOT STANDBY within 6 hours and in HOT SHUTDOWN within the following 6 hours.
- c. With three emergency feedwater pumps inoperable, immediately initiate corrective action to restore at least one emergency feedwater pump to OPERABLE status as soon as possible.

SURVEILLANCE REQUIREMENTS

4.7.1.2 Each emergency feedwater pump shall be demonstrated OPERABLE:

- a. At least once per 31 days by:
 1. Verifying that each motor driven pump develops a discharge pressure of greater than or equal to 1600 psig at greater than or equal to 90 gpm flow.
 2. Verifying that the steam turbine driven pump develops a discharge pressure of greater than or equal to 1330 psig at a flow of greater than or equal to 97 gpm when the secondary steam supply pressure is greater than 865 psi. The provisions of Specification 4.0.4 are not applicable.
 3. Verifying that each non-automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.

9309090429 930901
PDR ADDCK 05000395
P PDR

DISTRIBUTION:

Docket File

NRC/Local PDRs

PD II-1 Reading File

S. Varga

S. Bajwa

G. Wunder

B. Mozafari

P. Anderson

OGC

R. Jones

8-E-23

D. Hagan

MNBB 3206

G. Hill (2)

P1 37

C. Grimes

11-E-22

ACRS (10)

OPA

OC/LFDCM

E. Merschoff, R-II