

50-395



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001
April 12, 1995

Mr. Gary J. Taylor
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, South Carolina 29065

SUBJECT: CORRECTION TO AMENDMENT NO. 123 TO FACILITY OPERATING LICENSE NO.
NPF-12 REGARDING DELETION OF LICENSE CONDITIONS - VIRGIL C. SUMMER
NUCLEAR STATION, UNIT NO. 1 (TAC NO. M88172)

Dear Mr. Taylor:

This letter forwards a corrected page 7 to Operating License No. NPF-12 for the Virgil C. Summer Nuclear Station, Unit No. 1. The corrected page replaces the one forwarded to you in Amendment No. 123 (issued on March 29, 1995). The amendment deleted License Conditions 2.C(13), 2.C(14), and 2.C(32).

In an April 5, 1995, telephone conversation, your staff informed me of two typographical errors in one of the operating license pages forwarded to you. The typographical errors occurred when the operating license pages were retyped by our staff (the errors were in license conditions that are unrelated to the granted amendment). Specifically, the word "cable" was inadvertently deleted from the last sentence in License Condition 2.C(16), and the word "shutdown" was inadvertently deleted from the last sentence in License Condition 2.C(17). The corrected page 7 is enclosed.

Additionally, your staff said that the page numbering and format of the license pages forwarded to you do not coincide with those of the operating license pages that you have on file. These differences most likely occurred over time as license conditions were added or deleted because in the past we did not provide you with retyped pages when license conditions were amended.

To clarify, the pages to your operating license were sent to you only for your convenience. If you prefer, you may delete the above listed license conditions from your operating license (as you have it formatted). As long as the content is the same, the format of the operating license may be different.

9504190288 950412
PDR ADDCK 05000395
P PDR

INFO FILE CENTER COPY

DF01

Mr. G. Taylor

- 2 -

I appreciate your staff promptly bringing these errors to my attention. If you would like to discuss this issue further, please call me at (301) 415-1455.

Sincerely,

Original signed by

Stephen Dembek, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-395

Enclosure: Corrected Page 7 to Operating
License No. NPF-12

cc w/enclosure: See next page

DISTRIBUTION

Docket File
PUBLIC
Summer Rdg.
S. Varga
J. Zwolinski
OGC
G. Hill (2)
C. Grimes
C. Liang
J. Hayes
R. Goel
M. Hartzman
G. Hornseth
R. Jones
J. Strosnider
ACRS (4)
OPA
OC/LFDCB
E. Merschhoff, RII

DOCUMENT NAME: A:\SUM88172.AMD

OFFICE	LA:PDII-3	PM:PDII-3	D:PDII-3		
NAME	BC Dayton	SDembek	FHebdon		
DATE	04/11/95	04/12/95	04/12/95		
COPY	(Yes/No)	(Yes/No)	(Yes/No)		

OFFICIAL RECORD COPY

Mr. Gary J. Taylor
South Carolina Electric & Gas Company

VIRGIL C. SUMMER NUCLEAR STATION

cc:

Mr. R. J. White
Nuclear Coordinator
S.C. Public Service Authority
c/o Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 802
Jenkinsville, South Carolina 29065

J. B. Knotts, Jr., Esquire
Winston & Strawn Law Firm
1400 L Street, N.W.
Washington, D.C. 20005-3502

Resident Inspector/Summer NPS
c/o U.S. Nuclear Regulatory Commission
Route 1, Box 64
Jenkinsville, South Carolina 29065

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., N.W., Ste. 2900
Atlanta, Georgia 30323

Chairman, Fairfield County Council
Drawer 60
Winnsboro, South Carolina 29180

Mr. Max Batavia, Chief
South Carolina Department of Health
Bureau of Radiological Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. R. M. Fowlkes, Manager
Nuclear Licensing & Operating Experience
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, South Carolina 29065

- c. The reporting of the inservice inspection examination results shall be documented in a manner to define qualitatively whether, the weldment and the heat affected zone and adjacent base metal on both sides of the weld were examined by ultrasonic angle beam techniques.

(12) Design Description - Control (Section 4.3.2, SER)

SCE&G is prohibited from using part-length rods during power operation.

(13) Deleted

(14) Deleted

(15) Deleted

(16) Cable Tray Separation (Section 8.3.3, SSER 4)

Prior to startup after the first refueling outage, SCE&G shall implement the modifications to the cable trays discussed in Section 8.3.3 of Supplement No. 4 to the Safety Evaluation Report or demonstrate to the NRC staff that faults induced in non-Class 1E cable trays will not result in failure of cable in the adjacent Class 1E cable trays.

(17) Alternate Shutdown System (Section 9.5.1, SSER 4)

Prior to startup after the first refueling outage, SCE&G shall install a source range neutron flux monitor independent of the control complex as part of the alternate shutdown system.