

E. Fire Protection

STPNOC shall implement and maintain in effect all provisions of the approved fire protection program as described in the Final Safety Analysis Report through Amendment No. 55 and the Fire Hazards Analysis Report through Amendment No. 7, and submittals dated April 29, May 7, 8 and 29, June 11, 25 and 26, 1987, and as approved in the SER (NUREG-0781) dated April 1986 and its Supplements, subject to the following provision:

STPNOC may make changes to the approved fire protection program without prior approval of the Commission, only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

F. Physical Security

STPNOC shall fully implement and maintain in effect all provisions of the physical security, guard training and qualification, and safeguards contingency plans previously approved by the Commission and all amendments and revisions to such plans made pursuant to the authority under 10 CFR 50.90 and 10 CFR 50.54(p).

The plans, which contain Safeguards Information protected under 10 CFR 73.21, are entitled: "South Texas Project Electric Generating Station Physical Security Plan," with revisions/amendments submitted through March 4, 1988; "South Texas Project Electric Generating Station Security Personnel Qualification and Training Plan" with revisions submitted through March 4, 1988, and "South Texas Project Electric Generating Station Safeguards Contingency Plan," with revisions/amendments submitted through July 24, 1987.

G. Not Used

H. Financial Protection

The owners shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.

contingency plans previously approved by the Commission and all amendments and revisions to such plans made pursuant to the authority under 10 CFR 50.90 and 10 CFR 50.54(p). The plans, which contain Safeguards Information protected under 10 CFR 73.21, are entitled: "South Texas Project Electric Generating Station Physical Security Plan," with revisions/amendments submitted through September 30, 1988; "South Texas Project Electric Generating Station Security Personnel Qualification and Training Plan" with revisions submitted through March 4, 1988, and "South Texas Project Electric Generating Station Safeguards Contingency Plan," with revisions/amendments submitted through July 19, 1988.

G. Not Used

H. Financial Protection

The Owners shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.

I. Effective date and Expiration

This license is effective as of the date of issuance and shall expire at midnight on December 15, 2028.

FOR THE NUCLEAR REGULATORY COMMISSION

Original Signed By: James H. Sniezek/for

Thomas E. Murley, Director

Office of Nuclear Reactor Regulation

Enclosures:

1. Appendix A, Technical Specifications (NUREG-1346)
2. Appendix B, Environmental Protection Plan
3. Appendix C, Antitrust Conditions

Date of Issuance: March 28, 1989

ADMINISTRATIVE CONTROLS

ACTIVITIES (Continued)

at least one of whom holds a Senior Reactor Operator's License. Changes to procedures that may involve a change to the intent of the original procedure shall be approved by the individual authorized to approve the procedure prior to implementation of the change.

- b. Proposed changes or modifications to safety-related structures, systems, and components shall be reviewed as designated by the Plant Manager. Each such modification shall be reviewed by an individual/group other than the individual/group who designed the modification, but who may be from the same organization as the individual/group who designed the modification. Proposed modifications to safety-related structures, systems, and components shall be approved by the Plant Manager prior to implementation.
- c. Proposed tests and experiments that affect nuclear safety and that are not addressed in the Final Safety Analysis Report shall be prepared, reviewed, and approved prior to implementation. Each such test or experiment shall be reviewed by an individual/group other than the individual/group who prepared the test or experiment but who may be from the same organization as the individual/group who prepared the test or experiment. Proposed tests and experiments shall be approved by the Plant Manager.
- d. Individuals responsible for reviews performed in accordance with Specification 6.5.3.1 (a) through (c) shall be members of the plant management staff previously designated by the Plant Manager. Each review shall include a determination of whether or not additional, cross-disciplinary review is necessary. If deemed necessary, such review shall be performed by qualified personnel of the appropriate discipline.
- e. Each review will include a determination of whether or not an unreviewed safety question is involved. Pursuant to 10 CFR 50.59, NRC approval of items involving an unreviewed safety question will be obtained prior to Plant Manager approval for implementation.

6.5.3.2 Records of the above activities shall be provided to the Plant Manager, PORC, and/or NSRB as necessary for required reviews.

6.6 REPORTABLE EVENT ACTION

6.6.1 The following actions shall be taken for REPORTABLE EVENTS:

- a. Not Used.
- b. Each REPORTABLE EVENT shall be reviewed by the PORC, and the results of this review shall be submitted to the NRSB and the President and Chief Executive Officer.

6.7 SAFETY LIMIT VIOLATION

6.7.1 The following actions shall be taken in the event a Safety Limit is violated: