FENOC
FirstEnergy Nuclear Operating Company

Perry Nuclear Power Plant
10 Center Road
P.O. Box 97
Perry, Ohio 44081

Auguest 14, 2001
PY-CEI/NRR-2587L

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
License No. NPF-58
Monthly Operating Report

Ladies and Gentlemen:

Attached is the July 2001 Monthly Operating Report for Perry Unit 1. Page 1 is the Operating Data Report and page 2 is the Unit Shutdowns Report. This report is submitted in accordance with Technical Specification 5.6.4 and Generic Letter 97-02, "Revised Contents of the Monthly Operating Report."

If you have questions or require additional information, please contact Ms. Toni Phelps at (440) 280-7660.

Very truly yours,

Gregory A. Dunn
Manager - Regulatory Affairs

Attachment

cc: NRC Region III Administrator
NRC Project Manager
NRC Resident Inspector

IE24

OPERATING DATA REPORT

UNIT: Perry
DATE: 8/7/01

1. Docket: 50-440
2. Unit Name: Perry Nuclear Power Plant
3. Reporting Period: July 2001
4. Utility Contact: T. Phelps
5. Telephone: 440-280-7660
6. Design Electrical Rating (Net MWe): 1266*
7. Maximum Dependable Capacity (Net MWe): 1241**

		This Month	Yr-to-Date	Cumulative
8.	Hours Reactor was Critical	334.9	3,356.4	92,965.0
9.	Hours Generator On-Line	285.7	3,154.8	90,517.0
10.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
11.	Net Electrical Energy (MWeH)	324,672.0	3,418,757.0	102,239,714.0

- *The New Design Electrical Rating is based on the 105% uprate which was completed April of 2001.
- ** The new MDC was effective April 1, 2001.

UNIT SHUTDOWNS
REPORT MONTH – JULY 2001

DOCKET NO: 50-440
NAME: Perry Nuclear Power Plant
DATE: 8/7/01
CONTACT: T. Phelps
TELEPHONE: (440) 280-7660

No.	Date	Type 1	Duration Hours	Reason 2	Method 3	Cause and Corrective Action to Prevent Recurrence
01-7	7/11/01	F	458.35	A	3	The plant had an automatic scram on 7/11/01 at 2227. The scram was as a result of a power loss due to a blown fuse.

SUMMARY: The Perry plant began the month on line. On 7/11/01 2227 the plant incurred an automatic shutdown due to a blown fuse. The unit remained off line until 7/31/01 at 0048, when the Unit was sychronized to the grid.

1. TYPE:
   F: Forced
   S: Scheduled

2. REASON:
   A - Equipment Failure (explain)
   B - Maintenance or Test
   C - Refueling
   D - Regulatory
   E - Operating Training & License Examination
   F - Administrative
   G - Operational Error (explain)
   H - Other (explain)

3. METHOD:
   1 - Manual
   2 - Manual Scram
   3 - Automatic Scram
   4 - Continuation
   5 - Other