Docket Nos. 50-424 and 50-425 Mr. C. K. McCoy Vice President - Nuclear Vogtle Project Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201	Distribution PDII-3 R/F NRC/Local PDRs S.Varga R.Hermann C.E.Carpenter L.Berry OGC 15B18	D.Hagan MNBB4702 G.Hill(4) P1-37 C.Grimes 11F23 ACRS(10) P-135 PA 2G5 OC/LFMB MNBB4702 E.Merschoff, RII
---	---	---

Dear Mr. McCoy:

CORRECTION TO AMENDMENT NOS. 69 AND 48 - VOGTLE ELECTRIC SUBJECT: GENERATING PLANT, UNITS 1 AND 2 (TAC NOS. M84159 AND M84160)

The Nuclear Regulatory Commission issued Amendment No. 68 to Facility Operating License NPF-68 and Amendment No. 48 to Facility Operating License NPF-81 for the Vogtle Electric Generating Plant, Units 1 and 2, on October 6, 1993. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated July 31, 1992, as supplemented January 22 and July 27, 1993.

Due to an administrative error, pages 3/4 7-9a and B 3/4 7-2a were incorrectly titled. Additionally, there was a typographical error in the second sentence of Bases Section 3/4.7.1.6.

Please replace TS page 3/4 7-9a and Bases page B 3/4 7-2a with the enclosed revised pages.

We regret any inconvenience this may have caused.

Sincerely,

/s/

C. E. Carpenter, Jr., Acting Project Manager Project Directorate II-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosures: Revised TS page 3/4 7-9a and Bases page B 3/4 7-2a

cc w/enclosures: See next page

OFC	LA:PD23:DRPE	PM:PD23:DRPE	AD: PD23: DRPE	AD
NAME	LGBerry	CECarpenter:cw CEC	RHermann	0-1
DATE	11/3/93	11/3/93	11/ 4/93	
AFFICIA	U DECORD CODY	ETLE NAME:	G:\V0GTLE\V0G84159.C0	R

OFFICIAL RECORD COPY

FILE NAME: a: \Vuaite

NRC FILE CENTER COPY



## UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001 November 4, 1993

Docket Nos. 50-424 and 50-425

> Mr. C. K. McCoy Vice President - Nuclear Vogtle Project Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Dear Mr. McCoy:

# SUBJECT: CORRECTION TO AMENDMENT NOS. 69 AND 48 - VOGTLE ELECTRIC GENERATING PLANT, UNITS 1 AND 2 (TAC NOS. M84159 AND M84160)

The Nuclear Regulatory Commission issued Amendment No. 68 to Facility Operating License NPF-68 and Amendment No. 48 to Facility Operating License NPF-81 for the Vogtle Electric Generating Plant, Units 1 and 2, on October 6, 1993. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated July 31, 1992, as supplemented January 22 and July 27, 1993.

Due to an administrative error, pages 3/4 7-9a and B 3/4 7-2a were incorrectly titled. Additionally, there was a typographical error in the second sentence of Bases Section 3/4.7.1.6.

Please replace TS page 3/4 7-9a and Bases page B 3/4 7-2a with the enclosed revised pages.

We regret any inconvenience this may have caused.

Sincerely,

4

C. E. Carpenter, Jr., Acting Project Manager Project Directorate II-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosures: Revised TS page 3/4 7-9a and Bases page B 3/4 7-2a

cc w/enclosures: See next page Mr. C. K. McCoy Georgia Power Company

cc: Mr. J. A. Bailey Manager - Licensing Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Mr. J. B. Beasley
General Manager, Vogtle Electric
Generating Plant
P. O. Box 1600
Waynesboro, Georgia 30830

Regional Administrator, Region II U. S. Nuclear Regulatory Commission 101 Marietta Street, NW., Suite 2900 Atlanta, Georgia 30323

Office of Planning and Budget Room 615B 270 Washington Street, SW. Atlanta, Georgia 30334

Office of the County Commissioner Burke County Commission Waynesboro, Georgia 30830

Mr. J. D. Woodard Senior Vice President – Nuclear Operations Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201 Vogtle Electric Generating Plant

Harold Reheis, Director Department of Natural Resources 205 Butler Street, SE. Suite 1252 Atlanta, Georgia 30334

Attorney General Law Department 132 Judicial Building Atlanta, Georgia 30334

Mr. Alan R. Herdt Project Branch #3 U. S. Nuclear Regulatory Commission 101 Marietta Street, NW. Suite 2900 Atlanta, Georgia 30323

Mr. Dan H. Smith, Vice President Power Supply Operations Oglethorpe Power Corporation 2100 East Exchange Place Tucker, Georgia 30085-1349

Charles A. Patrizia, Esquire Paul, Hastings, Janofsky & Walker 12th Floor 1050 Connecticut Avenue, NW. Washington, DC 20036

Arthur H. Domby, Esquire Troutman Sanders NationsBank Plaza 600 Peachtree Street, NE. Suite 5200 Atlanta, Georgia 30308-2216

~ ~

Resident Inspector U. S. Nuclear Regulatory Commission P. O. Box 572 Waynesboro, Georgia 30830

## PLANT SYSTEMS

## MAIN FEEDWATER ISOLATION SYSTEMS

#### LIMITING CONDITION FOR OPERATION

3.7.1.6 Four main feedwater isolation valves (MFIVs), four main feedwater regulating valves (MFRVs), and associated bypass valves shall be OPERABLE.

<u>APPLICABILITY</u>:\* MODES 1 AND 2, except when the MFIV, MFRV or associated bypass valve is closed and deactivated.

#### ACTION:

- a. With one MFIV, MFRV, or associated bypass valve inoperable in one or more feedwater lines, operation may continue provided each inoperable valve is restored to OPERABLE status or closed in each feedwater line within 72 hours. Otherwise be in HOT STANDBY within the next 6 hours.
- b. With no isolation system (each system consisting of a MFIV and its associated bypass valve or a MFRV and its associated bypass valve) OPERABLE\*\* in any one feedwater line, restore at least one isolation system in each feedwater line to OPERABLE status within 4 hours or be in HOT STANDBY within the next 6 hours.

#### SURVEILLANCE REQUIREMENTS

4.7.1.6(a) Each MFIV, BFIV, MFRV and BFRV shall be demonstrated OPERABLE by verifying full closure within 5 seconds when tested pursuant to Specification 4.0.5. The provisions of 4.0.4 are not applicable for entry into MODE 2.

4.7.1.6(b) For each inoperable valve, verify that it is closed or isolated once per 7 days.

\*Each MFIV, MFRV, or associated bypass valve shall be treated independently.

\*\*An OPERABLE main feedwater isolation system may consist of inoperable valves provided the inoperable valves are maintained closed and deactivated.

VOGTLE UNITS - 1 & 2

ADOCK 05000424

PDR

9311120112 931104

**P**DR

3/4 7-9a

Amendment No. 69 (Unit 1) Amendment No. 48 (Unit 2)

#### PLANT SYSTEMS

#### BASES

#### 3/4.7.1.6 MAIN FEEDWATER ISOLATION SYSTEMS

Isolation of the main feedwater (MFW) system is provided when required to mitigate the consequences of a steam line break, feedwater line break, feedwater controller malfunction, steam generator tube rupture or small break loss of coolant accident. Redundant isolation capability is provided by two isolation systems on each feedwater line consisting of the main feedwater isolation valve (MFIV) and its associated bypass valve (BFIV) and the main feedwater regulating valve (MFRV) and its associated bypass valve (BFRV). The safety function of these valves is fulfilled when closed. Therefore, a feedwater isolation system may be considered OPERABLE if its respective valves are OPERABLE or if they are maintained in a closed and deactivated position. The 72 hour completion time to either restore or close an inoperable valve takes into account the redundancy afforded by the remaining OPERABLE valves and the low probability of an event occurring that would require isolation of the MFW flow paths during this time period. The 7 day completion time to verify that an inoperable valve is closed or isolated is reasonable based on valve status indications available in the control room, and other administrative controls to ensure the valves are closed or isolated.

Amendment No. 69 (Unit 1) Amendment No. 48 (Unit 2)

1