

NRC REGION II BRIEFING

Crystal River Unit 3 Update


August 13, 2001



AGENDA

- **Introduction Dale Young**
- **Integration Activities Dale Young**
- **Plant Update Danny Roderick**
- **Refuel 12 Outage Overview ... Danny Roderick**
- **Refuel 12 Major Activities Jim Terry**
- **Corrective Action Program ... Richard Warden**
- **Future Initiatives Dale Young**
- **Closing Remarks Dale Young**

KEY DEPARTMENT MANAGERS



Florida Power
A Progress Energy Company


INTEGRATION ACTIVITIES

- **Close – December 2000**
- **Controlled Change**
- **Peer Groups**
- **Nuclear Assessment Section (NAS)**
- **Materials**
- **Nuclear Information Technology (NIT)**
- **Re-organization - January 2001**
- **Corrective Action Program (CAP)**
- **PassPort – February 2002**

CRYSTAL RIVER – UNIT 3

POWER HISTORY

June 1, 2000 - August 1, 2001



INPO PERFORMANCE INDICATOR INDEX

- **All Progress Energy Nuclear Plants Are in the Industry Top Quartile Through the First Quarter of 2001**
- **Crystal River 3 is 10th in the Industry**
- **Crystal River 3 Has Been in the Top Quartile for the Past 5 Quarters**
- **Crystal River 3 is the Highest Ranked B&W Plant**

OPERATING RESULTS


	To Date	
	<u>2000</u>	<u>2001</u>
Capacity Factor [%]	98.3	94.3
Forced Outage Rate [%]	0.0	0.0
Radiation Dose [Rem]	14.7	4.4 On-line
DHV-3 Outage [Rem]		11.4 Outage
Personnel Contaminations	27	3
Maintenance Backlog	333	318

REACTOR COOLANT SYSTEM LEAKAGE

- **Decay Heat Suction Valve DHV-3 Repairs Complete**
- **ITS Identified Leakage Limit is 10 gpm**
- **Total RCS Leakage Was Estimated at 6 gpm While Shutdown**
- **Reactor Oversight Process Performance Indicator for 2rd Quarter 2001 RCS Identified Leakage is White**

Crystal River - Unit 3

2Q/01 Plant Performance Summary



Performance Indicators

Based on data through June 30, 2001

Unplanned Scrams	Emergency AC Power System Unavailability	Reactor Coolant System Specific Activity	Drill / Exercise Performance	Occupational Exposure Control Effectiveness	RETS/ODCM Radiological Effluents	Protected Area Equipment
Scrams With Loss of Normal Heat Removal	High Pressure Injection System Unavailability	Reactor Coolant System Leakage	ERO Drill Participation			Personnel Screening Program
Unplanned Power Changes	Emergency Feedwater System Unavailability		Alert and Notification System			FFD / Personnel Reliability Program
	Residual Heat Removal System Unavailability					
	Safety System Functional Failure					


Most Significant Inspection Findings

Quarter	Indicator 1	Indicator 2	Indicator 3	Indicator 4	Indicator 5	Indicator 6	Indicator 7
2Q/2001	No Findings this Quarter	No Findings this Quarter	No Findings this Quarter	No Findings this Quarter	No Findings this Quarter	No Findings this Quarter	No Findings this Quarter
1Q/2001	No Findings this Quarter	NCV00-05-02	No Findings this Quarter	No Findings this Quarter	No Findings this Quarter	No Findings this Quarter	NCV00-05-01
4Q/2000	No Findings this Quarter	NCV00-04-01	Findings without color designation	No Findings this Quarter	No Findings this Quarter	No Findings this Quarter	No Findings this Quarter
3Q/2000	No Findings this Quarter	NCV00-03-01	No Findings this Quarter	No Findings this Quarter	NCV00-02-01	No Findings this Quarter	No Findings this Quarter

LICENSED OPERATOR TRAINING

- **Operator Pipeline**
- **Current License Class**
 - ◆ **February 2002 Examination**
- **Succession Planning From Operations**

REFUEL 12 OUTAGE OVERVIEW



REFUEL 12 OUTAGE STRETCH GOALS

Human Performance Events	\leq 1 Event
OSHA Recordable Injuries	\leq 1 Injury
Radiation Exposure	\leq 110 Rem
Duration	\leq 27 Days
Budget	\leq \$17.4 Million

REFUEL 12

MAJOR ACTIVITIES

- **Steam Generator Inspections**
- **Control Rod Drive Motor (CRDM) Nozzle Inspection**
- **Emergency Diesel Generator (EDG) Maintenance**

STEAM GENERATOR INSPECTIONS

- **Bobbin Full Length Examination (100%)**
- **Upper Tube Sheet Motorized Rotating Pancake Coil (MRPC) Inspection (100%)**
- **Lower Tube Sheet MRPC Inspection
Sludge Pile Region (20%)**

CRDM NOZZLE INSPECTIONS

- **100% Bare Head External Inspection**
- **Incorporating Lessons Learned from Oconee**
- **Contingency Plans Fully Developed**
 - ◆ **Non-Destructive Examination (NDE) Plans**
 - ◆ **Repair Plans**


SAFETY SYSTEM DESIGN INSPECTION

- **Comprehensive Inspection of Station Black-Out (SBO) Coping Ability**
- **Included In-Depth Reviews of Risk Significant Systems**
- **Included In-Depth Program Reviews**
- **Exit Conclusion: No Findings**
 - ◆ **Good Technical Capabilities of Personnel**
 - ◆ **Confidence in Ability to Mitigate SBO Event**

CORRECTIVE ACTION PROGRAM

- **Key Performance Indicators**
- **Nuclear Generation Group (NGG) Transition**
- **CAP Improvement Initiatives**

CORRECTIVE ACTION PROGRAM



CORRECTIVE ACTION PROGRAM

Key Performance Indicators

	<u>Actual</u>	<u>Target</u>
● Significant Adverse Corrective Action Average Age	88 days	90 days
● Adverse Corrective Action Average Age	79 days	90 days
● Operating Experience Evaluation	31 days	90 days



Florida Power
A Progress Energy Company

CORRECTIVE ACTION PROGRAM

NGG Transition

- **Implemented NGG CAP Procedures
June 4, 2001**
- **Implemented Action Tracking (PassPort)
June 4, 2001**
- **“Trend Watch” Ongoing**

CORRECTIVE ACTION PROGRAM

CAP Improvement Initiatives

- **Action Tracking Training – Site Personnel**
- **Root Cause Investigation Training**
- **Unit Evaluator Trend Training**

FUTURE INITIATIVES

- **Power Uprate**
- **Operating License Renewal**
- **Steam Generator Replacement**
- **Reactor Vessel Head Replacement**

CLOSING REMARKS

August 13, 2001

