

Mr. C. K. McCoy
Vice President - Nuclear
Vogtle Project
Georgia Power Company
P. O. Box 1295
Birmingham, AL 35201

December 13, 1994

SUBJECT: CORRECTION TO AMENDMENT NOS. 69 AND 48 - VOGTLE ELECTRIC
GENERATING PLANT, UNITS 1 AND 2 (TAC NOS. M84159 AND M84160)

Dear Mr. McCoy:

The Nuclear Regulatory Commission issued Amendment No. 68 to Facility Operating License NPF-68 and Amendment No. 48 to Facility Operating License NPF-81 for the Vogtle Electric Generating Plant, Units 1 and 2, on October 6, 1993. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated July 31, 1992, as supplemented January 22 and July 27, 1993.

There was a typographical error in Action Statement 7 on TS page 3/4 3-7. Please replace TS page 3/4 3-7 with the enclosed revised page.

We regret any inconvenience this may have caused.

Sincerely,

/s/
Louis L. Wheeler, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425

Enclosure: Revised TS page 3/4 3-7

cc w/encl: See next page

DISTRIBUTION

Docket File
PUBLIC
PD23 Reading File
S. Varga
J. Zwolinski
OGC
G. Hill, (4)
C. Grimes
ACRS (4)
OPA
OC/LFDCB
B. Boger
M. Sinkule

DOCUMENT NAME: G:\VOGTLE\VOG84159.CR2

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD23:DRPE	E	PM:PD23:DRPE	E	D:PD23:DRPE	To			
NAME	CNorsworthy <i>cn</i>		LWheeler:dt		HBerkow <i>HB</i>				
DATE	12/12/94		12/12/94		12/13/94				

OFFICIAL RECORD COPY

1600007
9412210105 941213
PDR ADOCK 05000424
P PDR

NRC FILE CENTER COPY

DF01



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 13, 1994

Mr. C. K. McCoy
Vice President - Nuclear
Vogtle Project
Georgia Power Company
P. O. Box 1295
Birmingham, AL 35201

SUBJECT: CORRECTION TO AMENDMENT NOS. 69 AND 48 - VOGTLE ELECTRIC
GENERATING PLANT, UNITS 1 AND 2 (TAC NOS. M84159 AND M84160)

Dear Mr. McCoy:

The Nuclear Regulatory Commission issued Amendment No. 68 to Facility Operating License NPF-68 and Amendment No. 48 to Facility Operating License NPF-81 for the Vogtle Electric Generating Plant, Units 1 and 2, on October 6, 1993. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated July 31, 1992, as supplemented January 22 and July 27, 1993.

There was a typographical error in Action Statement 7 on TS page 3/4 3-7. Please replace TS page 3/4 3-7 with the enclosed revised page.

We regret any inconvenience this may have caused.

Sincerely,

A handwritten signature in cursive script, appearing to read "Louis L. Wheeler".

Louis L. Wheeler, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425

Enclosure: Revised TS page 3/4 3-7

cc w/encl: See next page

Mr. C. K. McCoy
Georgia Power Company

Vogtle Electric Generating Plant

cc:

Mr. J. A. Bailey
Manager - Licensing
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Harold Reheis, Director
Department of Natural Resources
205 Butler Street, SE. Suite 1252
Atlanta, Georgia 30334

Mr. J. B. Beasley
General Manager, Vogtle Electric
Generating Plant
P. O. Box 1600
Waynesboro, Georgia 30830

Attorney General
Law Department
132 Judicial Building
Atlanta, Georgia 30334

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW., Suite 2900
Atlanta, Georgia 30323

Mr. Ernie Toupin
Manager of Nuclear Operations
Oglethorpe Power Corporation
2100 East Exchange Place
Tucker, Georgia 30085-1349

Office of Planning and Budget
Room 615B
270 Washington Street, SW.
Atlanta, Georgia 30334

Charles A. Patrizia, Esquire
Paul, Hastings, Janofsky & Walker
12th Floor
1050 Connecticut Avenue, NW.
Washington, DC 20036

Office of the County Commissioner
Burke County Commission
Waynesboro, Georgia 30830

Arthur H. Domby, Esquire
Troutman Sanders
NationsBank Plaza
600 Peachtree Street, NE.
Suite 5200
Atlanta, Georgia 30308-2216

Mr. J. D. Woodard
Senior Vice President -
Nuclear Operations
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 572
Waynesboro, Georgia 30830

TABLE 3.3-1 (Continued)

ACTION STATEMENTS (Continued)

- ACTION 3** - With the number of channels OPERABLE one less than the Minimum Channels OPERABLE requirement and with the THERMAL POWER level:
- a. Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-6 Setpoint, and
 - b. Above the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint but below 10% of RATED THERMAL POWER, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above 10% of RATED THERMAL POWER.
- ACTION 4** - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, suspend all operations involving positive reactivity changes.
- ACTION 5** - a. With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or open the Reactor Trip System breakers, suspend all operations involving positive reactivity changes and verify valves 1208-U4-175, 1208-U4-177, 1208-U4-183, and 1208-U4-176 are closed and secured in position within the hour.
- b. With no channels OPERABLE, open the Reactor Trip Breakers, suspend all operations involving positive reactivity changes, and verify compliance with the SHUTDOWN MARGIN requirements of Specification 3.1.1.1 or 3.1.1.2, as applicable, within 1 hour and every 12 hours thereafter. Verify valves 1208-U4-175, 1208-U4-177, 1208-U4-183, and 1208-U4-176 are closed and secured in position within 4 hours and verified to be closed and secured in position every 14 days.
- ACTION 6** - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 6 hours, and
 - b. The Minimum Channels OPERABLE requirement is met; however, a channel may be bypassed for up to 4 hours for surveillance testing per Specification 4.3.1.1.
- ACTION 7** - With the number of OPERABLE Channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 6 hours or be in at least HOT STANDBY within the next 6 hours; however, one channel may be bypassed for up to 4 hours for surveillance testing per Specification 4.3.1.1, provided the other channel is operable.