

September 5, 2001

Mr. Jeffrey S. Forbes
Site Vice President
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

SUBJECT: MONTICELLO NUCLEAR GENERATING PLANT - CORRECTION TO
AMENDMENT NO. 122 (TAC NO. MB1866)

Dear Mr. Forbes:

On August 1, 2001, the Commission issued Amendment No. 122 to Facility Operating License No. DPR-22 for the Monticello Nuclear Generating Plant. The amendment (1) relocates requirements of the American Society of Mechanical Engineers (ASME) *Boiler and Pressure Vessel Code* (the Code), Section XI, Inservice Testing (IST) Program currently contained in Technical Specifications Surveillance Requirement (TSSR) 4.15.B to TS Administrative Control Section 6.8, "Programs and Manuals," (2) makes conforming changes to several SRs to reflect the change in reference from TSSR 4.15.B to the licensee-controlled IST Program, (3) rewords TSSRs 4.5.A.3 and 4.5.D.1 to be consistent with NUREG-1433, (4) incorporates TS Task Force (TSTF) initiative TSTF-279 into TS Administrative Control Section 6.8, and (5) revises TSSRs 4.6.H.1, 4.6.H.3, and Table 4.6.1 to change the inspection and functional testing interval extensions reference from plus-or-minus 25 percent to plus 25 percent.

The amendment consisted of changes to the TSs in response to your application dated May 2, 2001, as supplemented June 22 and July 27, 2001. While processing the completed amendment for issuance, a clerical error resulted in two copies of TS page 111 being issued, one of which contained an error in the third paragraph for the allowable reactor steam pressure to perform TSSR 4.5.A.3.a. The correct value should be "≥950 psig." This matter was discussed by me in a telephone conversation with Mr. D. Neve of your staff on August 21, 2001. A corrected copy of page 111 is enclosed.

If you have any questions concerning this matter, please call me at (301) 415-2296.

Sincerely,

/RA/

Carl F. Lyon, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure: Corrected TS page 111

cc w/encl: See next page

September 5, 2001

Mr. Jeffrey S. Forbes
Site Vice President
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

SUBJECT: MONTICELLO NUCLEAR GENERATING PLANT - CORRECTION TO
AMENDMENT NO. 122 (TAC NO. MB1866)

Dear Mr. Forbes:

On August 1, 2001, the Commission issued Amendment No. 122 to Facility Operating License No. DPR-22 for the Monticello Nuclear Generating Plant. The amendment (1) relocates requirements of the American Society of Mechanical Engineers (ASME) *Boiler and Pressure Vessel Code* (the Code), Section XI, Inservice Testing (IST) Program currently contained in Technical Specifications Surveillance Requirement (TSSR) 4.15.B to TS Administrative Control Section 6.8, "Programs and Manuals," (2) makes conforming changes to several SRs to reflect the change in reference from TSSR 4.15.B to the licensee-controlled IST Program, (3) rewords TSSRs 4.5.A.3 and 4.5.D.1 to be consistent with NUREG-1433, (4) incorporates TS Task Force (TSTF) initiative TSTF-279 into TS Administrative Control Section 6.8, and (5) revises TSSRs 4.6.H.1, 4.6.H.3, and Table 4.6.1 to change the inspection and functional testing interval extensions reference from plus-or-minus 25 percent to plus 25 percent.

The amendment consisted of changes to the TSs in response to your application dated May 2, 2001, as supplemented June 22 and July 27, 2001. While processing the completed amendment for issuance, a clerical error resulted in two copies of TS page 111 being issued, one of which contained an error in the third paragraph for the allowable reactor steam pressure to perform TSSR 4.5.A.3.a. The correct value should be "≥950 psig." This matter was discussed by me in a telephone conversation with Mr. D. Neve of your staff on August 21, 2001. A corrected copy of page 111 is enclosed.

If you have any questions concerning this matter, please call me at (301) 415-2296.

Sincerely,

/RA/

Carl F. Lyon, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure: Corrected TS page 111

cc w/encl: See next page

DISTRIBUTION

PUBLIC	OGC	FLyon	BBurgess, RGN-III
PDIII-1 Reading	ACRS	CCraig	DTerao
GHill(2)	WBeckner	RBouling	RDennig

Accession No. **ML012350062**

OFFICE	PDIII-1/PM	PDIII-1/LA	OGC	PDIII-1/SC
NAME	FLyon	THarris for RBouling	AHodgdon	CCraig
DATE	8/28/01	9/4/01	8/30/01	9/4/01

OFFICIAL RECORD COPY

Monticello Nuclear Generating Plant

cc:

J. E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington, DC 20037

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
2807 W. County Road 75
Monticello, MN 55362

Site Licensing Manager
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

Robert Nelson, President
Minnesota Environmental Control
Citizens Association (MECCA)
1051 South McKnight Road
St. Paul, MN 55119

Commissioner
Minnesota Pollution Control Agency
520 Lafayette Road
St. Paul, MN 55155-4194

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Commissioner
Minnesota Department of Health
717 Delaware Street, S. E.
Minneapolis, MN 55440

Douglas M. Gruber, Auditor/Treasurer
Wright County Government Center
10 NW Second Street
Buffalo, MN 55313

Commissioner
Minnesota Department of Commerce
121 Seventh Place East
Suite 200
St. Paul, MN 55101-2145

Adonis A. Neblett
Assistant Attorney General
Office of the Attorney General
445 Minnesota Street
Suite 900
St. Paul, MN 55101-2127

Mr. Roy A. Anderson
Executive Vice President and
Chief Nuclear Officer
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Nuclear Asset Manager
Xcel Energy, Inc.
414 Nicollet Mall
Minneapolis, MN 55401

Mr. James R. Morris
Site Vice President
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637