

MEMORANDUM FOR: Sholly Coordinator

FROM: Darl S. Hood, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE -  
NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO  
FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT  
HAZARDS OF CONSIDERATION DETERMINATION AND OPPORTUNITY  
FOR A HEARING (TAC NOS. M82133/M82134) REPEAT OF  
INDIVIDUAL NOTICE

Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric  
Authority of Georgia, City of Dalton, Georgia Docket Nos. 50-424 and 50-425,  
Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia

Date of amendment request: November 11, 1991, as supplemented January 23, 1992

Description of amendment request: The amendments would change surveillance  
requirements in Technical Specifications 3/4.7.6, 3/4.7.7, 3/4.9.12, and  
associated TS Bases, to revise the minimum heater capacity, and the relative  
humidity testing requirements for the control room emergency filtration system  
(CREFS), the piping penetration area filtration and exhaust systems (PPAFES),  
and the fuel handling building post accident filter system (FHBPAPS).

Date of publication of individual notice in Federal Register: February 11,  
1992 (57 FR 5026)

Expiration date of individual notice: March 12, 1992

Local Public Document Room location: Burke County Public Library, 412 Fourth  
Street, Waynesboro, Georgia 30830

/s/

Darl S. Hood, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

9202270051 920220  
PDR ADDOCK 05000424  
P PDR

Distribution  
Docket File  
NRC/Local PDRs  
PDII-3 R/F

Vogtle R/F  
D. Hood  
D. Matthews  
L. Berry

Sholly Coordinator  
OGC, 15B18

DOCUMENT NAME: SHOLLY M82133/M82134

DFol  
110

PDII-3:LA  
LBerry

<sup>DSH</sup>  
PDII-3:PM  
DHood/rst  
2/19/92

D:PDII-3  
D:Matthews  
2/20/92

URGENT CLASSIFIED COPY

2/19/92



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

February 20, 1992

MEMORANDUM FOR: Sholly Coordinator

FROM: Darl S. Hood, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE -  
NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO  
FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT  
HAZARDS OF CONSIDERATION DETERMINATION AND OPPORTUNITY  
FOR A HEARING (TAC NOS. M82133/M82134) REPEAT OF  
INDIVIDUAL NOTICE

Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric

Authority of Georgia, City of Dalton, Georgia Docket Nos. 50-424 and 50-425,

Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia

Date of amendment request: November 11, 1991, as supplemented January 23, 1992

Description of amendment request: The amendments would change surveillance requirements in Technical Specifications 3/4.7.6, 3/4.7.7, 3/4.9.12, and associated TS Bases, to revise the minimum heater capacity, and the relative humidity testing requirements for the control room emergency filtration system (CREFS), the piping penetration area filtration and exhaust systems (PPAFES), and the fuel handling building post accident filter system (FHBPAFS).

Date of publication of individual notice in Federal Register: February 11, 1992 (57 FR 5026)

Expiration date of individual notice: March 12, 1992

Local Public Document Room location: Burke County Public Library, 412 Fourth Street, Waynesboro, Georgia 30830

Darl S. Hood, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation