

November 15, 1988

Docket No. 50-424

Mr. W. G. Hairston, III  
Senior Vice President -  
Nuclear Operations  
Georgia Power Company  
P.O. Box 1295  
Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT: WITHDRAWAL OF APPLICATION FOR AMENDMENT (TAC 68242)

By letter dated August 30, 1988, Georgia Power Company withdrew an application for amendment to Vogtle Electric Generating Plant, Unit 1, Facility Operating License NPF-68. The application was dated May 19, 1988, and related to Technical Specification 3.2.2, "Heat Flux Hot Channel Factor-FQ(Z)."

The application for amendment was withdrawn since a reanalysis shows that a change to FQ(Z) is not needed to compensate for increased containment spray flow.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

*JS*  
Jon B. Hopkins, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
Federal Register Notice

cc: w/encl.  
See next page

DISTRIBUTION:

Docket File  
NRC PDR  
Local PDR  
PDII-3 Reading  
S. Varga 14-E-4  
G. Lainas 14-H-3  
D. Matthews 14-H-25  
M. Rood 14-H-25  
J. Hopkins 14-H-25  
OGC 15-B-18  
E. Jordan MNBB-3302  
B. Grimes 9-A-2  
ACRS (10) P-315  
VOGTLE PLANT FILE

PDII-3  
MRood  
11/7/88

PDII-3  
JHopkins:ls  
11/7/88

OGC  
myoung  
11/9/88

PDII-3  
for DMatthews  
11/15/88

*JFOI*  
*11*

*A/A 3*

8811210220 881115  
PDR ADOCK 05000424  
P FDC



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

November 15, 1988

Docket No. 50-424

Mr. W. G. Hairston, III  
Senior Vice President -  
Nuclear Operations  
Georgia Power Company  
P.O. Box 1295  
Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT: WITHDRAWAL OF APPLICATION FOR AMENDMENT (TAC 68242)

By letter dated August 30, 1988, Georgia Power Company withdrew an application for amendment to Vogtle Electric Generating Plant, Unit 1, Facility Operating License NPF-68. The application was dated May 19, 1988, and related to Technical Specification 3.2.2, "Heat Flux Hot Channel Factor-FQ(Z)."

The application for amendment was withdrawn since a reanalysis shows that a change to FQ(Z) is not needed to compensate for increased containment spray flow.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script that reads "Jon B. Hopkins".

Jon B. Hopkins, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
Federal Register Notice

cc: w/encl.  
See next page

Mr. W. G. Hairston, III  
Georgia Power Company

Vogtle Electric Generating Plant

cc:

Mr. J. P. Kane  
Manager, Licensing and Engineering  
Georgia Power Company  
P.O. Box 4545  
Atlanta, Georgia 30302

Resident Inspector  
Nuclear Regulatory Commission  
P.O. Box 572  
Waynesboro, Georgia 30830

Mr. Ruble A. Thomas  
Executive Consultant  
Southern Company Services, Inc.  
P.O. Box 1295  
Birmingham, Alabama 35201

Deppish Kirkland, III, Counsel  
Office of the Consumers' Utility  
Council  
Suite 225  
32 Peachtree Street, N.E.  
Atlanta, Georgia 30302

Mr. Paul D. Rice  
Vice President & Project Director  
Georgia Power Company  
Post Office Box 282  
Waynesboro, Georgia 30830

James E. Joiner  
Troutman, Sanders, Lockerman,  
& Ashmore  
1400 Candler Building  
127 Peachtree Street, N.E.  
Atlanta, Georgia 30303

Mr. J. A. Bailey  
Project Licensing Manager  
Southern Company Services, Inc.  
P.O. Box 1295  
Birmingham, Alabama 35201

Danny Feig  
1130 Alta Avenue  
Atlanta, Georgia 30307

Ernest L. Blake, Jr.  
Bruce W. Churchill, Esq.  
Shaw, Pittman, Potts and Trowbridge  
2300 N Street, N. W.  
Washington, D. C. 20037

Carol Stangler  
Georgians Against Nuclear Energy  
425 Euclid Terrace  
Atlanta, Georgia 30307

Mr. G. Bockhold, Jr.  
General Manager, Nuclear Operations  
Georgia Power Company  
P.O. Box 1600  
Waynesboro, Georgia 30830

Mr. R. P. McDonald  
Executive Vice President -  
Nuclear Operations  
Georgia Power Company  
P.O. Box 1295  
Birmingham, Alabama 35201

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30323

Mr. J. Leonard Ledbetter, Commissioner  
Department of Natural Resources  
270 Washington Street, NW  
Atlanta, Georgia 30334

Office of the County Commissioner  
Burke County Commission  
Waynesboro, Georgia 30830

Attorney General  
Law Department  
132 Judicial Building  
Atlanta, Georgia 30334

Office of Planning and Budget  
Room 615B  
270 Washington Street, S.W.  
Atlanta, Georgia 30334


UNITED STATES NUCLEAR REGULATORY COMMISSIONGEORGIA POWER COMPANYOGLETHORPE POWER CORPORATIONMUNICIPAL ELECTRIC AUTHORITY OF GEORGIACITY OF DALTON, GEORGIADOCKET NO. 50-424VOGTLE ELECTRIC GENERATING PLANT, UNIT 1NOTICE OF WITHDRAWAL OF APPLICATION FORAMENDMENT TO FACILITY OPERATING LICENSE

The United States Nuclear Regulatory Commission (the Commission) has granted the request of Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and City of Dalton, Georgia (the licensee) to withdraw its May 19, 1988, application of the Vogtle Electric Generating Plant, Unit 1, located in Burke County, Georgia. The proposed amendment would have revised Technical Specification (TS) 3.2.2, "Heat Flux Hot Channel Factor-FQ(Z)" from 2.30 to 2.25 at 100% power, and from 4.60 to 4.50 at 50% power or less. The bases to TS 3.2.1 would also have been revised to reflect the change. The Commission issued a Notice of Consideration of Issuance of the Amendment in the FEDERAL REGISTER on June 19, 1988 (53 FR 24511). By letter dated August 30, 1988, the licensee withdrew its application for the proposed amendment because a reanalysis showed that a change to FQ(Z) is not needed to compensate for increased containment spray flow.

For further details with respect to this action, see (1) the application for amendment dated May 19, 1988, (2) the licensee's letter dated August 30, 1988, withdrawing the application for amendment, and (3) our letters dated November 2, 1988, and Nov. 15, 1988 . All of the above documents are available for public inspection at the Commission's Public Document Room, 2120 L Street, N.W., Washington, D.C., and at the Burke County Public Library, 412 Fourth Street, Waynesboro, Georgia 30830.

Dated at Rockville, Maryland, this 15th day of November 1988.

FOR THE NUCLEAR REGULATORY COMMISSION



Jon B. Hopkins, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

For further details with respect to this action, see (1) the application for amendment dated May 19, 1988, (2) the licensee's letter dated August 30, 1988, withdrawing the application for amendment, and (3) our letters dated November 2, 1988, and Nov. 15, 1988 . All of the above documents are available for public inspection at the Commission's Public Document Room, 2120 L Street, N.W., Washington, D.C., and at the Burke County Public Library, 412 Fourth Street, Waynesboro, Georgia 30830.

Dated at Rockville, Maryland, this 15th day of November 1988.

FOR THE NUCLEAR REGULATORY COMMISSION

*151*

Jon B. Hopkins, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

*[Signature]*  
PDII-3  
MRood  
11/7/88

*[Signature]*  
PDII-3  
JHopkins:ls  
11/7/88

OGC *[Signature]*  
*[Signature]*  
11/9/88

*[Signature]*  
PDII-3  
DMatthews  
11/15/88

Doc. Name LTR HAIRSTON 11/3