



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
James A. Fitzpatrick NPP
P.O. Box 110
Lycoming, NY 13093
Tel 315 342 3840

August 15, 2001
JAFP-01-0192

U. S. Nuclear Regulatory Commission
Mail Station O-P1-17
Washington, D. C. 20555

ATTENTION: Document Control Desk

SUBJECT: OPERATING STATUS REPORT


Reference: Docket No. 50-333

Dear Sir:

Enclosed is the Operating Status Report for the James A. FitzPatrick Nuclear Power Plant for the month of July 2001.

If there are any questions concerning this report, please contact Sherard Anderson, Thermal Performance Engineer, (315) 349-6558.

Very truly yours,



T. A. SULLIVAN
V.P., OPERATIONS

TAS:MJC:GC:SA:tmb
Enclosure

cc: JAF Department Heads
White Plains Office
Barb Taggart IP3
Paul Lemberg WPO
Robert Penny WPO
JENG JAFP File
RMS (JAF)
RMS (WPO)

IE24

**ENTERGY NUCLEAR NORTHEAST
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

REPORT MONTH: JULY 2001

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	August 9, 2001
Completed By:	S. Anderson
Telephone:	(315)349-6558

DAY	NET AVERAGE DAILY POWER LEVEL	DAY	NET AVERAGE DAILY POWER LEVEL
1	817	17	825
2	819	18	825
3	824	19	826
4	824	20	827
5	707	21	829
6	829	22	826
7	829	23	825
8	830	24	824
9	829	25	820
10	828	26	822
11	828	27	835
12	830	28	835
13	829	29	836
14	829	30	833
15	830	31	832
16	829		

REPORT MONTH: JULY 2001

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	August 9, 2001
Completed By:	S. Anderson
Telephone:	(315)349-6558

NO.	DATE	TYPE	DURATION HOURS	REASON	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT NO.	SYSTEM CODE	COMPONENT CODE	CAUSE and CORRECTIVE ACTION TO PREVENT RECURRENCE

F: FORCED preparation of
S: SCHEDULED Report

- REASON:**
- A. Equipment failure (explain)
 - B. Maintenance or Test
 - C. Refueling
 - D. Regulatory Restriction
 - E. Operator training and license examination
 - F. Administrative
 - G. Operational error (explain)
 - H. Other (explain)

- METHOD:**
- 1. Manual
 - 2. Manual Scram
 - 3. Automatic Scram
 - 4. Continued
 - 5. Reduced load
 - 9. Other

EXHIBIT G: Instructions for data entry sheets for Licensee Event (LER) file (NUREG-0161)

REPORT MONTH: JULY 2001

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	August 9, 2001
Completed By:	S. Anderson
Telephone:	(315)349-6558

OPERATIONAL SUMMARY

The FitzPatrick plant - with the exception of minor derates for rod adjustments - operated at or near rated power during the month of July, 2001 except for the following:

- July 5, 2001 0802 Power was reduced to approximately 60% to support condenser waterbox de-fish evolutions. Work began at 0856 on waterbox isolations, and was completed at 1320. Power ascension then commenced, and the unit returned to full power at approximately 2000. The entire duration of the load drop was roughly 12 hours.