

Lawrence F. Womack Vice President Nuclear Services Diablo Canyon Power Plant P.O. Box 56 Avila Beach, CA 93424

805.545.4600 Fax: 805.545.4234

August 21, 2001

PG&E Letter DCL-01-086

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

Docket No. 50-323, OL-DPR-82 Diablo Canyon Unit 2 <u>Special Report 01-04 – 90-Day Report, Results of Steam Generator Alternate Repair</u> Criteria for Diablo Canyon Power Plant Unit 2 Tenth Refueling Outage

Dear Commissioners and Staff:

In accordance with Technical Specifications 5.6.10.e and 5.6.10.f, this Special Report transmits the 90-day steam generator tube alternate repair criteria report for the Unit 2 tenth refueling outage. Enclosure 1 provides the implementation results of Wstar (W*) repair criteria. Enclosure 2 provides the implementation results of voltage-based repair criteria.

Sincerely,

Lawrence F. Womack

cc: Ellis W. Merschoff David L. Proulx Girija S. Shukla State of California Diablo Distribution

Enclosures

DDM/469

Enclosure 1 PG&E Letter DCL-01-086

SPECIAL REPORT 01-04

90-DAY REPORT W* ALTERNATE REPAIR CRITERIA DIABLO CANYON POWER PLANT UNIT 2 TENTH REFUELING OUTAGE

NRC Reporting Requirements

Diablo Canyon Power Plant (DCPP) Technical Specification (TS) 5.6.10.e requires that the results of the inspection of Wstar (W*) tubes be reported to the Commission pursuant to 10 CFR 50.4 within 90 days following return to service of the steam generators (SGs). The report shall include:

- 1. Identification of W* tubes. Per TS 5.5.9.d.1.k, a W* tube is a tube left in service with degradation within or below the W* length.
- 2. W* inspection distance measured with respect to the bottom of the WEXTEX transition (BWT) or the top of tubesheet, whichever is lower.
- 3. Elevation and length of axial indications within the flexible W* distance and the angle of inclination of clearly skewed axial cracks (if applicable).
- 4. The total steam line break leakage for the limiting SG per WCAP-14797.

DCPP TS 5.6.10.f requires that the aggregate calculated steam line break leakage from application of all alternate repair criteria (ARC) be reported to the Commission pursuant to 10 CFR 50.4 within 90 days following return to service of the SGs.

W* Inspections and Results

This report implements the DCPP TS reporting criteria. W* ARC was implemented for the second time in DCPP Unit 2 during the tenth refueling outage (2R10). Following inspections and maintenance, the SGs were returned to service on May 22, 2001, upon entry into Mode 4.

One hundred percent of the SG tubes were inspected by bobbin from tube end to tube end, with the exception of rows 1 and 2 U-bends. One hundred percent of the hot leg top of tube sheet (TTS) region was inspected by Plus Point. Cold leg TTS inspections by Plus Point were not required.

Table 1 provides a comprehensive list of axial primary water stress corrosion cracking (PWSCC) indications detected in the WEXTEX region during 2R10 Plus Point inspections. The following TS-required reporting information is extracted from the table:

1. *Identification of W* tubes*. See "W* Tube" column in Table 1. Fifty-eight tubes (containing 68 indications) are categorized as W* tubes and left in service. Only

three new W* tubes were detected in 2R10, one of which was plugged because the axial PWSCC indication did not meet W* ARC because the upper crack tip was located above BWT, after accounting for nondestructive examination (NDE) uncertainty. One circumferential PWSCC indication (not listed) was also detected and plugged because circumferential indications in the W* region are excluded from W* ARC. All W* tubes that had been left in service in 2R9 were also left in service in 2R10.

- 2. W* inspection distance measured with respect to BWT or TTS, whichever is lower. For the 100 percent Plus Point hot leg TTS exam, the inspection extent relative to the TTS was specified as +2/-8 inches. Assuming no degradation in the W* length, 8 inches below the TTS constitutes the W* inspection distance. This distance bounds W* lengths for Zone A and Zone B (5.2 and 7.0 inches, respectively, relative to BWT), and includes margin for a nominal distance from BWT to TTS plus NDE uncertainty in measuring W* length. If degradation is detected in the W* region, the inspection extent must bound the calculated flexible W* length. The "W* Insp Dist" column in Table 1 lists the W* inspection distances measured with respect to BWT for tubes in which axial PWSCC was detected (in all cases, BWT was lower than the TTS).
- 3. *Elevation and length of axial indications within the flexible W* distance*. See "From," "To," and "L" columns in Table 1 for elevation and length of axial indications.
- 4. Angle of inclination of clearly skewed axial cracks (if applicable). None of the axial indications were skewed, so the angle of inclination was reported as 0 degrees for all axial indications.
- 5. The total steam line break leakage for the limiting steam generator per WCAP-14797. Steam Line Break (SLB) leakage attributed to each W* indication at end of cycle (EOC) 10 (condition monitoring) and projected EOC 11 (operational assessment) are listed in "CM LR" and "OA LR" columns in Table 1. The limiting W* SLB leak rates for condition monitoring and operational assessment are 0.477 gpm and 0.661 gpm, respectively, in SG 2-3 (see Table 2).

Table 2 reports the following SLB leak rates, pursuant to TS 5.6.10.e.4 and 5.6.10.f:

- 1. W* ARC SLB leakage for each SG at EOC 10. The maximum leak rate is 0.477 gpm in SG 2-3.
- 2. *W** *ARC SLB leakage for each SG at EOC 11.* The maximum leak rate is 0.661 gpm for SG 2-3.
- 3. Generic Letter (GL) 95-05 voltage based ARC SLB leakage for each SG at EOC 10 and EOC 11. The maximum EOC 10 leak rate is 1.041 gpm in SG 2-4. The maximum EOC 11 leak rate is 2.852 gpm in SG 2-4.

- 4. The aggregate calculated SLB leakage from application of both ARC at EOC 10. The maximum leak rate is 1.329 gpm in SG 2-4.
- 5. The aggregate calculated SLB leakage from application of both ARC at EOC 11. The maximum leak rate is 3.309 gpm in SG 2-4.

Growth Rates

Based on 2R10 inspections, 67 additional growth rate data points were added to the industry growth distribution for W* region axial PWSCC indications. There are 138 data points in the industry growth distribution. The updated 95 percent cumulative probability growth rate is 0.19 inch per effective full power year (EFPY), slightly lower than the prior rate of 0.21 inch per EFPY.

Insitu Leak Testing

In an effort to validate the leak rate model in WCAP-14797, Revision 1, four W* indications in three tubes were insitu leak tested in 2R10: SG 2-3 R7C52, SG 2-4 R3C5, and SG 2-4 R2C29 (2 indications). All indications were in tubes that had been deplugged in 2R9. The insitu guidelines for selecting indications for leak testing were established in PG&E Letter DCL-01-052, dated May 4, 2001.

Two indications required testing based on exceeding the insitu selection criteria. The peak Plus Point voltage for R2C29 was 4.51 volts, exceeding the 4.0 volt threshold voltage, and the depth profile indicated the flaw was greater than 80 percent deep for a length exceeding 0.1 inch. The peak Plus Point voltage for R7C52 was 3.37 and did not exceed the 4.0 volt threshold, but was among the 5 largest voltages and the depth profile indicated than 80 percent deep for a length exceeding 0.1 inch.

The peak Plus Point voltage for R3C5 was 1.51 volts and did not exceed the 4.0 volt threshold nor was it in the top 5 voltages, but was insitu tested for discretionary reasons because the depth profile indicated the flaw was greater than 80 percent deep for a length exceeding much greater than 0.1 inch, and the indication was located near the BWT.

The indications were insitu tested full length to normal operating pressure differential. Because they did not leak, the test was terminated at that pressure. Plus Point inspections were performed again and verified that the indications satisfy the W* repair criteria. The indications were returned to service.

Tube Integrity Performance Monitoring

Performance Criteria to Limit Free Span Cracking. The upper crack tip of W* indications returned to service under W* ARC shall remain below the TTS by at least the NDE uncertainty on locating the crack tip relative to the TTS. The "UCT to TSH"

column in Table 1 provides the elevation of the upper crack tip relative to the top of tubesheet, accounting for NDE uncertainty in locating the crack relative to the top of tubesheet. In all cases, the crack tip is below the top of tubesheet. Therefore, the performance criteria were satisfied for condition monitoring at EOC 10.

Accident-Induced Leakage Performance Criteria. Calculated W* leak rates under postulated SLB conditions, when combined with calculated leak rates from application of GL 95-05 voltage-based ARC, shall not exceed 12.8 gpm (at room temperature) in the faulted SG for condition monitoring and operational assessment. Based on Table 2, the aggregate calculated SLB leakage from application of both ARC at EOC 10 and EOC 11 for the limiting SG is much less than the allowable limit of 12.8 gpm for a faulted SG. Therefore, the performance criteria were satisfied for condition monitoring at EOC 10 and operational assessment at EOC 11.

 Table 1

 DCPP Unit 2 - 2R10 Axial PWSCC Indications in Hot Leg WEXTEX Region

SG	R	с	IND	PP Volts	From	То	L	UC T to TSH	W* Zone	W* L	вwт	UCT to BWT	UCT Below W*	UCT below BWT	EOC 11 UCT	UCT below TSH at EOC 11	W* Tube	Insp Ext	W* Insp Dist	Flex W* L	CM LR	EOC 11 UCT- BWT	OA LR	LIS 2R9	Deplug 2R9	Plug 2R10
2-1	7	24	SAI	0.26	-1.92	-1.78	0.14	-1.56	B3	7.12	-0.25	1.25	No	Yes	-1.22	Yes	Yes	- 9.77	9.43	7.46	0.015	-1.00	0.018	YES	YES	
2-1	8	32	SAI	0.48	-1.75	-1.62	0.13	-1.4	B2	7.12	-0.25	1.09	No	Yes	-1.06	Yes	Yes	-9.94	9.6	7.45	0.017	-0.84	0.021	YES	-	
2-1	15	32	SAI	0.4	-0.46	-0.35	0.11	-0.13	B2	7.12	-0.4	-0.33	No	No	0.21	No	No	-9.73	9.24	7.43	0.045	0.58	0.000	-	-	Yes
2-1	11	37	SAI-1	0.55	-7.34	-7.2	0.14	-6.98	B2	7.12	-0.33	6.59	No	Yes	-6.64	Yes	Yes	-9.56	9.14	7.86	0.000	-6.34	0.000	YES	-	
2-1	11	37	SAI-2	0.74	-6.45	-6.29	0.16	-6.07	B2	7.12	-0.33	5.68	No	Yes	-5.73	Yes	Yes	-9.56	9.14	7.86	0.001	-5.43	0.001	YES	-	
2-1	11	37	SAI-3	0.4	-1.85	-1.61	0.24	-1.39	B2	7.12	-0.33	1	No	Yes	-1.05	Yes	Yes	-9.56	9.14	7.86	0.018	-0.75	0.023	YES	-	
2-1	11	39	SAI	1.55	-1.5	-1.37	0.13	-1.15	B1	7.12	-0.33	0.76	No	Yes	-0.81	Yes	Yes	-9.26	8.84	7.45	0.022	-0.51	0.028	YES	YES	L
2-1	11	40	SAI	0.48	-0.94	-0.79	0.15	-0.57	B1	7.12	-0.31	0.2	No	Yes	-0.23	Yes	Yes	-8.85	8.45	7.47	0.038	0.05	0.045	YES	-	
2-1	11	48	SAI	1.68	-5.05	-4.67	0.38	-4.45	B1	7.12	-0.36	4.03	No	Yes	-4.11	Yes	Yes	-10.14	9.69	7.70	0.005	-3.78	0.005	YES	-	
2-1	9	49	SAI	0.32	-2.04	-1.9	0.14	-1.68	B1	7.12	-0.32	1.3	No	Yes	-1.34	Yes	Yes	-10.39	9.98	7.46	0.015	-1.05	0.018	-	-	ļ
2-1	3	59	SAI	4.67	-1.41	-0.81	0.6	-0.59	B1	7.12	-0.36	0.17	No	Yes	-0.25	Yes	Yes	-9.82	9.37	7.92	0.039	0.08	0.045	YES	YES	
2-1	7	62	SAI	4.08	-2.13	-1.53	0.6	-1.31	B2	7.12	-1.06	0.19	No	Yes	-0.97	Yes	Yes	-21.4	20.25	7.92	0.038	0.06	0.045	YES	YES	
2-1	23	70	SAI	1.03	-1.58	-1.23	0.35	-1.01	Α	5.32	-0.13	0.82	No	Yes	-0.67	Yes	Yes	-9.1	8.88	5.87	0.016	-0.57	0.026	YES	YES	<u> </u>
2-1	6	77	SAI	1.21	-1.36	-1.17	0.19	-0.95	B4	7.12	-0.4	0.49	No	Yes	-0.61	Yes	Yes	-9.47	8.98	7.51	0.028	-0.24	0.037	YES	YES	L
2-2	28	15	SAI-1	2.95	-20.1	-18.6	1.47	-18.38	Α	5.32	-0.36	17.96	Yes	Yes	-18.04	Yes	Yes	-21.4	20.95	N/A	0.000	-17.71	0.000	YES	YES	
2-2	28	15	SAI-2	3.95	-20	-18.64	1.36	-18.42	Α	5.32	-0.36	18	Yes	Yes	-18.08	Yes	Yes	-21.4	20.95	N/A	0.000	-17.75	0.000	YES	YES	<u> </u>
2-2	28	15	SAI-3	0.67	-10.7	-10.55	0.16	-10.33	Α	5.32	-0.36	9.91	Yes	Yes	-9.99	Yes	Yes	-21.4	20.95	N/A	0.000	-9.66	0.000	YES	YES	<u> </u>
2-2	28	15	SAI-4	0.69	-2.49	-2.34	0.15	-2.12	A	5.32	-0.36	1.7	No	Yes	-1.78	Yes	Yes	-9.86	9.41	5.52	0.005	-1.45	0.007	YES	YES	
2-2	28	15	SAI-5	0.69	-2.08	-1.84	0.24	-1.62	Α	5.32	-0.36	1.2	No	Yes	-1.28	Yes	Yes	-9.86	9.41	5.52	0.008	-0.95	0.012	YES	YES	ļ
2-2	5	18	SAI	0.56	-1.16	-0.95	0.21	-0.73	B4	7.12	-0.28	0.39	No	Yes	-0.39	Yes	Yes	-10.59	10.22	7.53	0.031	-0.14	0.042	YES	-	
2-2	31	25	SAI	3.82	-2.01	-1.52	0.49	-1.3	A	5.32	-0.5	0.74	No	Yes	-0.96	Yes	Yes	-9.29	8.7	6.01	0.019	-0.49	0.029	YES	YES	ļ
2-2	13	43	SAI	1.21	-1.43	-1.26	0.17	-1.04	B1	7.12	-0.36	0.62	No	Yes	-0.70	Yes	Yes	-9.48	9.03	7.49	0.024	-0.37	0.032	YES	YES	
2-2	10	48	SAI	0.53	-2.97	-2.84	0.13	-2.62	B1	7.12	-0.21	2.35	No	Yes	-2.28	Yes	Yes	-9.08	8.78	7.45	0.009	-2.10	0.009	YES	-	
2-2	10	56	SAI	1.01	-1.04	-0.90	0.14	-0.68	B1	7.12	-0.41	0.21	No	Yes	-0.34	Yes	Yes	-9.02	8.52	7.46	0.037	0.04	0.045	YES	YES	_
2-3	28	12	SAI	1.5	-2.24	-1.84	0.4	-1.62	Α	5.32	-0.57	0.99	No	Yes	-1.28	Yes	Yes	-9.74	9.08	5.92	0.009	-0.74	0.020	YES	-	<u> </u>
2-3	14	24	SAI	0.5	-1.94	-1.80	0.14	-1.58	B4	7.12	-0.17	1.35	No	Yes	-1.24	Yes	Yes	-8.82	8.56	7.46	0.009	-1.10	0.013	YES	YES	
2-3	16	24	SAI	0.29	-1.45	-1.30	0.15	-1.08	B4	7.12	-0.2	0.82	No	Yes	-0.74	Yes	Yes	-9.24	8.95	7.47	0.019	-0.57	0.026	YES	YES	
2-3	25	37	SAI	2.09	-1.68	-1.20	0.48	-0.98	B4	7.12	-0.38	0.54	No	Yes	-0.64	Yes	Yes	-9.21	8.74	7.80	0.026	-0.29	0.035	YES	YES	
2-3	45	37	SAI	1.55	-1.8	-1.51	0.29	-1.29	Α	5.32	-0.24	0.99	No	Yes	-0.95	Yes	Yes	-10.7	10.37	5.81	0.009	-0.74	0.020	YES	YES	
2-3	21	38	SAI	1.13	-1.62	-1.12	0.5	-0.9	B3	7.12	-0.45	0.39	No	Yes	-0.56	Yes	Yes	-9.64	9.1	7.82	0.031	-0.14	0.042	YES	YES	
2-3	12	48	SAI	0.38	-2.22	-2.08	0.14	-1.86	B1	7.12	-0.38	1.42	No	Yes	-1.52	Yes	Yes	-8.65	8.18	7.46	0.014	-1.17	0.017	YES	YES	
2-3	5	51	SAI	0.39	-2.1	-1.97	0.13	-1.75	B1	7.12	-0.29	1.40	No	Yes	-1.41	Yes	Yes	-9.38	9	7.45	0.014	-1.15	0.017	YES	YES	
2-3	7	52	SAI	3.9	-1.32	-0.77	0.55	-0.55	B1	7.12	-0.21	0.28	No	Yes	-0.21	Yes	Yes	-8.88	8.58	7.87	0.000	-0.03	0.045	YES	YES	1

Enclosure 1 PG&E Letter DCL-01-086

SG	R	с	IND	PP Volts	From	То	L	UCT to TSH	W* Zone	W* L	в₩Т	UCT to BWT	UCT Below W*	UCT below BWT	EOC 11 UCT	UCT below TSH at EOC 11	W* Tube	Insp Ext	W* Insp Dist	Flex W* L	CM LR	EOC 11 UCT- BWT	OA LR	LIS 2R9	Deplug 2R9	Plug 2R10
2-3	5	55	SAI	0.78	-2.14	-1.96	0.18	-1.74	B1	7.12	-0.17	1.51	No	Yes	-1.40	Yes	Yes	-9.41	9.15	7.50	0.013	-1.26	0.016	YES		
2-3	32	55	SAI	0.97	-0.98	-0.74	0.24	-0.52	Α	5.32	-0.36	0.10	No	Yes	-0.18	Yes	Yes	-9.81	9.36	5.76	0.042	0.15	0.045	YES	YES	
2-3	7	59	SAI	1.44	-1.64	-1.28	0.36	-1.06	B1	7.12	-0.27	0.73	No	Yes	-0.72	Yes	Yes	-8.81	8.45	7.68	0.023	-0.48	0.029	YES	YES	
2-3	9	63	SAI	0.4	-1.19	-1.06	0.13	-0.84	B2	7.12	-0.31	0.47	No	Yes	-0.50	Yes	Yes	-8.69	8.29	7.45	0.027	-0.22	0.038	-	-	
2-3	3	69	SAI	0.55	-1.05	-0.90	0.15	-0.68	B2	7.12	-0.27	0.35	No	Yes	-0.34	Yes	Yes	-9	8.64	7.47	0.032	-0.10	0.043	YES	<u> </u>	[
2-3	19	71	SAI	1.28	-2.1	-1.78	0.32	-1.56	Α	5.32	-0.25	1.25	No	Yes	-1.22	Yes	Yes	-9.73	9.39	5.84	0.008	-1.00	0.010	YES	YES	
2-3	17	72	SAI	1.83	-0.96	-0.60	0.36	-0.38	Α	5.32	-0.23	0.09	No	Yes	-0.04	Yes	Yes	-9.74	9.42	5.88	0.042	0.16	0.045	YES	YES	L
2-3	6	77	SAL	0.35	-1.71	-1.63	0.08	-1.41	B4	7.12	-0.28	1.07	No	Yes	-1.07	Yes	Yes	-9.75	9.38	7.40	0.013	-0.82	0.019	YES	YES	ļ
2-3	21	83	SAI	1.32	-1.11	-0.85	0.26	-0.63	Α	5.32	-0.23	0.34	No	Yes	-0.29	Yes	Yes	-9.49	9.17	5.78	0.032	-0.09	0.043	YES	YES	ļ
2-3	2	91	SAI	0.63	-0.84	-0.61	0.23	-0.39	A	5.32	-0.19	0.14	No	Yes	-0.05	Yes	Yes	-8.79	8.51	5.75	0.040	0.11	0.045	YES	YES	
2-3	7	92	SAL	1	-0.88	-0.69	0.19	-0.47	Α	5.32	-0.19	0.22	No	Yes	-0.13	Yes	Yes	-8.78	8.5	5.71	0.037	0.03	0.045	YES	YES	
2-3	8	93	SAL	1.38	-0.81	-0.59	0.22	-0.37	Α	5.32	-0.11	0.20	No	Yes	-0.03	Yes	Yes	-9.26	9.06	5.74	0.038	0.05	0.045	YES	YES	
2-4	7	4	SAI	0.87	-1.26	-1.09	0.17	-0.87	A	5.32	-0.24	0.57	No	Yes	-0.53	Yes	Yes	-8.69	8.36	5.69	0.025	-0.32	0.034	YES	YES	L
2-4	13	4	SAL	0.39	-1.35	-1.23	0.12	-1.01	A	5.32	-0.27	0.68	No	Yes	-0.67	Yes	Yes	-8.39	8.03	5.64	0.021	-0.43	0.030	YES	-	
2-4	3	5	SAL	1.51	-1.53	-0.81	0.72	-0.59	Α	5.32	-0.26	0.27	No	Yes	-0.25	Yes	Yes	-8.61	8.26	6.24	0.000	-0.02	0.045	YES	YES	
2-4	2	10	SAL	0.56	-1.38	-1.28	0.1	-1.06	Α	5.32	-0.13	0.87	No	Yes	-0.72	Yes	Yes	-8.44	8.22	5.62	0.014	-0.62	0.025	YES	YES	
2-4	15	10	SAI	0.42	-0.9	-0.73	0.17	-0.51	Α	5.32	-0.22	0.23	No	Yes	-0.17	Yes	Yes	-8.35	8.04	5.69	0.036	0.02	0.045	YES	YES	L
2-4	16	10	SAI	1.98	-2.16	-1.82	0.34	-1.6	A	5.32	-0.11	1.43	No	Yes	-1.26	Yes	Yes	-8.41	8.21	5.86	0.006	-1.18	0.008	YES	YES	
2-4	3	12	SAI-1	0.54	-2.64	-2.52	0.12	-2.3	A	5.32	-0.29	1.95	No	Yes	-1.96	Yes	Yes	-8.12	7.74	5.86	0.004	-1.70	0.005	YES	YES	
2-4	3	12	SAI-2	1.07	-2.32	-2.1	0.22	-1.88	A	5.32	-0.29	1.53	No	Yes	-1.54	Yes	Yes	-8.12	7.74	5.86	0.006	-1.28	0.008	YES	YES	
2-4	24	26	SAI	0.55	-1.85	-1.66	0.19	-1.44	A	5.32	-0.31	1.07	No	Yes	-1.10	Yes	Yes	-9.44	9.04	5.71	0.009	-0.82	0.017	YES	-	
2-4	2	29	SAI-1	4.45	-4.37	-3.42	0.95	-3.2	B2	7.12	-0.26	2.88	No	Yes	-2.86	Yes	Yes	-10.23	9.88	8.53	0.000	-2.63	0.007	YES	YES	
2-4	2	29	SAI-2	0.94	-2	-1.74	0.26	-1.52	B2	7.12	-0.26	1.2	No	Yes	-1.18	Yes	Yes	-10.23	9.88	8.53	0.000	-0.95	0.015	YES	YES	
2-4	6	33	SAI	0.72	-2.51	-2.36	0.15	-2.14	B2	7.12	-0.35	1.73	No	Yes	-1.80	Yes	Yes	-8.3	7.86	7.47	0.011	-1.48	0.013	YES	l	
2-4	4	35	SAL	0.99	-1.69	-1.46	0.23	-1.24	B1	7.12	-0.26	0.92	No	Yes	-0.90	Yes	Yes	-9.52	9.17	7.55	0.020	-0.67	0.024	YES	YES	
2-4	5	36	SAI	0.3	-1.96	-1.8	0.16	-1.58	B1	7.12	-0.11	1.41	No	Yes	-1.24	Yes	Yes	-8.86	8.66	7.48	0.014	-1.16	0.017	YES	<u> </u>	
2-4	5	37	SAI-1	0.26	-4.18	-4.03	0.15	-3.81	B1	7.12	-0.28	3.47	No	Yes	-3.47	Yes	Yes	-8.71	8.34	7.84	0.006	-3.22	0.007	YES	YES	
2-4	5	37	SAI-2	1.38	-3.98	-3.61	0.37	-3.39	B1	7.12	-0.28	3.05	No	Yes	-3.05	Yes	Yes	-8.71	8.34	7.84	0.007	-2.80	0.008	YES	YES	
2-4	7	38	SAI-1	2.43	-7.04	-6.72	0.32	-6.5	B1	7.12	-0.4	6.04	No	Yes	-6.16	Yes	Yes	-8.67	8.18	8.24	0.000	-5.79	0.001	YES	YES	
2-4	7	38	SAI-2	1.69	-4.62	-4.02	0.6	-3.8	B1	7.12	-0.4	3.34	No	Yes	-3.46	Yes	Yes	-8.67	8.18	8.24	0.006	-3.09	0.007	YES	YES	
2-4	13	40	SAI	1.19	-1.69	-1.45	0.24	-1.23	B2	7.12	-0.27	0.9	No	Yes	-0.89	Yes	Yes	-8.77	8.41	7.56	0.020	-0.65	0.029	YES	YES	
2-4	26	45	SAI	0.91	-3.42	-3.27	0.15	-3.05	B4	7.12	-0.32	2.67	No	Yes	-2.71	Yes	Yes	-8.19	7.78	7.47	0.004	-2.42	0.004	YES	-	
2-4	31	45	SAI	1.38	-1.98	-1.71	0.27	-1.49	A	5.32	-0.35	1.08	No	Yes	-1.15	Yes	Yes	-9.17	8.73	5.79	0.009	-0.83	0.017	YES	YES	
2-4	20	47	SAI	1.29	-1.63	-1.32	0.31	-1.1	B2	7.12	-0.33	0.71	No	Yes	-0.76	Yes	Yes	-8.81	8.39	7.63	0.023	-0.46	0.029	YES	YES	
2-4	5	53	SAI	1.37	-1.97	-1.69	0.28	-1.47	B1	7.12	-0.46	0.95	No	Yes	-1.13	Yes	Yes	-9.51	8.96	7.60	0.019	-0.70	0.023	YES	-	
2-4	25	64	SAI	1.63	-1.3	-1.02	0.28	-0.8	B4	7.12	-0.24	0.5	No	Yes	-0.46	Yes	Yes	-8.77	8.44	7.60	0.027	-0.25	0.037	YES	YES	

Column - Table 1	Legend and Notes for Table 1
SG	Steam generator
R	Row
C	Column
IND	Plus point indication. SAI is single axial indication. Some tubes have multiple non-parallel SAI.
PP Volts	Peak voltage from Plus Point coil.
From - To	Elevation (inch) of lower crack tip (from) to upper crack tip (to), relative to the hot leg top of tubesheet (TSH).
L	Length of crack (inch)
UCT to TSH	Elevation (inch) of the upper crack tip (UCT) relative to TSH, including ANDECT-TTS (Plus Point NDE uncertainty on locating the
	crack tip relative to the TTS). None of the indications extended above the top of tubesheet.
W* Zone	W* tubesheet zone based on crack location.
W*L	W* length based on W* Zone, plus ∆NDE _W (NDE uncertainty in measuring the W* depth).
BWT	Bottom of the WEXTEX transition (inch), measured by bobbin relative to TSH.
UCT to BWT	Distance (inch) from the upper crack tip (UCT) to BWT, minus ∆NDE _{CT-BWT} (Plus Point NDE uncertainty on locating the crack tip
	relative to the BWT).
UCT below W*	If the UCT is located below the W* length, then the tube is a W* tube. Any type of degradation below the W* length is acceptable.
UCT below BWT	If the UCT is located below BWT, then the tube is a W* candidate.
EOC 11 UCT	UCT location (inch) relative to TSH at the end of the next operating cycle, EOC 11, based on growing the UCT at 0.21 inch/EFPY.
	Unit 2 Cycle 11 is projected to be 1.61 EFPY.
UCT below TSH at EOC 11	If the UCT is below TSH at EOC 11, a free span indication is precluded and the tube is a W* candidate.
W* Tube	If the UCT is below BWT and the UCT is below TSH at EOC 11, then the tube is a W* tube. If the UCT is located below the W*
	length, then the tube is a W* tube.
Insp Ext	Inspection extent of Plus Point relative to TSH (inch)
W* Insp Dist	W* inspection distance (inch). This is the +Point inspection extent relative to BWI. The W* inspection distance below BWI is
	equal to the Plus Point inspection extent below ISH, plus measured distance from BWT to TSH, plus bobbin NDE uncertainty in
	locating BWT relative to TSH. The W* inspection distance must be greater than or equal to the flexible W rength.
Flex W* L	Flexible W* length relative to BWT (inch), equal to W* Length + Σ_{CI} (total axial crack length) + N _{CL} Δ NDE _{CL} (number of indications
	times Plus Point NDE uncertainty with measuring length of axial cracks) + N _{CL} *ACG (number of indications times crack growth
	allowance from prior cycle tube integrity assessment, 0.21 inch/EFPY)
	Condition monitoring SLB leak rate at EUC 10 conditions, gpm at room temperature, using Figure 0.4-5 of WCAF-14/97 Rev 1,
	based on distance of UCT to BWT. No accident leakage is assigned to indications with UCT below the W length. No accident
	Distance of LICT to DWT (inch) at ECC 11 for operational assessment, based on growing the LICT at the latest undated industry
	combined 05 percent growth rate (0.19 inch/EEPY)
	Operational assessment leak rate at EOC 11 conditions, gpm at room temperature, using Figure 6.4-3 of WCAP-14797 Rev 1.
	based on distance of projected UCT (at EOC 11) to BWT.
115 289	Indication had been left in service in 2R9.
Deplug 2R9	Tube had been deplugged in 2R9.
Plug 2B10	Tube was plugged in 2R10
	Trave had plagged in Error

Table 2

DCPP Unit 2 Steam Line Break Leak Rates for Alternate Repair Criteria

EOC 10 Condition Monitoring Leak Rate (gpm at room temperature)	SG 2-1	SG 2-2	SG 2-3	SG 2-4
W* ARC	0.297	0.133	0.477	0.288
Voltage-Based ARC	0.150	0.055	0.124	1.041
Aggregate ARC	0.447	0.188	0.601	1.329

EOC 11 Operational Assessment Leak Rate (gpm at room temperature)	SG 2-1	SG 2-2	SG 2-3	SG 2-4
W* ARC	0.314	0.176	0.661	0.457
Voltage-Based ARC	0.617	0.344	0.353	2.852 (1)
Aggregate ARC	0.931	0.520	1.014	3.309

Note 1: SG 2-4 leak rate of 2.852 gpm was calculated using a normal growth rate distribution. Using a more conservative voltage-dependent growth rate distribution, leak rate of 3.730 gpm was calculated for SG 2-4.

Enclosure 2 PG&E Letter DCL-01-086

SPECIAL REPORT 01-04

90-DAY REPORT GENERIC LETTER 95-05 VOLTAGE-BASED REPAIR CRITERIA DIABLO CANYON POWER PLANT UNIT 2 TENTH REFUELING OUTAGE

FRAMATOME ANP	CAI	CULATION SU	JMMARY SHEET	(CSS)						
Document Identifier	86 - 5013685 - 01									
Title DCPP Unit	2 - 2R10 90 Day ARC	Calculations								
PREPAREI	D BY:		REVIEWED BY:							
		METHOD: 🛛 DETAILE								
NAME Victor F Newmai	n	NAME A	lan M Brown							
SIGNATURE			Hen M							
TITLE Engineer IV	DATE 8/15/01		ngineer IV DATE	8/15/01						
COST CENTER 12742	REF. PAGE(S) <u>62-63</u>	TM STATEMENT: REVIEWER INDEPEND	DENCE AND FOR	JMF						
PURPOSE AND SUMMARY OF RESULTS: This report provides the results of the Diablo Canyon Unit 2 May 2001 Outage (2R10) with respect to (1) the eddy current inspection of the steam generator tubes at TSP intersections and (2) the implementation of the Alternate Repair Criteria (ARC) as specified in Generic Letter 95-05 for ODSCC at TSP intersections in Westinghouse-designed steam generators with drilled supports and alloy 600 tubing. This summary also provides the projected EOC-11 probability of burst and leak rate tube integrity calculations as required for ARC implementation. Note that this is the non-proprietary version of the 90 Day summary report contained in Ref. 24.										
THE FOLLOWING COMPUTE	R CODES HAVE BEEN USED	IN THIS DOCUMENT:	THE DOCUMENT CONTA THAT MUST BE VERIFIED SAFETY-RELAT	INS ASSUMPTIONS PRIOR TO USE ON ED WORK						
CODE/VERSION/REV	co	DE/VERSION/REV								
Burst97 Simulation/1.0/01										
Leaker97 Simulation/1.0/00			YES	NO NO						

Page <u>1</u>	of	<u> 63 </u>
---------------	----	-----------------

RECORD OF REVISIONS

Revision Number	Affected Page(s)	Description of Change(s)
0	All	Original Release
1	35 59 9	Removed Section 4.1 in Rev. 0 Added SG 2-4 specific growth distribution Added reasons for using SG 2-4 growth distribution
	6 10 6, 7, 8, 11, & 63	Section 2.0; changed 864 to 862, added sentence regarding AONDB indications Section 3.3; removed text in 2 nd paragraph Miscellaneous editorial changes

TABLE OF CONTENTS

	TABLE OF CONTENTS	6
1.0	Introduction	.0
2.0	Executive Summary	.07
3.0	EOC-10 Inspection Results and Voltage Growth Rates	. /
3.	1 EOC-10 Inspection Results	. /
3.	2 Voltage Growth Rates	0.0
3.	3 Probe Wear Criteria	. 9
3.	4 Upper Voltage Repair Limit	11
3.	5 NDE Uncertainty Distributions	11
4.0	Database Applied for Leak and Burst Correlations	25
4.	.1 Conditional Probability of Burst	25
4.	.2 Conditional Leak Rate	20
5.0	Bobbin Voltage Distributions	20
5.	.1 Probability of Detection	20
5	.2 Probability of Prior Cycle Detection	20
5	.3 Calculation of BOC-11 Voltage Distributions	29
5	4 Predicted EOC-11 Voltage Distributions.	39
5	.5 Comparison of Predicted and Actual EOC-10 Voltage Distributions, Leak Rate and Probabil	aty
0	fBurst	40
60	Tube Leak Rate and Tube Burst Probabilities	59
6.0	1 Leak Rate and Tube Burst Probability for EOC-11	59
6	2 Summary and Conclusions	39
70	References	62
1.0		

LIST OF TABLES

,

1	12
Table 3-1: 2R10 DOS Indications > 2.0 volts	12
Table 3-2: 2R10 AONDB Indications	13
Table 3-3: Summary of Inspection and Repair for Tubes	11
Table 3-4: Summary of Largest Voltage Growth Rates per EFPY	15
Table 3-5: Voltage and Growth Distribution by TSP	16
Table 3-6: Summary of Voltage Growth per EFPY	17
Table 3-7: Voltage Dependent Growth	17 10
Table 3-8: Voltage Dependent Growth	10
Table 3-9: Re-tested DOSs \geq 1.5 Volts that Failed the Probe Wear Check	19
Table 3-10: New 2R10 DOSs >=0.5 Volts In Tubes Inspected With A Worn Probe In 2R9	20
Table 3-11: Summary of New DOS Indications Sorted by Category	41 22
Table 3-12: Percentage of Tubes With New Indications	22 22
Table 3-13: Average Growth Rates for Cycle 10	22
Table 3-14: NDE Uncertainty Distributions	25
Table 4-1: Tube Burst Pressure vs. Bobbin Amplitude Correlation	26
Table 4-2: 7/8" Tube Probability of Leak Correlation (2560 psi)	30
Table 4-3: Leak Rate Database for 7/8" Tube ARC Applications	<i>A</i> 1
Table 5-1: Diablo Canyon Unit 2 POPCD Evaluation	41
Table 5-2: SG 2-1 As-Found and BOC-11 Voltage Distribution	42
Table 5-3: SG 2-2 As-Found and BOC-11 Voltage Distribution	45
Table 5-4: SG 2-3 As-Found and BOC-11 Voltage Distribution	44
Table 5-5: SG 2-4 As-Found and BOC-11 Voltage Distribution	- - -5 //6
Table 5-6: Summary of Monte Carlo Simulations	40
Table 5-7: EOC-11 Distributions with POD=0.6	18
Table 5-8: EOC-11 Voltage Distributions with EPRI POPCD	40
Table 5-9: EOC-10 As-Found vs Projected Voltage Distribution	50
Table 5-10: EOC-10 Projected vs Actual POB & Leak Rate	60
Table 6-1: Leak Rate and Burst Probability Using 0.6 POD.	61
Table 6-2: Leak Rate and Burst Probability Using POPCD	01

.

Glossary of Acronyms

. .

Term	Definition
AONDB	Axial ODSCC Not Detected by Bobbin
ARC	Alternate Repair Criteria
BOC	Beginning of Cycle
CPDF	Cumulative Probability Distribution Function
CFR	Code of Federal Regulations
CLT	Cold-Leg Thinning
DCPP	Diablo Canyon Power Plant
DIS	Distorted ID Support Signal with possible Indication
DOS	Distorted OD Support Signal with possible Indication
DNF	Degradation Not Found
EFPD	Effective Full Power Day
EFPY	Effective Full Power Year
ECT	Eddy Current Test
EOC	End of Cycle
FS	Free Span
FRA-ANP	Framatome Advanced Nuclear Power
GL	NRC Generic Letter 95-05
GPM	Gallons per Minute
ISI	In-service Inspection
LRL	Lower Repair Limit
MSLB	Main Steam Line Break
NDE	Non Destructive Examination
NDD	No Degradation Detected
NRC	Nuclear Regulatory Commission
ODSCC	Outside Diameter Stress Corrosion Cracking
PG&E	Pacific Gas and Electric Company
POB	Probability of Burst
POD	Probability of Detection
POPCD	Probability of Prior Cycle Detection
POL	Probability of Leak
PWSCC	Primary Water Stress Corrosion Cracking
RPC	Rotating Pancake Coil
RSS	Retest Support Plate Signal
RTS	Return to Service
SG	Steam Generator
SER	Safety Evaluation Report
TS	Technical Specification
TSP	Tube Support Plate
WEXTEX	Westinghouse Explosive Tubesheet Expansion
+Point	Plus Point Coll

1.0 Introduction

The Diablo Canyon Power Plant (DCPP) Unit 2 completed the tenth cycle of operation and subsequent steam generator ISI in May 2001. The unit employs four Westinghouse-designed Model 51 SGs with 7/8-inch OD mill annealed alloy 600 tubing and ³/₄-inch carbon steel drilled-hole tube support plates.

In accordance with the Generic Letter 95-05, ARC implementation requires a pre-startup assessment (Ref. 1) and a 90-day post-startup tube integrity assessment. The NRC Generic Letter 95-05, Ref. 2, outlines an alternate repair criteria (ARC) for allowing tubes containing ODSCC indications to remain in service if the indications are contained within the TSP structure and the measured Bobbin voltage is ≤ 2.0 volts. A complete list of exclusion criteria is provided in section 1.b of Ref. 2 and in Ref. 3. The NRC has approved implementation of the voltage-based repair criteria at both DCPP units per Ref. 3. The steam generator TSP ISI results and the postulated MSLB leak rate and tube burst probabilities are summarized in this report. FRA-ANP uses Monte Carlo codes, as described in Refs. 4 and 5, to provide the burst and leak rate analysis simulations. These evaluations are based on the methods in Ref. 6, as well as previous 90-day reports (Refs. 7 - 10). The correlation parameters used in the simulation are taken from the EPRI ODSCC ARC Addendum 3 Updated Database (Ref. 13) for burst correlations and Addendum 2 Updated Database (Ref. 20) for leak rate correlations as reviewed in Section 4 of this report.

2.0 Executive Summary

Based on the number of indications and the size of the indications, SG 2-4 is predicted to be the limiting generator for Diablo Canyon Unit 2 at the end of Cycle 11. During Cycle 10, SG 2-4 started experiencing voltage dependent growth, where the larger indications were growing faster as measured by voltage. Of the 115 plus point inspections, 100 were confirmed yielding an overall confirmation rate of about 87%. Based on the plus point confirmation rate, approximately 687 tubes were saved by the implementation of the ARC during 2R10.

The EOC-11 leak rate correlations used were based on the latest NRC approved database for 7/8" tubing (Ref. 13). Both NRC mandated constant 0.6 POD and the voltage dependent distribution POPCD were considered. The results of POPCD are provided in Section 6 of this document. The limiting EOC-11 SLB leak rates (SG 2-4) predicted with constant POD were 2.85 gpm (Normal growth) and 3.73 gpm (voltage dependent growth), where both predictions meet the limit of 12.8 gpm for a full cycle of operation. The tube burst probabilities with constant POD for the limiting generator (SG 2-4) were 1.30 x 10⁻³ (normal growth) and 3.66 x 10^{-3} (voltage dependent growth), which is well below the NRC reporting guideline of 1.0×10^{-2} .

A total of 862 indications were found in the EOC-10 inspection, of which 148 were over 1 volt, 22 were over 2 volts, and 3 exceeded the upper repair limit of 4.9 volts. All indications over 2 volts were confirmed by plus point inspection and repaired by plugging. Two additional indications were identified as AONDB (axial ODSCC not detected by bobbin).

The EOC-10 projections were approximately equivalent to the actual as-found conditions of the SGs. SG 2-3 and SG 2-4 experienced voltage dependent growth over the previous cycle;

however, it was not significant enough to invalidate the previous 90-day report projections. Refer to Section 5.5 for further details.

3.0 EOC-10 Inspection Results and Voltage Growth Rates

3.1 EOC-10 Inspection Results

The DCPP 2R10 bobbin coil inspection consisted of a 100% complete full-length bobbin coil examination of tubes in all four steam generators except Rows 1 and 2 U-bends. 720 replaceable feet bobbin probes were used for the straight length examinations including all TSP intersections in the hot and cold legs. Special interest plus point examinations were conducted as follows in support of the voltage-based ARC.

- 100% of DOSs greater than 2 volts (as identified in Ref. 12)
- 100% of DOSs in dented intersections (Ref. 12)
- 100% of DISs
- Dent examinations per Ref. 12.
- Other Special Interest or test programs that may test TSP intersections per Ref. 12.

Based upon the 100% bobbin inspection of all steam generators, a total of 862 DOS indications were identified. The results of the inspections are summarized as follows:

- 1. Table 3-1 lists the DOS indications that were above the LRL (2.0 volts). Each of the indications was confirmed as ODSCC and was repaired by plugging.
- 2. 2 circumferential ODSCC indications were detected at support plates containing dents >5 volts in SG 2-2.
- 3. Table 3-2 lists the indications that were identified as AONDB (axial ODSCC not detected by bobbin). These indications have axial ODSCC but with no indication of a bobbin DOS signal. One of the indications was called DIS and the other was NDD by bobbin. These locations are typically smaller voltage ODSCC, by plus point, and are accompanied by a dent that masks the bobbin voltage. Per Refs. 12 and 13, a methodology has been developed to assign a bobbin voltage based on a correlation to the plus point voltage. Once the calculated voltages are obtained, the locations are subjected to the same exclusion criteria as the DOS population.
- 4. 5 DOS indications were detected in the cold leg thinning (CLT) region. These indications were inspected with plus point and confirmed as CLT. They were not included in the DOS analysis pool.
- 5. Overall, 38 DOS indications in 28 tubes were repaired.

A summary of the ECT results for TSP indications is provided in Table 3-3. Table 3-3 summarizes the voltage distributions for the as-found condition of the indications, the repaired indications, the indications returned to service that were either confirmed by plus point or not inspected with plus point, and finally, the indications returned to service. Table 3-3 clearly illustrates that steam generator 2-4 is the limiting generator based on the number of indications and the number of large indications. Over 50% of the indications removed from service exceeded the 2 volt repair criteria; others were plugged due to exclusion criteria. The plus point inspections required for DOS indications were accomplished as a part of the special interest exams. The 2R10 inspection scope also included a scheduled number of dents based on the current inspection results as noted in the degradation assessment (Ref. 12). 115 plus point inspections were performed where DOS indications were called by bobbin, i.e., excluding the AONDB intersections. Of the inspections, 100 were confirmed yielding an overall confirmation rate of about 87%. Based on the plus point confirmation rate, approximately 687 tubes were saved by the implementation of the ARC during 2R10.

Figure 3-1 and Figure 3-2 show the actual bobbin voltage distribution for all tubes that were in service during Cycle 10. Figure 3-3 and Figure 3-4 show the indications removed from service at EOC-10. Notice that the largest number of indications removed from service were in SG 2-4; thus, further supporting the conclusion that SG 2-4 is the limiting generator. Figure 3-5 and Figure 3-6 illustrate all the indications returned to service following the EOC-10 ECT inspection. Note that a large number of >1 volt indications are being returned to service in SG 2-4. Table 3-4 summarizes the largest voltage indications, as well as indications that experienced the largest growth over the previous cycle of operation. Table 3-4 illustrates that all the \geq 2 volt indications were present during the previous cycle; however, these indications also have the largest growth rates for all SGs. Voltage dependent growth will be explored further in the growth section of this report.

A summary of the ECT voltages and growth by TSP is provided in Table 3-5 and Figure 3-7. As shown, the ODSCC mechanism is most active at the lower TSPs with minimal interaction at the 6th TSP and no interaction at the 7th TSP. The largest maximum growth also occurs at the 1st and 2nd TSPs. This distribution indicates a temperature dependence of ODSCC at Diablo Canyon Unit 2.

3.2 Voltage Growth Rates

For projection of leak rates and tube burst probabilities at the end of Cycle 11 operations, voltage growth rates were developed from the EOC-10 inspection data. For indications not reported during the EOC-9 inspection (i.e. new at EOC-10), the indications were sized using the EOC-9 ECT signals based on a lookup review. Table 3-5 provides the maximum and average voltage growth distribution by TSP. Table 3-6 shows the voltage growth distributions for each SG and the composite for all four SGs. The cumulative probability distribution function is also provided here. For the tube integrity calculations, the negative growth values were included as zero growth for all indications for each SG does not indicate any significant differences; however, reviewing the growth distribution for each SG in Figure 3-8 and Figure 3-9 indicates that SG 2-4 has significantly more indications. Also, using Figure 3-9, the growth distribution appears to be shifted further to the right for SG 2-4 and the tail of the distribution almost reaches 3 volts/EFPY.

To determine if these differences were due to voltage dependent growth, the growth rate was plotted against the BOC voltage for all SGs. This data for SG 2-1 and SG 2-2 is shown in Figure 3-10. This data for SG 2-3 and SG 2-4 is shown in Figure 3-11. Notice that the growth rate does significantly change for indications with a BOC voltage greater than one volt in SG 2-4. It is difficult to determine conclusively if SG 2-3 is experiencing the same type of voltage dependent growth rate given the small number of data points greater than one volt. Figure 3-12 shows the cumulative probability distribution functions for SG 2-4. Figure 3-13 illustrates the CPDF for all SGs. Table 3-7 and Table 3-8 summarize the voltage dependent growth distribution for all SGs as well as the CPDFs. For the voltage dependent growth, two different growth distributions were determined (one distribution for indications <= 1.00 volt and another distribution for indications > 1.00 volt). The 1 volt criterion was selected based on the guidance in Reference 20. Reference 20 states that the largest growth bin should be limited to about 50 indications. Using the > 1 volt criterion gives 42 indications in the growth distribution for SG 2-4 and 53 indications in the composite growth distribution. A composite growth distribution was used for SG 2-3 because SG 2-3 has less then 200 indications.

For the EOC-11 leak rate and probability of burst projections, the composite normal growth rate was used for SG 2-1, SG 2-2, and SG 2-3. A SG 2-4 specific normal growth distribution was used for SG 2-4 because the SG 2-4 growth distribution was limiting and SG 2-4 had more than 200 data points. In addition, a composite voltage dependent growth rate was used for SG 2-3 and SG 2-4 specific voltage dependent growth rate was used for SG 2-4.

To confirm that indications in the tubes deplugged at EOC-9 are growing similarly, the growth rates for EOC-9 deplugged tubes and EOC-9 in-service tubes were calculated separately and compared. The results for each SG are presented in Figure 3-14, Figure 3-15, Figure 3-16, and Figure 3-17. Figure 3-18 shows the CDPF for all deplugged tubes and all in-service tubes. There are no significant differences between deplugged tubes and in-service tubes.

Since DCPP-2 has more than the required minimum of 200 indications in its Cycle 10 active tube growth rate distribution, plant-specific growth rate can be used in lieu of the conservative industry bounding growth rate distribution. The cumulative probability distribution function (CPDF) for the five DCPP cycles in which voltage-based ARC was implemented are shown in Figure 3-19. This figure also shows the industry bounding growth distribution. Per the Generic Letter, the most limiting growth distribution from the two previous cycles should be used. Figure 3-19 shows that the U2-C10 growth distributions bounds the U2-C9 distribution. Therefore, the Cycle 10 growth distribution was used for the leakage and burst analysis.

3.3 Probe Wear Criteria

The first NRC requirement regarding probe wear is to minimize the potential for tubes to be inspected with a probe that had failed the probe wear check. This was accomplished by implementing ETSS #1 (Ref. 14) which required the probe have its feet replaced when failing the probe wear check, or in the case of non-changeable feet probes, the probe discarded.

If the DOS voltage is at the retest threshold (1.5 volts or higher) and the Cal is designated as "ARC Out" on the cal board, the indication code is changed from a DOS to a RSS (retest support plate signal). No new indications were detected in the tubes when inspected with the new probe.

The 2R10 eddy current inspection resulted in 25 bobbin indications in excess of 1.5 volts that were inspected with a worn probe. Those indications are shown in Table 3-9. The RSS and DOS voltage variation was tabulated for each worn probe inspection. The retest voltage values compare reasonably with the worn probe voltages. No retest voltage increased by more than 15% compared to the worn probe voltage. Figure 3-20 shows a comparison of the worn probe and good probe voltages. The data in this figure also includes data from previous Diablo Canyon inspections (1R9, 1R10, and 2R9). This figure shows that the voltages do not change significantly between the worn probes and the good probes. Therefore, continued use of the 1.5 volt retest threshold is justified.

All RSS bobbin indications were inspected in accordance with the Ref. 14 analysis guidelines. Review of the probe wear log sheets and the eddy current test results indicate that no tubes were inspected with a probe known to have failed the probe wear check. These reviews in conjunction with the results in Table 3-9 address the NRC requirements listed in Ref. 18.

The next requirement involves monitoring tubes that contain new DOS indications that were inspected with probes that failed the wear check in the previous outage. This evaluation is intended to look for new large indications or a non-proportionately large percentage of new indications in tubes that failed the check in the previous outage. Large is defined as ≥ 0.5 volt DOS. The 2R10 >= 0.5 volts DOS indications in tubes that failed the probe wear check in 2R9 are shown in Table 3-10.

Overall there were 862 DOS indications detected in the 2R10 inspection of the active tube population. 362 or 42% of the DOS indications were new indications. This percentage is considerably lower than the 2R9 results where about 62% of the DOS indications were new. The 2R10 results are more indicative of expected percentages as the population of repeat DOSs increase with consecutive outages implementing the ARC criteria.

In order to assess the new indications against the probe wear requirements, Table 3-11 and Table 3-12 are presented. Of the 362 total new indications, 169 were in tubes inspected with a worm probe in 2R9 and 193 were in tubes inspected with a good probe in 2R9. The number of new indications ≥ 0.5 volts was determined to be 147. Out of these, 62 were in tubes that were inspected with a worn probe in 2R9 and all were detectable in historical lookup review. When these numbers are compared to the total number of inspections in 2R9, the results shown in Table 3-12 are obtained. This table shows the approximate percentage of tubes with new indications. The results are categorized based on whether the previous inspection was performed with a worn probe or a good probe. This table shows that about 2.9% of the 2R9 worn probe inspections yielded new indications in 2R10. This is slightly higher than the 2.3 % rate for the tubes inspected with good probes in 2R9. For the new indications ≥ 0.5 volts, the rates were about the same (1.1% for the worn probes and 1.0% for the good probes).

Nearly all of the new DOS indications were detected during the historical review of the 2R9 data. Since most of the newly reported DOS indications were detected during the review of the 2R9 data, probe wear is not considered to be significantly affecting the quality of the data and,

therefore, the ODSCC detection capability. In addition, the fact that the rates of new indications ≥ 0.5 volts is about the same for the worn probe and the good probe populations suggests that detection of these larger indications is not affected. The slightly higher frequency of new indications in tubes inspected with worn probes is limited to indications < 0.5 volts which are insignificant relative to the tube integrity calculations.

New indications are more a result of probability of detection rather than the fact that the tube was inspected with a worn probe in 2R9. These percentages are not considered to indicate that a disproportionate number of new DOSs are present in tubes that were inspected with a worn probe in the previous outage. In summary, the NRC analysis requirements regarding probe wear monitoring were met during the 2R10 bobbin coil inspection and a more stringent wear tolerance is not required.

3.4 Upper Voltage Repair Limit

Per Generic Letter 95-05, the upper repair limit must be calculated prior to each outage, and the more conservative of the plant-specific average growth rate per EFPY or 30 percent per EFPY should be used as the anticipated growth rate input for this calculation. The upper voltage repair limit was calculated prior to the 2R10 inspection and was determined to be 4.9 volts (Ref. 15) based on the following formula. This calculation used a 35.6 percent per EFPY growth based on the 2R9 90-day report (Ref. 8).

$$V_{URL} = \frac{V_{SL}}{1 + \frac{\% V_{NDE}}{100} + \frac{\% V_{CG}}{100}}$$

V_{URL} = upper voltage repair limit,

where:

 $V_{NDE} = NDE$ voltage measurement uncertainty = 20%, V_{CG} = voltage growth anticipated between inspections = 35.6%,

 v_{CG} = voltage growth anticipated between hispections - 55.67%, V_{SL} = voltage structural limit from the burst pressure – Bobbin voltage correlation, where the limit of 8.3 volts was used based on Ref. 11.

Although the upper repair limit will not be calculated again until shortly before the next inspection, the average growth rates from Cycle 10 are documented in this report to verify the limiting growth rate to be used for the 2R11 outage. The 30% per EFPY NRC minimum limit is not bounding for DCPP Unit 2 Cycle 11 as Table 3-13 shows that the average percent growth for Cycle 10 is 33.4% per EFPY.

3.5 NDE Uncertainty Distributions

NDE uncertainties must be taken into account when projecting the end-of-cycle voltages for the next operating cycle. The NDE uncertainties used in the calculations of the EOC-11 voltages are described in Ref. 6. The acquisition uncertainty was sampled from a normal distribution with a mean of zero, a standard deviation of 7%, and a cutoff limit of 15% based on the use of the probe wear standard. The analyst uncertainty was sampled from a normal distribution with a mean of zero, a standard deviation of 10.3%, and no cutoff limit. These uncertainty distributions are shown in Table 3-14 and Figure 3-21.

SG	Row	Col	Ind	Elev	Inch	Volts	Deg	Cal
	5	17	DOS	2H	-0.02	3.35	61	HL-39
21	11	27	DOS	1H	0.06	2.54	68	CL-14
	5	5	DOS	3H	0.00	2.2	70	HL-30
	6	54	DOS	1H	0.02	2.16	77	CL-37
23	24	26	DOS	2H	0.09	4.31	69	CL-16
	27	59	DOS	1H	0.06	3.81	65	HL-4
	16	57	DOS	2H	-0.06	2.20	89	HL-2
	31	45	DOS	1H	0.02	2.23	96	CL-17
	27	69	DOS	2H	0.15	2.71	58	CL-37
	29	35	DOS	1H	0.00	2.74	86	CL-40
	24	84	DOS	1H	-0.06	2.89	66	HL-6
	38	60	DOS	2H	0.11	3.08	65	CL-37
	8	65	DOS	1H	0.13	3.13	63	CL-37
-	38	47	DOS	2H	0.13	3.32	72	CL-17
24	36	48	DOS	2H	0.22	3.44	70	CL-10
	7	62	DOS	1H	0.00	3.81	69	CL-40
	4	45	DOS	1H	0.04	4.06	58	HL-12
	13	63	DOS	1H	-0.04	4.14	63	CL-37
	5	48	DOS	1H	-0.11	4.40	74	HL-13
	42	48	DOS	2H	0.18	5.06	70	CL-11
	8	63	DOS	1H	0.10	5.22	66	CL-40
	3	51	DOS	1H	0.04	5.42	56	HL-13

Table 3-1: 2R10 DOS Indications > 2.0 volts

Table 3-2: 2R10 AONDB Indications

SG	Row	Col	Elevation	Dent Voltage	+Pt Voltage	Assigned DOS Voltage
22	12	• 71	1H	4.04	0.23	0.533
24	30	36	3H	4.19	0.23	0.533

_	SC 1						60.3		SG3			
[SG1				SG2	Samian			DOSs Returned to	Service
			DOSs Returned to	Service			DUSs Returned to	Service	A	Dansing	Conf ODSCC or	
Voltage	As-found	Repaired	Conf. OD-SCC or		As-found	Repaired	Cont. OD-SCC or	Total (1)	FOC-10	Tubes	Not Insn. w/+Pt	Total (1)
Bin	EOC-10	Tubes	Not Insp. w/+Pt	Total (1)	EOC-10	Tubes	Not insp. w/+rt	10tar (1)	ECC-IU	1000		
0.1											3	3
0.2	3		3	3	3				- 10		17	19
0.3	25		25	25	11				12		12	12
0.4	23		23	23	25		10	19	14		13	14
0.5	32		30	32	19		19	15	10		9	10
0.6	23		21	23		·	10	11	12		12	12
0.7	22		22				10		5		5	5
0.8	7		6	<u> </u>					6	· · · · · · · · · · · · · · · · · · ·	6	6
0.9	9		8	<u> </u>			6	6	1		1	1
1	4	1	3	3				<u> </u>	5		5	5
1.1	2		2		}			<u> </u>	2		2	2
1.2	3		3				2	2	2		2	2
1.3	3					I						
1.4	4		4						1		1	1
1.5	2											
1.6			<u></u>			<u> </u>						
1.7						t						<u> </u>
1.8	┝──┬──┤			2	1		1	1				L
1.9			<u>-</u> <u>-</u> <u>-</u> <u>-</u> <u>-</u>		1		1	1			L	
<u> </u>			<u>├</u>		· · · · · · · · · · · · · · · · · · ·						L	<u> </u>
2.1									2	2		
2.2												
2.3												
2.4											<u> </u>	<u> </u>
	2	2							2	2		
TOTAL	167	3	158	164	108	1	101	107	96	4	88	92
	19	2	17	17	5		5	5	14	4	10	10
>2 V	2	2							4	<u> 4 </u>		
			SG4			Com	osite of All SGs					
			DOSs Returned to	Service			DOSs Returned t	o Service				
Voltage	As-found	Renaired	Conf. OD-SCC or		As-found	Repaired	Conf. OD-SCC or					
Bin	EOC-10	Tubes	Not Insp. w/+Pt	Total (1)	EOC-10	Tubes	Not Insp. w/+Pt	Total (1)				
0.1			T									
0.2	6								1			
0.3	32		6	6	15		15	15				
0.4	-		<u>6</u> 32	6 32	15 87		15 83	15 87				
	58	3	6 32 55	6 32 55	15 87 118	4	15 83 112	15 87 114				
B 0.5	58 68	3	6 32 55 65	6 32 55 66	15 87 118 133	4	15 83 112 127	15 87 114 131				
0.5	58 68 73	3 2 2	6 32 55 65 70	6 32 55 66 71	15 87 118 133 122	4 2 2	15 83 112 127 115	15 87 114 131 120				
0.5	58 68 73 55	3 2 2 1	6 32 55 65 70 52	6 32 55 66 71 54	15 87 118 133 122 100	4 2 2 1	15 83 112 127 115 96	15 87 114 131 120 99				
0.5 0.6 0.7 0.8	58 68 73 55 40	3 2 2 1	6 32 55 65 70 52 40	6 32 55 66 71 54 40	15 87 118 133 122 100 55	4 2 2 1	15 83 112 127 115 96 54	15 87 114 131 120 99 55 55				
0.5 0.6 0.7 0.8 0.9	58 68 73 55 40 29	3 2 2 1	6 32 55 65 70 52 40 29	6 32 55 66 71 54 40 29	15 87 118 133 122 100 55 53		15 83 112 127 115 96 54 52 32	15 87 114 131 120 99 55 53 32				
0.5 0.6 0.7 0.8 0.9 1	58 68 73 55 40 29 22	3 2 2 1	6 32 55 65 70 52 40 29 22 22	6 32 55 66 71 54 40 29 22 22	15 87 118 133 122 100 55 53 33 25		15 83 112 127 115 96 54 52 32 32	15 87 114 131 120 99 55 55 53 32 32				
0.5 0.6 0.7 0.8 0.9 1 1.1	58 68 73 55 40 29 22 27 27	3 2 2 1 3	6 32 55 65 70 52 40 29 22 22 24 7	6 32 55 66 71 54 40 29 22 22 24	15 87 118 133 122 100 55 53 33 33 33 13		15 83 112 127 115 96 54 52 32 32 12	15 87 114 131 120 99 55 53 32 32 32 12				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.1	58 68 73 55 40 29 22 27 8	3 2 2 1 3 1	6 32 55 65 70 52 40 29 22 24 7 7	6 32 55 66 71 54 40 29 22 22 24 7 7	15 87 118 133 122 100 55 53 33 33 35 13	4 2 1 1 3 1	15 83 112 127 115 96 54 52 32 32 12 18	15 87 114 131 120 99 55 53 32 32 32 12 12				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3	58 68 73 55 40 29 22 27 8 11	3 2 2 1 	6 32 55 65 70 52 40 29 22 24 7 7 11	6 32 55 66 71 34 40 29 22 24 7 11	15 87 118 133 122 100 55 53 33 35 13 13 18	4 2 1 1 3 1 1	15 83 112 127 115 96 54 52 32 32 12 18 18	15 87 114 131 120 99 55 53 32 32 12 18 18				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4	58 68 73 55 40 29 22 27 8 11 15	3 2 2 1 3 1	6 32 55 65 70 52 40 29 22 24 7 11 11 14	6 32 55 66 71 54 40 29 22 22 22 24 7 11 11 14	15 87 118 133 122 100 55 53 33 33 35 13 18 19	4 2 2 1 3 1 1 1 1	15 83 112 127 115 96 54 52 32 32 12 18 9	15 87 114 131 120 99 55 53 32 32 32 12 18 18 9				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4 1.5	58 68 73 55 40 29 22 27 8 11 15 7	3 2 2 1 3 3 1 1 1	6 32 55 65 70 52 40 29 22 24 7 11 14 6 5	6 32 55 66 71 54 40 29 22 24 7 7 11 14 6 6	15 87 118 133 122 100 55 53 33 35 13 18 19 10 5	4 2 1	15 83 112 127 115 96 54 52 32 12 18 9 6	15 87 114 131 120 99 55 53 32 32 12 18 18 9 6				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4 1.5 1.6	58 68 73 55 40 29 22 27 8 11 15 7 6	3 2 2 1 3 1 1 1 1	6 32 55 65 70 52 40 29 22 24 7 11 14 6 7	6 32 55 66 71 54 40 29 22 22 24 7 7 11 11 14 6 6 7	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7		15 83 112 127 115 96 54 52 32 12 18 9 6 7	15 87 114 131 120 55 53 32 32 12 18 9 6 7				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4 1.5 1.6 1.7 1.7	58 68 73 555 40 29 22 27 8 11 15 7 6 7	3 2 2 t 3 1 1	6 32 55 65 70 52 40 29 22 24 7 11 14 6 7 5	6 32 55 66 71 54 40 29 22 24 7 11 14 6 6 7 5	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7 5		15 83 112 127 115 96 52 32 12 18 18 9 6 7 5	15 87 114 131 120 99 55 53 32 12 18 9 6 7 5				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4 1.5 1.6 1.7 1.8 1.2	58 68 73 555 40 29 22 27 8 11 15 7 6 7 5	3 2 2 1 3 1 1	6 32 55 65 70 52 40 29 24 7 11 14 6 6 7 5 3	6 32 55 66 71 54 40 29 22 24 7 11 14 6 6 7 3	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7 5 6	4 2 2 1 1 1 3 1 1 1 1	15 83 112 127 115 96 54 52 32 12 18 9 6 7 5 6	15 87 114 131 120 99 55 53 32 32 12 18 9 6 7 5 6				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4 1.5 1.6 1.7 1.8 1.9 2	58 68 73 55 40 29 22 27 8 11 15 7 6 7 5 3	3 2 2 1 3 1 1	6 32 55 65 70 52 40 29 22 24 7 11 14 6 7 5 3 5	6 32 55 66 71 40 29 22 22 24 11 14 6 7 7 5 3 3 5	15 87 118 133 122 100 55 53 33 35 13 18 19 6 7 5 6 7	4 2 2 1 1 3 1 1 1 1 1	15 83 112 127 115 96 54 52 32 32 12 18 9 6 7 5 6 7	15 87 114 131 120 99 55 53 32 32 12 18 9 6 7 5 6 7 6 7				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4 1.5 1.6 1.7 1.8 1.9 2 1.1 1.2 1.3 1.4 1.5 1.6 1.7 1.8 1.9 2 1 1.9 1.1 1.9 1.1 1.1 1.1 1.1	58 68 73 55 40 29 22 27 8 11 15 7 6 7 5 3 5	3 2 1 3 1 1	6 32 55 65 70 52 40 29 22 24 7 11 14 6 7 5 3 5	6 32 55 66 71 54 40 29 22 24 7 11 14 6 6 6 7 7 5 3 3 5	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7 5 6 7	4 2 2 1 1 3 1 1 1 1 1 1	15 83 112 127 115 96 54 52 32 12 18 9 6 7 5 6 7	15 87 114 131 120 99 55 53 32 32 12 18 9 6 7 5 6 7				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4 1.5 1.6 1.7 1.8 1.9 2 2.1 2.2	58 68 73 55 40 29 22 27 8 11 15 7 6 7 5 3 5	3 2 1 1 3 1 1 1	6 32 55 65 70 52 40 29 22 24 7 11 14 6 7 5 3 5	6 32 55 66 71 54 40 29 22 24 7 11 14 6 6 7 5 3 5	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7 5 6 7 3		15 83 112 127 115 96 54 52 32 12 18 9 6 7 5 6 7	15 87 114 131 120 99 55 53 32 32 32 32 12 18 9 6 7 5 6 7				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4 1.5 1.6 1.7 1.8 1.9 2 2.1 2.2 2.1 2.2	58 68 73 555 40 29 22 27 8 11 15 7 6 7 5 3 5 1	3 2 2 1 3 1 1 1 1	6 32 55 65 70 52 40 29 24 7 11 6 6 7 5 3 5	6 32 55 666 71 54 40 29 22 24 7 11 14 6 6 7 5 3 5	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7 5 6 7 3 1		15 83 112 127 115 96 54 52 32 12 18 9 6 7 5 6 7	15 87 114 131 120 99 55 53 32 12 18 9 6 7 5 6 7				
$\begin{array}{c} 0.5 \\ \hline 0.6 \\ 0.7 \\ \hline 0.8 \\ \hline 0.9 \\ 1 \\ \hline 1.1 \\ 1.2 \\ \hline 1.3 \\ \hline 1.4 \\ \hline 1.5 \\ \hline 1.6 \\ \hline 1.7 \\ \hline 1.8 \\ \hline 1.9 \\ \hline 2 \\ 2.1 \\ \hline 2.2 \\ 2.3 \\ \hline 2.4 \\ \hline \end{array}$	58 68 73 55 40 29 22 27 8 11 15 7 6 7 5 3 5 1 1	3 2 2 1 3 1 1 1 1 1	6 32 55 65 70 52 40 29 22 24 7 11 14 6 7 5 3 5	6 32 55 66 71 54 40 29 22 24 11 14 6 7 5 3 5 5	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7 5 6 7 3 1		15 83 112 127 115 96 54 52 32 32 12 18 9 6 7 5 6 7	15 87 114 131 120 99 55 53 32 32 12 18 9 6 7 5 6 7				
$\begin{array}{c} 0.5 \\ \hline 0.6 \\ 0.7 \\ \hline 0.8 \\ \hline 0.9 \\ 1 \\ \hline 1.1 \\ 1.2 \\ \hline 1.3 \\ \hline 1.4 \\ \hline 1.5 \\ \hline 1.6 \\ \hline 1.7 \\ \hline 1.8 \\ \hline 1.9 \\ 2 \\ 2.1 \\ 2.2 \\ 2.3 \\ \hline 2.4 \\ \hline 2.4 \\ \hline 2.5 \\ \end{array}$	58 68 73 55 40 29 22 27 8 11 15 7 6 7 5 3 5 1	3 2 1 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	6 32 55 65 70 52 40 29 22 24 7 11 14 6 7 5 3 5	6 32 55 66 71 54 40 29 22 24 7 11 14 6 7 5 3 5	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7 5 6 7 3 1	4 2 1 3 1 1 3 1 3 1 3 1 3 1 3 1 3 1 3 1 3 1 3 1	15 83 112 127 115 96 54 52 32 32 12 18 9 6 7 5 6 7	15 87 114 131 120 99 55 53 32 32 32 12 18 9 6 7 5 6 7				
$\begin{array}{c} 0.5 \\ \hline 0.6 \\ 0.7 \\ \hline 0.8 \\ 0.9 \\ \hline 1 \\ 1.1 \\ \hline 1.2 \\ 1.3 \\ \hline 1.4 \\ 1.5 \\ \hline 1.6 \\ \hline 1.7 \\ 1.8 \\ \hline 1.9 \\ 2 \\ 2.1 \\ 2.2 \\ 2.3 \\ 2.4 \\ 2.5 \\ \hline > 2.5 \\ \end{array}$	58 68 73 55 40 29 22 27 8 11 15 7 6 7 5 3 5 1 1 1	3 2 1 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1	6 32 55 65 70 52 40 29 22 24 7 11 14 6 7 5 3 5	6 32 55 66 71 54 40 29 22 24 7 11 14 6 6 7 5 3 5	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7 5 6 7 3 1 1 18	4 2 2 1 1 3 1 1 1 1 1 1 3 1 1 3 1 1 3 1 1 3 1 1 3 1	15 83 112 127 115 96 54 52 32 12 18 9 6 7 5 6 7	15 87 114 131 120 99 55 53 32 12 18 18 9 6 7 5 6 7				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4 1.5 1.6 1.7 1.8 1.9 2 2.1 2.2 2.3 2.4 2.5 >2.5 >2.5	58 68 73 555 40 29 22 27 8 11 15 7 6 7 5 3 5 1 1 14	3 2 2 1 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	6 32 55 65 70 52 40 29 22 24 7 11 14 6 7 5 3 5 459	6 32 55 66 71 54 40 29 22 24 7 11 14 6 7 5 3 5 463	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7 5 6 7 3 1 18 19 10 6 7 5 6 7 1 18 18 11	4 2 2 1 1 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	15 83 112 127 115 96 54 52 32 32 12 18 9 6 7 5 6 7 806	15 87 114 131 120 99 55 53 32 32 32 18 18 9 6 7 5 6 7 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 9 6 7 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8			·	
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4 1.5 1.6 1.7 1.8 1.9 2 2.1 2.2 2.3 2.4 2.5 >2.5 TOTAL >1.V	58 68 73 55 40 29 22 27 8 11 15 7 6 7 5 3 5 1 14 493 110	3 2 2 1 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	6 32 55 65 70 52 40 29 22 24 7 11 6 6 7 5 3 5 459 88	6 32 55 666 71 54 40 29 22 24 7 11 14 6 6 7 5 3 5 463 88	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7 5 6 7 3 1 18 18 6 7 3 1 18 18 148	4 2 2 1 1 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	15 83 112 127 115 96 52 32 32 12 18 9 6 7 5 6 7 5 6 7 5 6 7 5 6 7 806 120	15 87 114 131 120 99 55 53 32 32 12 18 9 6 7 5 6 7 6 7 8 6 7 8 120				
0.5 0.6 0.7 0.8 0.9 1 1.1 1.2 1.3 1.4 1.5 1.6 1.7 1.8 1.9 2.1 2.2 2.3 2.4 2.5 >2.5 TOTAL >1 V >2 V	58 68 73 55 40 29 22 27 8 11 15 7 6 7 5 3 5 1 1 14 493 110 16	3 2 2 1 3 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	6 32 55 65 70 52 40 29 22 24 7 11 14 6 7 5 3 5 459 88	6 32 55 66 71 54 40 29 22 24 7 11 14 6 7 5 3 5 463 88	15 87 118 133 122 100 55 53 33 35 13 18 19 10 6 7 5 6 7 3 1 18 864 148 22	4 2 2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	15 83 112 127 115 96 54 52 32 32 12 18 9 6 7 5 6 7 806 120	15 87 114 131 120 99 55 53 32 32 12 18 9 6 7 5 6 7 826 120				

Table 3-3: Summary of Inspection and Repair for Tubes

(1) Total Includes all DOSs returned to service (confirmed, not inspected and not confirmed with Plus Point)

_ _ _ _

Table 3-4: Summary of Largest	Voltage Growth Rates per EFPY
-------------------------------	-------------------------------

			Floy	Volte	99 Voltage	Growth	RPC	New?	2001 Cal	1999 Cal
SG_ID	Row			5 42	1 26	2 8880	SAI	Repeat	HL-13	HL-61
24	3	51		5.04	1.20	2.0007	SAL	Repeat	CL-11	CL-22
24	42	48	<u></u>	5.00	1.59	2.5480	SAL	Repeat	CL-40	CL-41
24	8	63		- 3.22	1.38	1.0653	SAL	Repeat	CL-16	CL-20
23	24	26	2H	4.31	1.40	1.9055	SAL	Repeat	CL-40	CL-29
24	7	62		3.81	1.1	1.8810	SAL	Repeat	HL-12	HL-70
24	4	45	<u>H</u>	4.06	1.35	1.8819	SAL	Repeat	HL-13	HL-61
24	5	48	H	4.4	1.69	1.7451	SAL	Repeat	HL-39	HL-55
21	5	17	2H	3.35	0.88	1.6528	SAL	Repeat	CL-37	CL-41
24	13	63	<u></u>	4.14	1.70	1.0528	SAL	Repeat	CL-37	CL-29
24	8	65		3.13	1.24	1.375	SAL	Repeat	CL-17	CL-21
24	38	47	2H	3.32	1.34	1.375	SAL	Repeat	HL-4	CL-40
23	27	59		3.81	1.94	1.2980	SAI	Repeat	CL-10	CL-22
24	36	48	<u>2H</u>	3.44	1.04	1.23	SAL	Repeat	CL-14	CL-13
21	11	27	<u>1H</u>	2.54	0.82	1.1944	SAI	Repeat	CL-37	CL-28
24	27	69	2H	2.71	1.04	1.1397	SAL	Repeat	HL-6	CL-35
24	24	84	<u>1H</u>	2.89	1.31	1.0972	SAL	Repeat	CL-37	CL-21
24	44	45	2H	2	0.49	1.0480		Repeat	CL-40	CL-22
21	37	45	2H	1.96	0.5	1.0139	SAL	Repeat	CL-40	CL-20
24	29	35	1H	2.74	1.28	0.0444	- <u>5</u> Ai	Repeat	CL-40	CL-23
21	31	51	1H	1.84	0.48	0.9444	SAL	Repeat	HL-30	HL-62
23	5	5	3H	2.2	0.84	0.9444	BAI	New	HL-6	CC-32
24	18	76	2H	1.73	0.39	0.9300	SAL	Repeat	CL-37	CL-28
24	38	60	2H	3.08	1.93	0.7980	- SAI	Repeat	HL-9	CL-23
24	40	58	3H	1.96	0.89	0.7431		Repeat	CL-17	CL-22
24	35	45	IH	1.35	0.30	0.0873		Repeat	HL-43	HL-56
24	4	68	<u>2H</u>	1.97	1.01	0.0007	SAL	Repeat	HL-2	CL-26
24	16	57	2H	2.2	1.25	0.0397	5/1	Repeat	CL-17	CL-15
21	27	33	1H	1.36	0.43	0.0438	<u> </u>	Repeat	HL-2	CL-26
24	16	55	2H	1.26	0.33	0.6458		Repeat	HL-5	CL-31
24	11	77	2H	1.82	0.89	0.6458		Repeat	CL-10	CL-58
24	12	38	IH	1.9	0.97	0.6380		Repeat	HL-5	CL-37
21	15.	92	IH	1.29	0.37	0.0389		Repeat	CL-37	CL-19
24	38	43	2H	1.04	0.72	0.6181		Repeat	CL-7	CL-12
21	7	33	<u>1H</u>	1.88	0.99	0.6181	SAL	Repeat	CL-37	CL-41
23	6	54	IH	2.10	0.77	0.6181		Repeat	CL-37	CL-17
24	38	32		1.00	0.77	0.6111		Repeat	HL-13	HL-61
24	2	47		1.51	1.02	0.5072		Repeat	CL-5	CL-21
22	38	40		1.94	1.00	0.5764	-	Repeat	HL-4	CL-46
22	22	67	2H	1.84	0.95	0.5764	- 	Repeat	HL-14	HL-61
24	3	50		1.08	0.03	0.5704	+	New	HL-1	CC-42
24	7	54	2H	1.03	0.21	0.5604		Repeat	HL-14	HL-61
24	1	52		1.44	0.02	0.5094		Repeat	CL-16	CL-7
21	37	24		1.44	0.00	0.5417	+	Repeat	CL-40	CL-29
24	7	62	2H	1.37	1 1 22	0.5417	SAL	Repeat	HL-5	CL-33
24	19	84	2H		0.20	0.5778		Repeat	CL-15	CL-9
23	9	23		1.04	0.46	0.5278		Repeat	HL-9	CL-23
24	40	59	2H	1.22	1 40	0.5278	SAI	Repeat	CL-17	CL-2
24	31	45		2.23	0.70	0.5278	+	Repeat	HL-15	HL-56
24	2	59	2H	1.54	0.79	0.5208		Repeat	HL-13	HL-55
21	2	28		1.37	0.64	0.3009	+	Reneat	CL-11	CL-58
24	6	39		1.24	0.52			Repeat	HL-13	HL-61
24	5	50	I IH	1.92	1.2	0.5				

Table 3-5: Voltage and Growth Distribution by TSP

Tuba		Steam	Generator	2-1		Tube		Steam	Generator	2-2	
Support Plate	No. of Indications	Maximum Voltage	Average Voltage	Maximum Growth	Average Growth	Support Plate	No. of Indications	Maximum Voltage	Average Voltage	Maximum Growth	Average Growth
IH	112	2.54	0.63	1.19	0.15	١H	41	1.94	0.57	0.60	0.08
2Н	33	3.35	0.60	1.72	0.15	2H	47	1.84	0.58	0.58	0.10
3H	8	0.95	0.63	0.25	0.13	3H	10	0.93	0.47	0.37	0.11
	3	0.51	0.38	0.11	0.03	4H	3	0.69	0.49	0.03	-0.01
5H	8	0.74	0.60	0.14	0.03	5H	1	0.63	0.63	-0.09	-0.09
6H	1	0.32	0.32	0.16	0.16	6H	1	0.33	0.33	0.05	0.05
7H	0					7H	0				
CL	2	0.60	0.56	0.10	-0.01	CL	5	0.69	0.39	0.04	0.01
All Inds	167	3.35	0.61	1.72	0.14	All Inds	108	1.94	0.55	0.60	0.08
Tube		Steam	1 Generator	· 2-3		Tube		Steam	Generator	2-4	
Support Plate	No. of Indications	Maximum Voltage	Average Voltage	Maximum Growth	Average Growth	Support Plate	No. of Indications	Maximum Voltage	Average Voltage	Maximum Growth	Average Growth
ін	54	3.81	0.66	1.30	0.10	1H	182	5.42	0.85	2.89	0.23
2H	26	4.31	0.71	1.97	0.17	2H	245	5.06	0.83	2.55	0.20
3H	7	2.20	0.82	0.94	0.22	3Н	51	1.96	0.68	0.74	0.12
4H	2	0.46	0.38	0.15	0.07	4H	11	0.94	0.49	0.15	0.03
5H	2	0.62	0.51	-0.05	-0.08	5H	1	0.49	0.49	-0.03	-0.03
6H	2	0.22	0.22	0.00	-0.05	6H	0	ļ	ļ	ļ	
7H	0					7H	• 0	ļ	ļ	<u> </u>	
CL	3	0.53	0.35	0.22	0.06	CL	3	0.64	0.37	0.20	0.08
All Inds	96	4.31	0.66	1.97	0.12	All Inds	493	5.42	0.81	2.89	0.20
		Composi	ite of All F	our SGs			Tuba		Steam Ge	nerator 2-4	
Tube Support Plate	No. of Indications	Maximum Voltage	Average Voltage	Maximum Growth	Average Growth		Support Plate	Max Growth BOC <=1	Avg Growth BOC <=1	Max Growth BOC > 1	Avg Growth BOC > 1
ін	389	5.42	0.73	2.89	0.17		1H	1.54	0.15	2.89	1.18
2H	351	5.06	0.76	2.55	0.18	1	2H	1.05	0.17	2.55	0.49
ЗН	76	2.20	0.66	0.94	0.13		ЗН	0.74	0.13	-0.05	-0.06
4H	19	0.94	0.46	0.15	0.03		4H	0.15	0.03	<u> </u>	<u> </u>
5H	12	0.74	0.58	0.14	0.00		5H	-0.03	-0.03	<u> </u>	<u> </u>
6H	4	0.33	0.27	0.16	0.03		<u>6H</u>		ļ		<u> </u>
7H	0				<u> </u>		7H		<u> </u>		<u> </u>
CL	13	0.69	0.40	0.22	0.04		CL	0.20	0.08		<u> </u>
All Inds	864	5.42	0.72	2.89	0.16	j	All Inds	1.54	0.15	2.89	0.70
	-11										

Growth units are volts/EFPY

86-5013685-01 Page 16 of 63

	SG 1		SG 2		SG 3		SG 4		TOTAI	
Delta Volts	No of Obs	CPDF	No. of Obs.	CPDF						
0.7	<u>NO. 01 COS.</u>	0.000	1	0.009	0	0.000	0	0.000	1	0.001
-0.7	0	0.000	0	0.009	0	0.000	0	0.000	0	0.001
-0.6	0	0.000	0	0.009	0	0.000	0	0.000	0	0.001
-0.5	0	0.000	0	0.009	0	0.000	0	0.000	0	0.001
-0.4	0	0.000	0	0.009	0	0.000	0	0.000	0	0.001
-0.3	1	0.000	0	0.009	0	0.000	0	0.000	1	0.002
-0.2	1	0.000	4	0.047	4	0.042	5	0.010	17	0.022
	19	0.030	20	0.234	27	0.323	41	0.094	106	0.146
	10	0.130	49	0.692	28	0.615	152	0.406	296	0.491
0.1	41	0.555	18	0.860	19	0.813	144	0.701	222	0.749
0.2	10	0.704	7	0.925	7	0.885	65	0.834	98	0.864
0.3	19	0.022		0.953	4	0.927	28	0.891	39	0.909
0.4	4	0.922	3	0.981	2	0.948	19	0.930	28	0.942
0.5		0.940	2	1.000	1	0.958	8	0.947	13	0.957
0.0	2	0.936		1.000	1	0.969	9	0.965	13	0.972
0.7		0.976		1.000	0	0.969	2	0.969	2	0.974
0.8	0	0.976	<u> </u>	1 000	0	0.969	0	0.969	0	0.974
0.9		0.970	0	1.000	1	0.979	1	0.971	3	0.978
	1	0.962	0	1.000	0	0.979	3	0.977	4	0.983
	1	0.900	0	1 000	0	0.979	1	0.980	2	0.985
1.2		0.994	0	1.000	1	0.990	1	0.982	2	0.987
1.3	0	0.994	0	1.000	0	0.990	1	0.984	1	0.988
1.4	0	0.004	0	1.000	0	0.990	0	0.984	0	0.988
1.5	0	0.994	0	1.000	0	0.990	1	0.986	1	0.990
1.0	0	0.994	0	1.000	0	0.990	1	0.988	1	0.991
1./	0	1 000	0	1.000	0	0.990	1	0.990	2	0.993
1.8		1.000	0	1.000	0	0.990	2	0.994	2	0.995
1.9	0	1 000	0	1.000	1	1.000	0	0.994	1	0.997
2	0	1 000	0	1.000	0	1.000	0	0.994	0	0.997
2.1	0	1 000	0	1.000	0	1.000	0	0.994	0	0.997
2.2	0	1 000	0	1.000	0	1.000	0	0.994	0	0.997
2.5	0	1.000	0	1.000	0	1.000	0	0.994	0 ·	0.997
2.4	0	1.000	0	1.000	0	1.000	0	0.994	0	0.997
2.5	0	1.000	0	1.000	0	1.000	2	0.998	2	0.999
2.0	0	1.000	0	1.000	0	1.000	0	0.998	0	0.999
2.1		1,000	0	1.000	0	1.000	0	0.998	0	0.999
2.0		1,000	0	1.000	0	1.000	1	1.000	1	1.000
Total	167	NA	107	NA	96	NA	488	NA	858	NA

 Table 3-6: Summary of Voltage Growth per EFPY

Table 3-7: Voltage Dependent Growth

BOC-10 Voltage ≤ 1 V	Volt	
		-

Delta	SG 1		SG 2		SG 3		SG 4		TOTAI	
Volts	No. of Obs.	CPDF								
-0.7	0	0.000	0	0.000	0	0.000	0	0.000	0	0.000
-0.6	0	0.000	0	0.000	0	0.000	0	0.000	0	0.000
-0.5	0	0.000	0	0.000	0	0.000	0	0.000	0	0.000
-0.4	0	0.000	0	0.000	0	0.000	0	0.000	0	0.000
-0.3	0	0.000	0	0.000	0	0.000	0	0.000	0	0.000
-0.2	1	0.006	0	0.000	0	0.000	0	0.000	1	0.001
-0.1	4	0.030	3	0.029	3	0.033	5	0.011	15	0.020
0	18	0.139	20	0.223	27	0.330	37	0.094	102	0.147
0.1	65	0.533	49	0.699	28	0.637	149	0.428	291	0.508
0.2	41	0.782	18	0.874	19	0.846	137	0.735	215	0.775
0.3	19	0.897	7	0.942	6	0.912	62	0.874	94	0.892
0.4	4	0.921	3	0.971	4	0.956	24	0.928	35	0.935
0.5	4	0.945	3	1.000	2	0.978	15	0.962	24	0.965
0.6	2	0.958	0	1.000	1	0.989	6	0.975	9	0.976
0.7	3	0.976	0	1.000	0	0.989	7	0.991	10	0.989
0.8	0	0.976	0	1.000	0	0.989	1	0.993	1	0.990
0.9	0	0.976	0	1.000	0	0.989	0	0.993	0	0.990
1	1	0.982	0	1.000	1	1.000	1	0.996	3	0.994
1.1	1	0.988	0	1.000	0	1.000	1	0.998	2	0.996
1.2	1	0.994	0	1.000	0	1.000	0	0.998	1	0.998
1.3	0	0.994	0	1.000	0	1.000	0	0.998	0	0.998
1.4	0	0.994	0	1.000	0	1.000	0	0.998	0	0.998
1.5	0	0.994	0	1.000	0	1.000	0	0.998	0	0.998
1.6	0	0.994	0	1.000	0	1.000	1	1.000	1	0.999
1.7	0	0.994	0	1.000	0	1.000	0	1.000	0	0.999
1.8	1	1.000	0	1.000	0	1.000	0	1.000	1	1.000
1.9	0	1.000	0	1.000	0	1.000	0	1.000	0	1.000
2	0	1.000	0	1.000	0	1.000	0	1.000	0	1.000
2.1	0	1.000	0	1.000	0	1.000	0	1.000	0	1.000
2.2	0	1.000	0	1.000	0	1.000	0	1.000	0	1.000
2.3	0	1.000	0	1.000	0	1.000	0	1.000	0	1.000
2.4	0	1.000	0	1.000	0	1.000	0	1.000	0	1.000
2.5	0	1.000	0	1.000	0	1.000	0	1.000	0	1.000
2.6	0	1.000	0	1.000	0	1.000	0	1.000	0	1.000
2.7	0	1.000	0	1.000	0	1.000	0	1.000	0	1.000
2.8	0	1.000	0	1.000	0	1.000	0	1.000	0	1.000
2.9	0	1.000	0	1.000	0	1.000	0	1.000	0	1.000
Total	165	NA	103	NA	91	NA	446	NA	805	NA

Table 3-8: Voltage Dependent Growth

	96.1		SG 2		SG 3	T	SG 4		TOTAI	
Delta Volta		CDDE	No of Obs	CPDF	No of Obs	CPDF	No. of Obs.	CPDF	No. of Obs.	CPDF
v 0113	INO. OI UDS.		1	0.250	0	0.000	0	0.000	1	0.019
-0.7	0	0.000	1	0.250	0	0.000	0	0.000	0	0.019
-0.6	0	0.000	0	0.250	0	0.000	0	0.000	0	0.019
-0.5	0	0.000	0	0.250	0	0.000	0	0.000	0	0.019
-0.4	0	0.000	0	0.250	0	0.000	0	0.000	0	0.019
-0.3	0	0.000	0	0.250	0	0.000	0	0.000	0	0.019
-0.2	0	0.000	1	0.200	1	0.200	0	0.000	2	0.057
-0.1	0	0.000	1	0.500	0	0.200	4	0.095	4	0.132
0	0	0.000	0	0.500	0	0.200	3	0.167	5	0.226
0.1	2	1.000	0	0.500	0	0.200	7	0.333	7	0.358
0.2	0	1.000	0	0.500	1	0.200	3	0.405	4	0.434
0.3	0	1.000	0	0.500		0.400	4	0.500	4	0.509
0.4	0	1.000	0	0.500	0	0.400	4	0.595	4	0.585
0.5	0	1.000	0	1.000	0	0.400	2	0.643	4	0.660
0.6	0	1.000	2	1.000	1	0.400	2	0.690	3	0.717
0.7	0	1.000	0	1.000		0.000	1	0.714	1	0.736
0.8	0	1.000	0	1.000	0	0.000	0	0.714	0	0.736
0.9	0	1.000	0	1.000	0	0.600	0	0.714	0	0.736
1	0	1.000	0	1.000	0	0.600	2	0.762	2	0.774
1.1	0	1.000	0	1.000	0	0.600	1	0.786	1	0.792
1.2	0	1.000	0	1.000	1	0.000	1	0.810	2	0.830
1.3	0	1.000	0	1.000		0.000	1	0.833	1	0.849
1.4	0	1.000	0	1.000	0	0.000	0	0.833	0	0.849
1.5	0	1.000	0	1.000	0	0.800	0	0.833	0	0.849
1.6	0	1.000	0	1.000	0	0.800	1	0.857	1	0.868
1.7	0	1.000	0	1.000	0	0.800	1	0.881	1	0.887
1.8	0	1.000	0	1.000	0	0.800	2	0.929	2	0.925
1.9	0	1.000	0	1.000	1	1.000	0	0.929	1	0.943
2	0	1.000		1.000		1.000	0	0.929	0	0.943
2.1		1.000		1.000		1.000	0	0.929	0	0.943
2.2	<u> </u>	1.000		1.000		1.000	0	0.929	0	0.943
2.3	0	1.000	0	1.000	0	1.000	0	0.929	0	0.943
2.4	0	1.000		1.000	0	1.000	0	0.929	0	0.943
2.5	0	1.000		1.000		1,000	2	0.976	2	0.981
2.6	0	1.000		1.000		1 000	0	0.976	0	0.981
2.7	0	1.000		1.000		1 000	0	0.976	0	0.981
2.8	0	1.000		1.000	ο	1.000	1	1.000	1	1.000
2.9	0	1.000		1.000		NTA	42	NA	53	NA
Total	2	NA	4	NA	5	INA	42			

BOC-10 Voltage > 1 Volt

Table 3-9: Re-tested DOSs ≥ 1.5	Volts that Fa	ailed the Probe	Wear Check
--------------------------------------	---------------	-----------------	------------

.

r	1						Cal	ARC	
SG	Row	Col	Ind	Elev	Volts	Probe	No.	Out 2R10	% Diff
		54	229	1H	1.61	720PR	12	Yes	
	3	54	DOS	1H	1.27	720PR	39		-26.8
	3	17	RSS	2H	3.24	720PR	13	Yes	
	5	17		2H	3.35	720PR	39		3.3
	21	51	RSS	1H	1.58	720PR	8	Yes	
21	21	51	RSS	1H	1.82	720PR	32	Yes	
	31	51			1.84	720PR	40		14.1
	31	45	RSS	2H	1.75	720PR	21	Yes	
	27	45	RSS	2H	1.89	720PR	32	Yes	
	37	45	DOS	2H	1.96	720PR	40		10.7
			RSS	3H	2.26	720PR	13	Yes	
	3	5	DOS		2.2	720PR	30		-2.7
23	5	54	RSS	1H	2.13	720PR	13	Yes	
	6	54	DOS	1H	2.16	720PR	37		1.4
		60	RSS	İH	1.73	720PR	11	Yes	
	3	60	DOS	1H	1.64	720PR	43		-5.5
	3	68	RSS	2H	2.08	720PR	11	Yes	
	4	68	DOS	2H	1.97	720PR	43		-5.6
	4	62	RSS	1H	3.94	720PR	3	Yes	
	7	62	DOS	1H	3.81	720PR	40		-3.4
	8	63	RSS	1H	4.95	720PR	4	Yes	
	8	63	DOS	1H	5.22	720PR	40		5.2
	8	65	RSS	1H	2.77	720PR	4	Yes	
	8	65	DOS	1H	3.13	720PR	37		11.5
	13	63	RSS	1H	4.12	720PR	3	Yes	
	13	63	DOS	1H	4.14	720PR	37		0.5
	13	66	RSS	2H	1.69	720PR	3	Yes	
	13	66	DOS	2H	1.71	720PR	37		1.2
	23	42	RSS	2H	1.59	720PR	6	Yes	
	23	42	DOS	2H	1.54	720PR	37		-3.2
24	24	38	RSS	1H	1.74	720PR	6	Yes	4.2
24	24	38	DOS	1H	1.67	720PR	40	Vec	-4.2
	24	73	RSS	2H	1.74	720PR	4	Ies	1.8
	24	73	DOS	2H	1.77	720PR	3/	Vac	1.0
	27	69	RSS	2H	2.4	720PR	27	1 5	11.4
	27	69	DOS	2H	2.71	720PR	15	Vec	
	28	29	RSS	2H	1.5	720PR	15	1 65	-14
	28	29	DOS	<u>2H</u>	1.48	720PR	40	Vec	-1.4
	29	35	RSS	<u>1H</u>	2.82	720PR	15	105	-29
	29	35	DOS	<u>1H</u>	2.74	720PR	40	Vec	-2.9
	38	32	RSS		1.59	720PK	27	- 103	4.2
	38	32	DOS_		1.00	720FK	16	Yes	
	38	43	KSS ROOM		1.01	72000			1.8
	38	43	DOS_	2H	1.04	72000	7	Yes	
	38	60	RSS RSS	<u>2H</u>	2.93	720FR	37		4.2
	38	60	L DOS		1.08	72000	16	Yes	
	44	45			1.0	72000	37		10.0
	44	45	DOS	2H		120FK			

	Row	Col	Ind	Elev	Volts	Probe	Cal	ARC
30								Out 99?
	10	8	DOS	1H	0.74	720PR	CL-10	Out
	10	85	DOS	1H	0.5	720PR	HL-5	Out
	10	30	DOS	1H	0.51	720PR	CL-6	Out
21	10	18	DOS	2H	0.64	720PR	CL-11	Out
	40	51	DOS	1H	0.69	720PR	HL-7	Out
		54	DOS	1H	0.66	720PR	HL-7	Out
	7	82	DOS	1H	1.1	720PR	HL-3	Out
	7	73	DOS	2H	0.92	720PR	HL-3	Out
	15	73	DOS	1H	0.83	720PR	HL-3	Out
	17	81	DOS	2H	0.83	720PR	HL-3	Out
	6	43	DOS	1H	0.82	720PR	CL-22	Out
22	19	78	DOS	2H	0.69	720PR	HL-3	Out
	5	88	DOS	3C	0.69	720PR	CL-28	Out
	3	77	DOS	5H	0.63	720PR	HL-10	Out
	9	9	DOS	1H	0.53	720PR	CL-11	Out
	26	49	DOS	1H	0.51	720PR	CL-1	Out
	18	21	DOS	1H	0.5	720PR	CL-11	Out
	4	32	DOS	2H	0.69	720PR	HL-15	Out
	17	30	DOS	2H	0.55	720PR	CL-15	Out
	17	34	DOS	2H	0.62	720PR	CL-15	Out
23	24	16	DOS	1H	0.55	720PR	CL-16	Out
	27	81	DOS	2H	0.64	720PR	HL-I	Out
	39	45	DOS	1H	1.19	720PR	CL-3	Out
	44	42	DOS	3H	0.71	720PR	CL-4	Out
	3	55	DOS	2H	0.79	720PR	<u>HL-16</u>	Out
	4	46	DOS	1H	0.56	720PR	HL-46	Out
	4	50	DOS	1H	1.05	720PR	HL-13	Out
	4	60	DOS	<u>1H</u>	0.5	720PR	HL-10	Out
	6	54	DOS	1H	0.63	720PR	HL-2	Out
	6	56	DOS	<u>1H</u>	0.71	720PR	HL-2	Out
	7	54	DOS	<u>2H</u>	1.03	720PR		Out
	7	58	DOS		$\frac{0.53}{0.64}$	720PR		Out
24	7	70	DOS	2H	0.64	720PK		Out
24	8	69	DOS		0.6	720PR		
	8	69	DOS	<u>2H</u>	0.63	720PR		Out
	9	57	DOS	$\frac{2H}{1}$	1.5	720PR		Out
	9	67	DOS	<u>2H</u>	0.50	720PK		
	11	66	DOS		0.61	720PK		
	11	68	DOS_		0.52	720PR		Out
1	12	60	DOS	$\frac{2H}{2H}$	0.01	720PR		Out
	12	83	DOS	<u>3H</u>	0.5	720PR		Out
	13	49	DOS	<u> 1H</u>	0.51	120PR	U9	

Table 3-10: New 2R10 DOSs >=0.5 Volts In Tubes Inspected With A Worn Probe In 2R9

SG	Row	Col	Ind	Elev	Volts	Probe	Cal	ARC Out 99?
							OT 10	0.4
	14	38	DOS	3H	0.64	720PR	CL-10	Out
	16	37	DOS	1H	0.58	720PR	CL-6	Out
	16	61	DOS	2H	0.74	720PR	<u>HL-4</u>	Out
	16	62	DOS	2H	0.5	720PR	HL-4	Out
	16	68	DOS	3H	0.85	720PR	HL-4	Out
	$-\frac{10}{17}$	25	DOS	1H	0.81	720PR	CL-5	Out
	17	68	DOS	2H	0.79	720PR	HL-3	Out
	18	68	DOS	2H	0.72	720PR	HL-4	Out
	18	71	DOS	2H	0.57	720PR	HL-4	Out
	18	76	DOS	2H	1.73	720PR	HL-6	Out
24	$\frac{10}{20}$	64	DOS	1H	0.81	720PR	HL-4	Out
	22	47	DOS	2H	0.73	720PR	CL-11	Out
	23	64	DOS	2H	0.62	720PR	HL-3	Out
	25	64	DOS	4H	0.53	720PR	HL-4	Out
	26	25	DOS	1H	0.8	720PR	CL-13	Out
	28	22	DOS	2H	0.64	720PR	CL-13	Out
	28	54	DOS	1H	1.1	720PR	HL-9	Out
ļ	29	47	DOS	2H	0.81	720PR	CL-17	Out
	35	28	DOS	1H	0.65	720PR	CL-12	Out
	35	55	DOS	2H	0.57	720PR	HL-10	Out

Table 3-11: Summary of New DOS Indications Sorted by Category

	2R10 DOSs (Total)	New 2R10 Not Detected in 2R9	New 2R10 Ind. In Tubes Insp. w/ Worn Probe in 2R9	New 2R10 Ind. In Tubes Insp. w/ Good Probe in 2R9	New 2R10 Ind. ≥0.5 Volts	New 2R10 Ind. ≥0.5 Volts in Tubes Insp. w/ Worn Probe in 2R9
2-1	167	71	18	53	29	6
2-2	107	52	35	17	17	11
2-3	96	46	23	23	19	7
2-4	492	193	93	100	82	38
Tot.	862	362	169	193	147	62

	Worn Probe In 2R9	Good Probe In 2R9
Number of Inspections In 2R9	5775	8290
New Indications	169	193
Percentage w/ New Indications	2.9%	2.3%
New Indications >0.5V	62	85
Percentage w/ New Indications ≥0.5V	1.1%	1.0%

Table 3-12: Percentage of Tubes With New Indications

Table 3-13: Average Growth Rates for Cycle 10

SG	No of Inds In Growth Dist.	Average BOC-10 Voltage	Average Voltage Growth	Average Growth per EFPY	Average Percent Growth for Cycle 10	Average Percent Growth per EFPY
SG 2-1	167	0.42	0.20	0.14	47.8%	33.2%
SG 2-2	107	0.43	0.12	0.08	27.4%	19.0%
SG 2-3	96	0.48	0.18	0.12	36.7%	25.5%
SG 2-4	488	0.53	0.28	0.20	54.0%	37.5%
Total	858	0.49	0.24	0.16	48.1%	33.4%

Table 3-14: NDE Uncertainty Distributions

Analyst Uncertainty

Percent	Cumulative Brobability		
Variation	Probability		
-40.0%	0.00005		
-38.0%	0.00011		
-36.0%	0.00024		
-34.0%	0.00048		
-32.0%	0.00095		
-30.0%	0.00179		
-28.0%	0.00328		
~26.0%	0.00580		
-24.0%	0.00990		
-22.0%	0.01634		
-20.0%	0.02608		
-18.0%	0.04027		
-16.0%	0.06016		
-14.0%	0.08704		
-12.0%	0.12200		
-10.0%	0.16581		
-8.0%	0.21867		
-6.0%	0.28011		
-4.0%	0.34888		
-2.0%	0.42302		
0.0%	0.50000		
2.0%	0.57698		
4.0%	0.65112		
6.0%	0.71989		
8.0%	0.78133		
10.0%	0.83419		
12.0%	0.87800		
14.0%	0.91296		
16.0%	0.93984		
18.0%	0.95973		
20.0%	0.97392		
22.0%	0.98366		
24.0%	0.99010		
26.0%	0.99420		
28.0%	0.99672		
30.0%	0.99821		
32.0%	0.99905		
34.0%	0.99952		
36.0%	0.99976		
38.0%	0.99989		
40.0%	0.99995		
Std Deviation = 10.3% Mean = 0.0% No Cutoff			

Percent Variation	Cumulative Probability			
	0.00000			
45.0%	0.00000			
-15.0%	0.01000			
-14.0%	0.02275			
-13.0%	0.03703			
-12.0%	0.05804			
-11.0%	0.03656			
-10.0%	0.00037			
-9.0%	0.13655			
-8.0%	0.12055			
-7.0%	0.15600			
-6.0%	0.19500			
-5.0%	0.23753			
-4.0%	0.28385			
-3.0%	0.33412			
-2.0%	0.38755			
-1.0%	0.44320			
0.0%	0.50000			
1.0%	0.55680			
2.0%	0.61245			
3.0%	0.66588			
4.0%	0.71615			
5.0%	0.76247			
6.0%	0.80432			
7.0%	0.84134			
8.0%	0.87345			
9.0%	0.90073			
10.0%	0.92344			
11.0%	0.94196			
12.0%	0.95676			
13.0%	0.96835			
14.0%	0.97725			
15.0%	0.98394			
>15.0%	1.00000			
Std Devia Mean Cutoff =	Std Deviation = 7.0% Mean = 0.0%			

Acquisition Uncertainty

Figure 3-1





0

0.1

0.3

0.5

0.7

0.9

1.1

1.5

1.9

Bobbin Voltage

2.7

3.1

3.3

3.5

3.7

3.9

4.1

4.3

4.5

2.9

SG 3

DSG 4

1.7

_

Ь

Figure 3-3



SG 1 & SG 2 Repaired Tube Voltage Distributions

Figure 3-4

SG 3 & SG 4 Repaired Tube Voltage Distributions



Figure 3-5



SG 1 & SG 2 Voltage Distributions of All DOS Indications Returned to Service

Figure 3-6

SG 3 & SG 4 Voltage Distributions of All DOS Indications Returned to Service


Distribution of Indications by TSP Location















Figure 3-11









Figure 3-13





Deplugged vs In-Service Growth Comparison SG 21

Deplugged vs. In-Service Growth Comparison SG 22





Deplugged vs. In-Service Growth Comparison SG 23

Deplugged vs In-Service Growth Comparison SG 24





Deplugged vs. In-Service Growth Comparison All SGs

Figure 3-19

DCPP Growth Rate (CPDF) Curves Compared with the Industry-Bounding Curve



Voltage Change



Probe Wear Voltage Comparison

Figure 3-21

NDE Uncertainty Distributions





Database Applied for Leak and Burst Correlations 4.0

The leak and burst correlations utilized in the analyses presented in this report are based on the Addendum 3 1999 Updated Database (Ref. 13) and Addendum 2 Updated Database (Ref. 20) for the voltage-based repair criteria for 7/8 inch tubing. The leak rate correlations used were developed for a MSLB delta P of 2560 psi. The correlations have been developed specifically for the evaluation of ODSCC indications at TSP locations in Model 51 steam generators and relate Bobbin voltage amplitudes, free span burst pressure, probability of leakage and associated leak rates to assess end of next cycle structural integrity.

Conditional Probability of Burst 4.1

For the burst pressure versus voltage correlation, the database contained in Ref. 13 meets all GL 95-05 requirements and was used in these calculations. Material properties were also considered as part of the calculations and were obtained from Ref. 6. The FTI Monte Carlo computer code was utilized to predict the POB at the end of cycle 11 based upon the input parameters shown in Table 4-1 (from Ref. 13, Table 6-6). This simulation follows the statistical methods presented in Ref. 6.

Table 4-1: Tube	Burst Pressure	vs. Bobbin	Amplitude	Correlation
-----------------	----------------	------------	-----------	-------------

Parameter	Database	Adjusted Input ⁽¹⁾
<u><u><u></u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u><u></u></u>	7.57661	8.261536
<u> </u>	-2.39816	-2.61495
r^2	82.3%	82.3%
<u></u>	0.82389	0.89837
N (data pairs)	91	91
n Value for α_2	1.60x10 ⁻³⁵	1.60x10 ⁻³⁵
Reference σ_{ℓ}	68.78	75

$$P_{B} = \alpha_{0} + \alpha_{1} \log(Volts)$$

Note:

(1) The slope and intercept coefficients and the standard error value from Ref. 13 were adjusted for a reference flow stress of 75.0 ksi by multiplying those input terms by 1.0904.

4.2 Conditional Leak Rate

Ref. 20 presents the results of the regression analysis for the voltage-dependent leak rate correlation using the updated leak rate database for 7/8" tubes mentioned above. It is shown that the one-sided p-value for the slope parameter in the voltage dependent leak rate correlation is 3.5%, which is below the 5% threshold for an acceptable correlation specified in Generic Letter 95-05.

The methodology used in the calculation of these parameters is consistent with the NRC criteria in Ref. 2. The POL and leak rate correlation parameters used in this analysis are shown in Tables 4-2 and 4-3. The inputs are taken directly from Ref. 13 Table 6-7 and Ref. 20 Table 6-7, respectively.

Parameter	Database
β ₁	-4.31236
β ₂	4.21125
$V_{11}^{(1)}$	0.67152
V ₁₂	-0.59145
V ₂₂	0.59172
DoF ⁽²⁾	137
Deviance	78.81
Pearson SD	75.0%

Table 4-2: 7/8" Tube Probability of Leak Correlation (2560 psi) $Pr(Leak) = \{1 + e^{-[\beta 1 + \beta 2 \log(V)]}\}^{-1}$

Notes:

(1) Parameters V_{ij} are elements of the covariance matrix of the coefficients, β_i , of the regression equation.

(2) Degrees of freedom.

making 4 2. Look Doto	Databasa fa	7/8" Tube	ARC Ann	lications
Table 4-3: Leak Rate	Database Ioi	·//ð~ lude	акс Арр	ncations

$$Q = 10^{(b_3 + b_4 \times log(volts))}$$

Parameter
Database

Intercept, b_3
-0.526882

Slope, b_4
0.987179

Index of Deter, r²
11.7%

Residuals, σ_{Error} (b_5)
0.808109

Data Pairs, N
29

Mean of Log(V)
1.15437

SS of Log(V)
2.39739

n Value for b
3.5%

p Value for b₄

3.5%

Bobbin Voltage Distributions 5.0

This section describes the prediction of the EOC voltage distribution used for evaluating tube leakage and burst probabilities at the end of the operating period.

Probability of Detection 5.1

The number of bobbin indications used to predict the tube leak rate and burst probability is obtained by adjusting the number of reported indications to account for the detection capability of the bobbin coil. This is accomplished by using a POD factor. The calculation of the bobbin voltage distribution is a net total number of indications returned to service, defined as:

$$N_{BOC11} = \frac{N_{EOC10}}{POD} - N_{repaired} + N_{deplugged}$$

where:

510.		
N _{BOC11}	=	Number of bobbin indications being returned to service for the next operating cycle
N_{EOC10}	=	Number of bobbin indications reported in the current inspection
POD	=	Probability of Detection
Nrepaired	=	Number of bobbin indications repaired after the last cycle
Ndeplugged	=	Number of previously plugged indications which are deplugged after the last cycle and are returned to service

Note that no tubes were deplugged and subsequently returned to service this outage. Therefore, N_{deplugged} is equal to zero.

The NRC generic letter (Ref. 2) requires the application of a constant POD equal to 0.6 to define the BOC distribution for the EOC voltage projections. The operating cycle length is required for proper voltage projection calculations: Cycle 10 (actual) = 1.44 EFPY and Cycle 11 (estimated)=1.61 EFPY (Ref. 23).

Probability of Prior Cycle Detection 5.2

For voltage-based repair criteria applications, the important indications are those that could significantly contribute to EOC leakage or burst probability. These significant indications can be expected to be detected by bobbin and confirmed by the plus point inspection. Thus, the population of interest for POD assessments is the EOC RPC confirmed indications that were or were not detected at the prior inspection. The probability of prior cycle detection (POPCD) is defined as follows:

POPCD EOC-9	EOC-10 RPC confirmed and detected at EOC-9	+	EOC-9 RPC confirmed and repaired at EOC-9
	(NUMERATOR)	+	New EOC-10 RPC confirmed indications

The POPCD evaluation for the 1999 EOC-9 inspection data is summarized in Table 5-1 and Figure 5-1. The predicted POPCD values based on both RPC confirmed indications only and RPC confirmed and not inspected indications approach 0.9 at about 1.0 volts and reach unity at approximately 2.0 volts. Although the Diablo Canyon POPCD distribution has a limited number of data points, it illustrates that using the EPRI generic POPCD distribution is conservative. The EPRI POPCD distribution is in Reference 22. The EPRI generic POPCD was used in calculating the BOC-11 voltage distribution. This POPCD evaluation supports a voltage dependent POD.

5.3 Calculation of BOC-11 Voltage Distributions

First, the initial condition of the steam generator at BOC-11 is determined from ECT inspection data. The BOC-11 distribution is calculated by dividing the as-found condition of the SG by the probability of detection (POD), and subtracting the number of repaired tubes. For this analysis, the BOC-11 distributions for each SG were calculated using two POD functions: 0.6 and probability of prior cycle detection (POPCD) from EPRI (Ref. 22). Table 5-2, Table 5-3, Table 5-4, and Table 5-5 summarize the as-found distribution, repaired tubes, and the two calculated BOC-11 distributions for SG 2-1, SG 2-2, SG 2-3, and SG 2-4 respectively. The distributions using POPCD are for information only.

5.4 Predicted EOC-11 Voltage Distributions

Once the BOC-11 voltage distribution has been determined, the EOC-11 voltage distributions are obtained by applying a Monte Carlo sampling process to the BOC-11 voltages. This process randomly assigns uncertainty values and a growth value to each of the BOC-11 indications. The EOC-11 voltage distributions are used to calculate a leak rate and probability of tube burst. Table 5-6 summarizes the BOC and growth voltage distributions used for the leak rate and burst simulations.

Table 5-7 and Table 5-8 summarize the EOC-11 voltage distributions for 0.6 POD and POPCD, respectively; using composite normal growth distributions for SG 2-1, SG 2-2, and SG 2-3, SG 2-4 specific normal growth distribution for SG 2-4, composite voltage dependent growth distributions for SG 2-3, and SG 2-4 specific voltage dependent growth distributions for SG 2-3, and SG 2-4 specific voltage dependent growth distributions for SG 2-4. Figure 5-6, Figure 5-7, Figure 5-8, Figure 5-9, Figure 5-10, and Figure 5-11 illustrate the calculated BOC-11 and EOC-11 voltage distributions for 0.6 POD and POPCD for SG 2-1, SG 2-2, SG 2-3, and SG 2-4, respectively. As expected, SG 2-4 has the largest number of indications at EOC-11 and also has the largest voltage indications.

5.5 Comparison of Predicted and Actual EOC-10 Voltage Distributions, Leak Rate and Probability of Burst

The actual EOC-10 bobbin voltage distributions and the predictions from the previous 90-day report (Ref. 8) are compared in Table 5-9 and Table 5-10 and Figure 5-12 through Figure 5-15. The total number of indications found at EOC-10 and projected is very similar; however, as seen in the figures the projected voltage distributions on average display a population with larger voltages. Note in Figure 5-14 and Figure 5-15 that the as-found population of larger voltages differs from the projected population. The most likely contributor is the voltage dependent growth that was not used in the Cycle 10 projections.

The leak rate and probability of burst projected and actual EOC-10 were also compared in Table 5-10. The projected leak rates were greater than the actual EOC-10 leak rates for all SGs. However, the projected probability of burst for SG 2-3 and SG 2-4 was slightly lower than actual EOC-10. Again, the most likely contributor to the underprediction is the voltage dependent growth.

Table 5-1: Diablo Canyon Unit 2 POPCD Evaluation

Composite of All Steam Generator Data

	New Ind	New Indications		Bobbin Call InHBoth InspectionsInsp		POPCD			
	RPC	RPC Confirmed	RPC	RPC Confirmed	RPC Confirmed and	RPC Co	onfirmed	RPC Conf In	irmed Plus Not spected
Voltage Bin	Confirmed	Inspected	Confirmed	Inspected	Plugged	Frac	Count	Frac	Count
>0 - 0.2	4	61	1	19	0	0.200	1/5	0.238	19/80
0.2 - 0.4	22	171	5	147	6	0.333	11/33	0.472	153/324
0.4 - 0.6	20	82	4	156	7	0.355	11/31	0.665	163/245
0.6 - 0.8	9	28	1	77	2	0.250	3/12	0.738	79/107
0.8 - 1.0	2	7	5	43	0	0.714	5/7	0.860	43/50
1.0 - 1.2	0	2	4	20	0	1.000	4/4	0.909	20/22
1.2 - 1.6	1	1	14	24	0	0.933	14/15	0.960	24/25
1.6 - 2.0	0	0	6	6	0	1.000	6/6	1.000	6/6
2.0 - 2.5	0	0	0	0	4	1.000	4/4	1.000	4/4
2.5 - 3.2	0	0	0	0	2	1.000	2/2	1.000	2/2
3.2 - 3.5	0	0	0	0	0				
TOTAL	58	352	40	492	21				
Total >1v	1	3	24	50	6				

							DOSs Returned to	Service
Voltage	As-found	POD	Repaired	Calculated	POPCD	Calc. POPCD	Conf. OD-SCC or	
Bin	EOC-10	(0.6)	Tubes	BOC-11	EPRI	BOC-11	Not Insp. w/+Pt	Total (1)
0.1								
0.2	3	5		5	9.09	9.09	3	3
0.3	25	41.67		41.67	54.35	54.35	25	25
0.4	23	38.33		38.33	41.82	41.82	23	23
0.5	32	53.33	:	53.33	50.79	50.79	30	32
0.6	23	38.33		38.33	32.86	32.86	21	23
0.7	22	36.67		36.67	28.95	28.95	22	22
0.8	7	11.67		11.67	8.86	8.86	6	7
0.9	9	15		15	10.84	10.84	8	9
1	4	6.67	1	5.67	4.76	3.76	3	3
1.1	2	3.33		3.33	2.33	2.33	2	2
1.2	3	5		5	3.41	3.41	3	3
1.3	3	5		5	3.37	3.37	3	3
1.4	4	6.67		6.67	4.44	4.44	4	4
1.5	2	3.33		3.33	2.21	2.21	2	2
1.6								
1.7								
1.8								
1.9	2	3.33		3.33	2.16	2.16	2	2
2	1	1.67		1.67	1.08	1.08	1	1
2.1								
2.2								
2.3								
2.4								
2.5								
2.6	1	1.67	1	0.67	1.04	0.04		
2.7								
2.8	ł							
2.9								
3								
3.1								
3.2			1					
3.3								
3.4	1	1.67	1	0.67	1			
3.5								
3.6								
3.7								
3.8								
3.9								
4								
4.1								
4.2								
4.3					1			
4.4								
4.5								
>4.5								
Total	167	278.34	3	275.34	263.36	260.36	158	164

Table 5-2: SG 2-1 As-Found and BOC-11 Voltage Distribution

							DOSs Returned to Service			
Voltage	As-found	POD	Repaired	Calculated	POPCD	Calc. POPCD	Conf. OD-SCC or			
Bin	EOC-10	(0.6)	Tubes	BOC-11	EPRI	BOC-11	Not Insp. w/+Pt	Total (1)		
0.1		<u></u>								
0.2	3	5		5	9.09	9.09	3	3		
0.3		18.33		18.33	23.91	23.91	9	11		
0.4	25	41.67	1	40.67	45.45	44.45	22	24		
0.5	19	31.67		31.67	30.16	30.16	19	19		
0.6	16	26.67		26.67	22.86	22.86	16	16		
0.7	11	18.33		18.33	14.47	14.47	10	11		
0.8	3	5		5	3.8	3.8	3	3		
0.9	9	15		15	10.84	10.84	9	9		
1	6	10		10	7.14	7.14	6	6		
1.1	1	1.67		1.67	1.16	1.16	1	1		
1.2										
1.3	2	3.33		3.33	2.25	2.25	2	2		
1.4										
1.5										
1.6										
1.7										
1.8										
1.9	1	1.67		1.67	1.08	1.08	1			
2	1	1.67		1.67	1.08	1.08	1			
2.1										
2.2										
2.3										
2.4										
2.5							·	ļ		
2.6										
2.7										
2.8										
2.9										
3										
3.1										
3.2	1									
3.3										
3.4										
3.5						ļ		<u> </u>		
3.6				ļ						
3.7										
3.8	ļ							1		
3.9					1					
4			ļ			ļ				
4.1										
4.2										
4.3										
4.4										
4.5				1						
>4.5		ļ					100	107		
Total	108	180.01	1	179.01	173.29	172.29	102	107		

Table 5-3: SG 2-2 As-Found and BOC-11 Voltage Distribution

							DOSs Returned to	Service
Voltage	As-found	POD	Repaired	Calculated	POPCD	Calc. POPCD	Conf. OD-SCC or	
Bin	EOC-10	(0.6)	Tubes	BOC-11	EPRI	BOC-11	Not Insp. w/+Pt	Total (1)
0.1								
0.1	3	5		5	9.09	9.09	3	3
0.2	19	31.67		31.67	41.3	41.3	17	19
0.5	12	20		20	21.82	21.82	12	12
0.4	14	23.33		23.33	22.22	22.22	13	14
0.6	10	16.67		16.67	14.29	14.29	9	10
0.0	12	20		20	15.79	15.79	12	12
0.8	5	8.33		8.33	6.33	6.33	5	5
0.9	6	10		10	7.23	7.23	6	6
1	1	1.67		1.67	1.19	1.19	1	1
1.1	5	8.33		8.33	5.81	5.81	5	5
1.2	2	3.33		3.33	2.27	2.27	2	2
1.3	2	3.33		3.33	2.25	2.25	2	2
1.4	_							
1.5	1	1.67		1.67	1.1	1.1	1	1
1.6								
1.7								
1.8								
1.9								
2								
2.1								
2.2	2	3.33	2	1.33	2.13	0.13		
2.3								
2.4								
2.5								
2.6	· · · · ·							
2.7								
2.8								
2.9								
3								
31								
3.1								
3.2								
2.4								
3.4								
3.5	·							
3.0						1		
3.2								
3.0	1	1.67	1	0.67	1	-		
4		,			-			
4 1						<u> </u>		<u> </u>
4.1								
43								
4.5	1	1.67	1	0.67	1			
4.5		,						
>/ 5								
Tetal	06	160	A	156	154.82	150.82	88	92
1 IOIAI	1 90	1 100	1 7	1 100			1 · · ·	

Table 5-4: SG 2-3 As-Found and BOC-11 Voltage Distribution

							DOSs Returned to	Service
Voltage	As-found	POD	Repaired	Calculated	POPCD	Calc. POPCD	Conf. OD-SCC or	
Bin	EOC-10	(0.6)	Tubes	BOC-11	EPRI	BOC-11	Not Insp. w/+Pt	Total (1)
0.1								I
0.1	6	10		10	18.18	18.18	6	6
0.2	32	53.33		53.33	69.57	69.57	32	32
0.5	58	96.67	3	93.67	105.45	102.45	55	56
0.4	68	113.33	2	111.33	107.94	105.94	66	66
0.5	73	121.67	2	119.67	104.29	102.29	72	72
0.0	55	91.67	1	90.67	72.37	71.37	52	54
0.8	40	66.67		66.67	50.63	50.63	40	40
0.9	29	48.33		48.33	34.94	34.94	29	29
1	22	36.67		36.67	26.19	26.19	22	22
1.1	27	45	3	42	31.4	28.4	24	24
1.2	8	13.33	1	12.33	9.09	8.09	7	7
1.3	11	18.33		18.33	12.36	12.36	11	11
1.4	15	25	1	24	16.67	15.67	14	14
1.5	7	11.67	1	10.67	7.73	6.73	6	6
1.6	6	10		10	6.59	6.59	6	6
1.7	7	11.67		11.67	7.65	7.65	7	7
1.8	5	8.33		8.33	5.43	5.43	5	5
1.9	3	5		5	3.24	3.24	3	3
2	5	8.33		8.33	5.38	5.38	5	5
2.1		1						
2.2	1	1.67	1	0.67	1.06	0.06		
2.3	1	1.67	1	0.67	1.06	0.06		
2.4								
2.5								
2.6								
2.7								
2.8	2	3.33	2	1.33	2.06	0.06		
2.9	1	1.67	1	0.67	1.03	0.03		
3							· · · · · · · · · · · · · · · · · · ·	
3.1	1	1.67	1	0.67	1.02	0.02		
3.2	1	1.67	1	0.67	1.01	0.01		
3.3								
3.4	1	1.67	1	0.67	I			
3.5	1	1.67	1	0.67	1			
3.6								
3.7			ŀ					
3.8	ļ							
3.9	1	1.67	1	0.67	1			
4								<u> </u>
4.1	1	1.67	1	0.67	1			
4.2	1	1.67	1	0.67	1			
4.3		1						
4.4	1	1.67	1	0.67	1			
4.5								
>4.5	3	5.00	3	2.00	3			+
Total	493	821.67	30	791.67	711.34	681.34	463	463

Table 5-5: SG 2-4 As-Found and BOC-11 Voltage Distribution

	BOC Distribution	Growth Distribution
SG 2-1	1. POD=0.6	1. Composite Normal
	2. EPRI POPCD	2. Composite Normal
SG 2-2	1. POD=0.6	1. Composite Normal
	2. EPRI POPCD	2. Composite Normal
SG 2-3	1. POD=0.6	1. Composite Normal and Composite
		Voltage Dependent
		2. Composite Normal and Composite
	2. EPRI POPCD	Voltage Dependent
SG 2-4	1. POD=0.6	1. SG 2-4 specific Normal and SG 2-4
	2. EPRI POPCD	specific Voltage Dependent
		2. SG 2-4 specific Normal and SG 2-4
		specific Voltage Dependent

Table 5-6: Summary of Monte Carlo Simulations

Voltage	Normal Growth			Voltage Dependent Growth		
Bin	SG 1	SG 2	SG 3	SG 4	SG 3	SG 4
0.1	0.0352	0.0354	0.0354	0.0457	0.0357	0.0456
0.2	1.2099	0.8802	1.0684	1.2932	1.0756	1.2907
0.3	6.1569	3.6294	4.6632	6.4033	4.7156	6.4837
0.4	12.8524	8.7859	8.6452	17.1565	8.9218	17.7687
0.5	21.8614	15.2161	13.3753	34.7063	13.8690	36.3996
0.6	29.8158	20.3075	16.6767	55.1153	17.2524	57.9234
0.7	31.9175	22.2377	16.5530	70.7933	17.1217	74.4505
0.8	32.1118	20.7648	16.6333	78.3955	17.1878	82.3408
0.9	27.4110	18.0508	14.3550	77.3316	14.7576	80.9237
1	22.3252	14.8777	12.2824	70.0281	12.4777	72.5434
1.1	17.4740	12.0825	10.2794	60.8283	9.9990	60.9333
1.2	13.2797	9.6418	8.2462	51.3919	7.3536	48.1280
1.3	10.5036	7.3031	6.7550	42.9507	5.3877	36.8051
1.4	8.6239	5.4361	5.5149	35.9803	4.0283	28.0423
1.5	7.1044	3.9986	4.2796	30.1206	2.9636	21.5345
1.6	5.8009	2.8344	3.1997	25.2450	2.2132	17.1662
1.7	4.5467	1.9954	2.2870	21.1022	1.6959	14.3744
1.8	3.4774	1.4257	1.6223	17.4680	1.3836	12.4371
1.9	2.7089	1.1110	1.1967	14.3570	1.2392	10.9745
2	2.1801	1.0061	0.8964	11.8201	1.1071	9.7602
2.1	1.8829	0.9500	0.7478	9.8394	1.0291	8.7490
2.2	1.6207	0.8806	0.6323	8.1503	0.9119	7.7882
2.3	1.3871	0.7635	0.5585	6.6435	0.7638	6.7847
2.4	1.1794	0.6466	0.5109	5.3306	0.5900	5.7293
2.5	0.9516	0.5408	0.4277	4.2226	0.4280	4.6751
2.6	0.7622	0.4312	0.3566	3.3429	0.2987	3.7575
2.7	0.5830	0.3331	0.2789	2.6462	0.2445	3.1808
2.8	0.4608	0.2464	0.2303	2.1251	0.2689	2.9859
2.9	0.3870	0.1972	0.1997	1.7781	0.3113	2.9548
3	0.3429	0.1723	0.1719	1.5674	0.3234	2.9094
3.1	0.3273	0.1646	0.1588	1.4689	0.3556	2.8572
3.2	0.3606	0.1717	0.1819	1.4391	0.3872	2.7793
3.3	0.3708	0.1900	0.1819	1.4599	0.3505	2.6305
3.4	0.3931	0.2009	0.1930	1.5032	0.2849	2.3736
3.5	0.3855	0.2015	0.1891	1.4780	0.2094	2.0571
3.6	0.3442	0.1778	0.1728	1.3622	0.1536	1.7786
3.7	0.2856	0.1396	0.1566	1.1875	0.1389	1.0580
3.8	0.2231	0.1033	0.1417	0.9868	0.1578	1.0/07
3.9	0.1659	0.0762	0.1305	0.8251	0.1925	1.7806
4	0.1233	0.0535	0.1220	0.7027	0.2433	2.0080
4.1	0.0945	0.0379	0.1162	0.6091	0.2962	2.2427
4.2	0.0743	0.0244	0.1112	0.5322	0.3190	2.2330
4.3	0.0609	0.0168	0.1076	0.4782	0.2985	2.038/
4.4	0.0753	0.0266	0.1225	0.4982	0.2444	1.7820
4.5	0.1298	0.0598	0.1564	0.6331	0.1854	1.5207
>4.5	0.9711	0.5828	1.0783	8.3692	2.2288	20.4440
Total	275.3397	179.0093	155.9999	791.7124	156.0017	/91.7081

Table 5-7: EOC-11 Distributions with POD=0.6

86-5013685-01 Page 48 of 63

Voltage	Normal Growth				Voltage Dependent Growth		
Bin	SG 1	SG 2	SG 3	SG 4	SG 3	SG 4	
0.1	0.0636	0.0641	0.0638	0.0831	0.0645	0.0831	
0.1	1.8978	1.4694	1.7147	2.0982	1.7254	2.0970	
0.2	8 2422	4.9310	6.3750	8.7528	6.4662	8.9059	
0.5	15 9730	10.8386	11.1539	21.3694	11.5431	22.2408	
0.4	25 3877	17.5192	16.2378	40.1023	16.8613	42.1537	
0.5	32,1042	21.7385	18.6933	58.7166	19.3443	61.7554	
0.7	31,8976	22.4957	17.0767	70.0929	17.6639	73.7000	
0.8	30.4577	19.8131	16.1118	72.9790	16.6165	76.5950	
0.9	24.6253	16.3742	12.9730	68.1815	13.2948	71.1759	
1	19.3304	12.9012	10.6429	59.1383	10.7743	61.0830	
1.1	14,7968	10.1313	8.6838	49.6466	8.4369	49.6692	
1.2	10.8988	7.9144	6.6991	40.6508	6.0215	38.2383	
1.3	8.4629	5.9118	5.3969	33.1095	4.3642	28.7058	
1.4	6.8509	4.3926	4.3690	27.1853	3.2617	21.5855	
1.5	5.4919	3.2226	3.3135	22.3359	2.3457	16.3436	
1.6	4.3595	2.2473	2.4188	18.3265	1.6948	12.7374	
1.7	3.3099	1.5357	1.6817	14.9648	1.2558	10.3597	
1.8	2.4904	1.0741	1.1833	12.1203	1.0122	8.7302	
1.9	1.9570	0.8357	0.8962	9.8382	0.9291	7.5792	
2	1.5936	0.7791	0.6748	8.1008	0.8153	6.6869	
2.1	1.4193	0.7473	0.5690	6.7926	0.7481	5.9638	
2.2	1.2203	0.6937	0.4492	5.6543	0.6423	5.2584	
2.3	1.0436	0.6015	0.3735	4.6004	0.5177	4.5307	
2.4	0.8925	0.5078	0.3337	3.6815	0.3779	3.7737	
2.5	0.7028	0.4265	0.2591	2.9042	0.2571	3.0360	
2.6	0.5439	0.3351	0.2056	2.2675	0.1650	2.4041	
2.7	0.3925	0.2538	0.1499	1.7406	0.1290	2.0121	
2.8	0.2986	0.1882	0.1300	1.3587	0.1560	1.9077	
2.9	0.2527	0.1572	0.1268	1.1225	0.1953	1.9184	
3	0.2271	0.1470	0.1188	0.9822	0.1958	1.8824	
3.1	0.2280	0.1522	0.1243	0.9218	0.2255	1.8137	
3.2	0.2769	0.1665	0.1618	0.9170	0.2584	1.7288	
3.3	0.2868	0.1912	0.1623	0.9640	0.2249	1.6016	
3.4	0.3097	0.1992	0.1706	1.0115	0.1781	1.4136	
3.5	0.2936	0.1917	0.1540	0.9510	0.1238	1.1921	
3.6	0.2436	0.1600	0.1213	0.8186	0.0836	0.9996	
3.7	0.1838	0.1184	0.0911	0.6471	0.0711	0.9146	
3.8	0.1288	0.0821	0.0676	0.4819	0.0804	0.9307	
3.9	0.0864	0.0569	0.0494	0.3552	0.0998	1.0045	
4	0.0570	0.0391	0.0350	0.2687	0.1295	1.1603	
4.1	0.0399	0.0268	0.0252	0.2071	0.1613	1.3182	
4.2	0.0294	0.0172	0.0184	0.1592	0.1755	1.3137	
4.3	0.0267	0.0134	0.0164	0.1361	0.1588	1.1798	
4.4	0.0599	0.0338	0.0438	0.2141	0.1206	1.0102	
4.5	0.1301	0.0692	0.0886	0.3870	0.0798	0.8416	
>4.5	0.7932	0.5253	0.4138	4.0043	0.7711	9.8041	
Total	260.3584	172.2904	150.8197	681.3418	150.8182	681.3399	

Table 5-8: EOC-11 Voltage Distributions with EPRI POPCD

	Normal Growth and POD=0.6								
Voltage Bin	SG 1 E	OC -10	SG 2 E	OC -10	SG 3 E	OC -10	SG 4 EOC -10		
Û	As-Found	Projected	As-Found	Projected	As-Found	Projected	As-Found	Projected	
01	0	0.0982	0	0.1833	0	0.0217	0	0.0132	
0.2	3	2.1719	3	1.4086	3	0.6022	6	0.4889	
0.2	25	7.0241	11	4.3593	19	2.6298	32	3.5376	
0.5	23	13.4823	25	8.4282	12	5.6214	58	13.5007	
0.1	32	20.4804	19	12.2942	14	8.6468	68	29.0110	
0.6	23	24.4314	16	13.7909	10	11.3975	73	46.8621	
0.7	22	23.3101	11	13.2365	12	11.4365	55	57.6301	
0.8	7	19.7832	3	10.7765	5	10.2318	40	58.4478	
0.9	9	15.4008	9	8.3288	6	8.3197	29	52.0781	
1	4	11.7380	6	6.0900	1	6.4910	22	43.1866	
1.1	2	8.8361	1	4.3547	5	4.9147	27	34.6052	
1.2	3	6.6465	0	3.1830	2	3.7593	8	27.8162	
1.3	3	4.8502	2	2.5475	2	2.9041	11	22.9405	
1.4	4	3.4954	0	2.0649	0	2.2507	15	19.2555	
1.5	2	2.6063	0	1.5630	1	1.8384	7	16.2955	
1.6	0	1.9818	0	1.1540	0	1.5419	6	13.5148	
1.7	0	1.4932	0	0.8472	0	1.2549	7	10.7735	
1.8	0	1.1110	0	0.6129	0	1.0138	5	8.3243	
1.9	2	0.8427	1	0.4531	0	0.8281	3	6.3648	
2	1	0.6761	1	0.3657	0	0.7174	5	5.1009	
2.1	0	0.5677	0	0.3211	0	0.6407	0	4.3177	
2.2	0	0.4722	0	0.2529	2	0.5869	1	3.7937	
2.3	0	0.3473	0	0.1883	0	0.5061	1	3.2387	
2.4	0	0.2324	0	0.1306	0	0.4181	0	2.6083	
2.5	0	0.1436	0	0.0996	0	0.3290	0	2.0050	
.2.6	1	0.1214	0	0.0896	0	0.2602	0	1.5144	
2.7	0	0.1558	0	0.1174	0	0.2319	0	1.2459	
2.8	0	0.1919	0	0.1658	0	0.2076	2	1.1571	
2.9	0	0.2196	0	0.1771	0	0.1891	1	1.1154	
3	0	0.2230	0	0.1848	0	0.1805	0	1.0858	
3.1	0	0.1956	0	0.1864	0	0.1518	1	1.0073	
3.2	0	0.1550	0	0.1437	0	0.1203	1	0.8530	
3.3	0	0.1092	0	0.1062	0	0.0931	0	0.6682	
3.4	1	0.0722	0	0.0865	0	0.0641	1	0.4844	
3.5	0	0.0456	0	0.0636	0	0.0440	1	0.3458	
3.6	0	0.0299	0	0.0460	0	0.0315	0	0.2570	
3.7	0	0.0183	0	0.0354	0	0.0230	0	0.1953	
3.8	0	0.0096	0	0.0274	0	0.0164	0	0.1489	
3.9	0	0.0048	0	0.0205	1	0.0124	1	0.1134	
4	0	0.0023	0	0.0146	0	0.0094	0	0.0855	
4.1	0	0.0011	0	0.0103	0	0.0072	1	0.0622	
4.2	0	0.0005	0	0.0073	0	0.0056	1	0.0445	
4.3	0	0.0002	0	0.0056	0	0.0045	0	0.0328	
4.4	0	0.0001	0	0.0044	1	0.0035	1	0.0254	
4.5	0	0.0000	0	0.0032	0	0.0032	0	0.0202	
>4.5	0	0.2207	0	0.1400	0	0.1280	3	0.8346	
Total	167	174.0001	108	98.6707	96	90.6893	493	497.0077	

Table 5-9: EOC-10 As-Found vs Projected Voltage Distribution

	EOC-10 F	Projected	EOC-10 Actual		
Steam Generator	Probability of Burst	SLB Leak Rate	Probability of Burst	SLB Leak Rate	
2-1	6.66 X 10 ⁻⁵	0.2349	2.19 X 10 ⁻⁵	0.1497	
2-2	4.41 X 10 ⁻⁵	0.1267	6.30 X 10 ⁻⁶	0.0546	
2-3	5.55 X 10 ⁻⁵	0.1500	9.31 X 10 ⁻⁵	0.1240	
2-4	3.24 X 10 ⁻⁴	1.2448	5.82 X 10 ⁻⁴	1.0409	

Table 5-10: EOC-10 Projected vs Actual POB & Leak Rate



Figure 5-2

SG 1 As-Found And Calculated BOC Voltage Distributions (POD=0.6)







Figure 5-4

SG 3 As-Found And Calculated BOC Voltage Distributions (POD=0.6)



SG 4 As-Found And Calculated BOC Voltage Distributions (POD=0.6)















Figure 5-10















Figure 5-14

SG 3 As Found vs Previous Cycle Projected EOC Voltage Distribution



SG 4 As Found vs Previous Cycle Projected EOC Voltage Distribution



6.0 Tube Leak Rate and Tube Burst Probabilities

This section presents the results of analyses carried out to predict leak rates and tube burst probabilities for postulated SLB conditions for the projected EOC-11 voltage distributions. Since SG 2-4 has the largest total number of indications and the largest number of indications over 1 volt, SG 2-4 is expected to yield the limiting SLB leak rates and burst probabilities for Cycle 11.

6.1 Leak Rate and Tube Burst Probability for EOC-11

Calculations to predict SLB leak rate and tube burst probability for each steam generator in DCPP Unit-2 at the EOC-11 conditions were carried out using the NRC-required constant POD value of 0.6. A composite normal growth rate distribution was used for SG 2-1, SG 2-2, and SG 2-3. A SG 2-4 specific growth distribution was used for SG 2-4. The leak and burst results for each steam generator using a 0.6 POD are given in Table 6-1. This table also provides the voltage dependent growth results for SG 2-3 and SG 2-4. For information only, the leak and burst results for each steam generator using POPCD are given in Table 6-2 for the same set of growth distributions used in Table 6-1.

For SG 2-3 and SG 2-4 the results from the two voltage dependent growth analyses (<1 volt, >1 volt) had to be combined. Conservatively, the leak rate and burst results for each analysis was simply summed together.

6.2 Summary and Conclusions

The requirements for burst probabilities are met at EOC-11 with no steam generator exceeding the 1×10^{-2} criteria. For the leak rate, the plant-specific value of 12.8 gpm (at room temperature) for the faulted steam generator was not exceeded for any steam generator.

Table 6-1: Leak Rate and Burst Probability Using 0.6 POD

DCPP Unit 2 May 2001 Outage (2R10) Summary of Calculations of Tube Leak Rate and Burst Probability at EOC-11 for 1 million Simulations Using 0.6 POD

Steam	POD Applied	Number of Indications at EOC-11 ⁽¹⁾	Probabili	ty of Burst	SLB Leak Rate ^(3,5)	Voltage Dependent Growth
Generator			Best Estimate ⁽²⁾	95% UCL ⁽⁴⁾ (1 or More Failures)	(gpm)	
2-1	0.6	275.34	1.51 X 10 ⁻⁴	1.73 X 10 ⁻⁴	0.6170	No
2-2	0.6	179.01	8.60 X 10 ⁻⁵	1.03 X 10 ⁻⁴	0.3439	No
2-3	0.6	156.00	1.43 X 10 ⁻⁴	1.64 X 10 ⁻⁴	0.3528	No
2-3	0.6	156.00	3.92 X 10 ⁻⁴	4.32 X 10 ⁻⁴	0.4297 (6)	Yes
2-4	0.6	791.71	1.24 X 10 ⁻³	1.30 X 10 ⁻³	2.852	No
2-4	0.6	791.71	3.55 X 10 ⁻³	3.66 X 10 ⁻³	3.730 (6)	Yes
	Accep	tance Criteria	1.0×10^{-2}	12.8(7)		

Notes:

1) Adjusted for POD.

2) Best Estimate is the number of trials with a failure divided by the number of trials.

3) Equivalent volumetric rate at room temperature.

4) The 95% Upper Confidence Limit (UCL) is based on the number of trials with one or more failures.

5) The calculated total leak rate reflects the upper 95% quantile value at an upper 95% confidence bound.

6) Voltage dependent growth used. SG 2-3 composite; SG 2-4 generator specific.

7) This limit has not been adjusted for leakage contributions from other ARCs that have been implemented during U2R10.

Table 6-2: Leak Rate and Burst Probability Using POPCD

DCPP Unit 2 May 2001 Outage (2R10) Summary of Calculations of Tube Leak Rate and Burst Probability at EOC-11 for 1 million Simulations Using POPCD

Steam	POD Applied	Number of Indications at EOC-11 ⁽¹⁾	Probabili	ty of Burst	SLB Leak Rate ^(3,5)	Voltage Dependent Growth
Generator			Best Estimate ⁽²⁾	95% UCL ⁽⁴⁾ (1 or More Failures)	(gpm)	
2-1	POPCD	260.36	1.09 X 10 ⁻⁴	1.28 X 10 ⁻⁴	0.4942	No
2-2	POPCD	172.29	7.70 X 10 ⁻⁵	9.31 X 10 ⁻⁵	0.2924	No
2-3	POPCD	150.82	5.90 X 10 ⁻⁵	7.33 X 10 ⁻⁵	0.2459	No
2-3	POPCD	150.82	1.31 X 10 ⁻⁴	1.58 X 10 ⁻⁴	0.2542 (6)	Yes
2-4	POPCD	681.34	5.71 X 10 ⁻⁴	6.12 X 10 ⁻⁴	1.934	No
2-4	POPCD	681.34	1.57 X 10 ⁻³	1.64 X 10 ⁻³	2.3716 (6)	Yes
	Accept	tance Criteria	1.0×10^{-2}	12.8(7)		

Notes:

- 1) Adjusted for POD.
- 2) Best Estimate is the number of trials with a failure divided by the number of trials.
- 3) Equivalent volumetric rate at room temperature.
- 4) The 95% Upper Confidence Limit (UCL) is based on the number of trials with one or more failures.
- 5) The calculated total leak rate reflects the upper 95% quantile value at an upper 95% confidence bound.
- 6) Voltage dependent growth used. SG 2-3 composite; SG 2-4 generator specific.
- 7) This limit has not been adjusted for leakage contributions from other ARCs that have been implemented during U2R10.

7.0 References

- 1. FRA-ANP Document 86-5012862-00, "DCPP 2R10 Bobbin Coil Voltage ARC, Return-to-Power Report," May 2001.
- 2. NRC Generic Letter 95-05, "Voltage-Based Repair Criteria for the Repair of Westinghouse Steam Generator Tubes Affected by Outside Diameter Stress Corrosion Cracking," USNRC Office of Nuclear Reactor Regulation, August 3, 1995.
- 3. NRC SER for Diablo Canyon Units 1 and 2 for Voltage-Based Repair Criteria, letter to PG&E dated March 12, 1998.
- 4. FTI Document 51-5001160-01, "Steam Generator POB Simulation Code POB97vb.F90", March 2000.
- 5. FTI Document 51-5001151-00, "Steam Generator Leak Rate Simulation Code LKR97vb.F90", March 1998.
- 6. WCAP 14277, Revision 1, SLB Leak Rate and Tube Burst Probability Analysis Methods for ODSCC at TSP Intersections, December, 1996.
- 7. FTI Document 86-5001354-00, "DCPP Unit 2 2R8 90 Day Report," June 1998.
- 8. FTI Document 86-5006208-01, "Diablo Canyon Unit 2 2R9 Voltage-Based Repair Criteria 90 Day Report Unit 2 2R9 90 Day Calculations," January 2000.
- 9. FTI Document 86-5003756-00, "DCPP Unit 1 1R9 90 Day Report," June 1999.
- 10. FTI Document 86-5010437-00, "Diablo Canyon 1R10 90 Day Report," March 2001.
- 11. EPRI TR-113861, "Steam Generator Tubing ODSCC at Tube Support Plates for Alternate Repair Limits Database Update 1999," Electric Power Research Institute, Interim Report, November 1999.
- 12. Pacific Gas and Electric, Diablo Canyon Unit 2 Refueling Outage 2R10, "Steam Generator Tubing Degradation Assessment", Revision 0, May 3, 2001.
- 13. EPRI Report NP 7480-L, Addendum 3, 1999 Database Update, "Steam Generator Tube Outside Diameter Stress Corrosion Cracking at Tube Support Plates Database for Alternate Repairs Limits", Electric Power Research Institute, 9/22/99.
- 14. PG&E NDE Procedure N-ET-7, Rev. 3, "Eddy Current Examination of DCPP Units 1 & 2 Steam Generator Tubing", May 2001.
- 15. Pacific Gas and Electric Company, Diablo Canyon Power Plant, Surveillance Test Procedure, STP M-SGTI, Revision 4, "Steam Generator Tube Inspection."
- 16. FRA-ANP Document 51-5012861-00, "Probe Wear Monitoring for DCPP 2R10", May 2001.
- 17. FTI Document 51-5003036-00, "50.59 Input for Using Changeable Feet Probes at DCPP, February 1999.
- 18. NRC Letter to NEI, dated February 9, 1996, "Probe Wear Criteria."
- 19. WCAP-15289, "Nuclear Design and Core Physics Characteristics of Diablo Canyon Power Plant Unit 2 Cycle 10", September 1999.
- 20. EPRI Report NP 7480-L, Addendum 2 1998 Database Update, "Steam Generator Tubing Outside Diameter Stress Corrosion Cracking at Tube Support Plates Database for Alternate Repair Limits," Electric Power Research Institute, April 1998.
- 21. FTI Document 51-5005962-00, "Bobbin Voltage Correlation for AONDB Indications at DCPP", October 1999.
- 22. NEI letter to NRC dated February 11, 2000, "Steam Generator Degradation Specific Management Database, POPCD Corrections in Addendum 3."
- 23. E-mail, John Arhar to Jeff Fleck, "U2 Cycle Lengths," May 7, 2001.
- 24. FRA-ANP Document 32-5013592-00, "DCPP Unit 2 2R10 90 Day ARC Calculations", August 2001.

OUTGOING CORRESPONDENCE SCREEN (Remove prior to NRC submittal)

Document:PG&E Letter DCL-01-086Subject:Special Report 01-04 – 90-Day Report, Results of Steam GeneratorAlternate Repair Criteria for Diablo Canyon Power Plant Unit 2 Tenth Refueling Outage

File Location S:\RS\RA\GRP WORK\ASME\STEAMGEN\DCL01086.doc

FSAR Update Review

Utilizing the guidance in XI3.ID2, does the FSAR Update need to be revised? Yes No X
If "Yes", submit an FSAR Update Change Request in accordance with XI3.ID2 (or if this is an LAR, process in accordance with WG-9)

COMMITMENT #1 No new commitments are contained in this document. Statement of Commitment: None.

Clarification: None.

Tracking Document:	AR or NCR None	AE or ACT
Assigned To:	NAME	ORGANIZATION CODE
Commitment Type:	FIRM OR TARGET	DUE DATE:
Outage Commitment?	YES OR NO NO	IF YES. WHICH? (E.G. 2R9. 1R10. ETC.)
PCD Commitment?	YES OR NO NO	IF YES. LIST THE IMPLEMENTING DOCUMENTS (IF KNOWN)
Duplicate of New NCR Commitment in PCD?	yes or no No	IF YES, LIST PCD NUMBER (e.g., T35905, etc.)
	YES OR NO	1. IF YES, LIST PCD NUMBER, AND 2. CLARIFY TO CLERICAL HOW COMMITMENT TO BE REVISED
Old PCD Commitment being changed?	No	

SUBMITTAL PROCESSING CHECKLIST

		Regulatory S	ervices Engineer	1		1
SUBJECT:	Unit 2	10th Ret	uching	90 kdy	SGREPON	T
PG&E LETTER	: DCL-01-08	le	FIRM) TAR	GET DATE:	8/21/01	
LOCATION: S:	RSI KA Gre-	Work ASME	El Sterno	a) 2R10-	Aday IC. Co	C
				6	101086 de	26

DOCUMENT VERIFICATION

- REFERENCES/BASES IDENTIFIED FOR FACTUAL INFORMATION
- COMMITMENT(S) PROPERLY IDENTIFIED (XI1.ID1)
- MANAGER'S CONCURRENCE FOR RELEASE
- RECORD OF REVIEW CHECKLIST (XI1.ID1) COMPLETE AND SIGNED
- CLERICAL QUALITY/FORMAT REVIEW Draft # 2 Str. 18/17/01

Draft # /____

Draft#//

Yes X

FINAL CLERICAL REVIEW (Letterhead)

No 🗍

- PEER REVIEW OF FINAL LETTER/ENCLOSURE(S)
- **PROVIDE TO SIGNATORY:**
 - · Final letter/enclosures, record of review, commitment memo
 - For ALL submittals, was 2 days met?
- COPY OF SUBMITTAL W/RECORD OF REVIEW AND COMMITMENT DATA TO RMS (FIREPROOF) CABINET
- INTERNAL -- provide this checklist, original of signed submittal, commitment data, and record of review to clerks
- NCRs, ARs, AND LERtemplate.ppt UPDATED FOR SUBMITTAL COMPLETION

TRACKING CLOSEOUT WITHIN 15 DAYS OF SUBMITTAL

VERIFY COMMITMENT ENTRY ON NCR ACTs, AEs

2nd enclosure still to come from W (200 tragen)

INITIALS/DATE

11/10/00

NUCLEAR POWER GENERATION XI1.ID1 ATTACHMENT 8.1

TITLE: 1	Regulatory Submittal - Record of 1	Review Checklist				<u>.</u>
SUBMITTA	LTITLE Special Ker	tot 2R10-5G	90 k	1 Zep K	EPON	7.
REQUIRED SUBMITTAL DATE: 8/2//0/ []N/A SCHEDULED SUBMITTAL DATE:						
PRIMARY	REVIEWERS	NAME	COMMENTS RESOLVE		LVED	
		, , , ,	YES	NO	YES	NO
LEAD TECI	HNICAL REVIEWER	JOHN Arhav	[]	[J]	[]	[]
LEAD TECI	HNICAL DIRECTOR/MGR	Bob Exner	[]	[4]	[]	[]
SUBMITTA	L LEAD MANAGEMENT	J.R. Hinds.D. Voshu	No.		[]	[]
INDEPEND	ENT TECH REVIEWER	Bob Exner	()	[4]	[]	[]
CROSS-DIS	CIPLINE REVIEWER(S)	IST	[]	M	[]	[]
[] OPI	ERATIONS SERVICES		[]	[]	[]	[]
[] MA	INTENANCE SERVICES	·	[]	[]	[]	[]
[] EN	GINEERING SERVICES	DAVE MikLush	[]	[]	[]	[]
[] SIT	E SERVICES		[]	[]	[]	[]
[] NQ.	AL		[]/	[]	[]	[]
		Roper Russell Ph	-[4	[]	[]	[]
[] TES	5	1	[]	[]	[]	[]
[] CH	EMISTRY & ENVIRONMENTAL		[]	[]	[]	[]
OPI	ERATIONS		[]	[]	[]	[]
[] PSF	RC		[]	[]	[]	[]
[] NSC	OC		[]	[]	[]	[]
[] OT	HER	Bat Nugerit. NH	-[]	[]	[]	[]
SECONDA	RY REVIEWERS	NAME	COMM	ENTS	RESOL	VED
			YES	NO	YES	NO
DCPP			[]	[]	[]	[]
ES			[]	[]	[]	[]
NQAL			[]	[]	[]	[]
LAW		<u></u>	[]	[]	[]	[]
		·····	[]	[]	[]	[]
	<u></u>		[]	[]	[]	[]
<u></u>			[]	[]	[]	[]

CONCURRENCE HAS BEEN RECEIVED FROM PRIMARY REVIEWERS AND TECHNICAL COMMENTS HAVE BEEN RESOLVED

SUBMITTAL LEAD ENGINEER:

DATE:

Page 1 of 1

PEER REVIEW CHECKLIST RS ENGINEER SUBMITTAL (To be performed on final draft only.)

ITEM	DESCRIPTION	DE ENCO
	DECOMINION	INITIALS
COVER LETTER	Correct signatory letterhead	
	Full names used for signatory & cc list; right people listed	1.2
	Title correct	3/3
	DCL number verified against DCL log	1 14
	DCL number appears on all pages	1 30
	All pages numbered except first page	3.4
	Date correct and appears on all pages (month day, and year)	- 30
	Address and docket number(s) correct	200
	Text reviewed for obvious errors	
	TS and/or 10 CFR references correct	
	If affidavit required or NOV response, verify Law Department has reviewed	
	and a service of the triceponed, termy Law Department has reviewed	
ALL SUBMITTALS	Text reviewed for obvious errors	20
· · ·	Revision bars included (if applicable)	
	TS and/or 10 CFR references correct	1~
	References to other documents correct (e.g., DCLs, FSAR, etc.)	3.4
	Submittal addresses the specific regulation requirements	- mc
	Enclosures labeled	JM
COMMITMENT TRACKING	DCL number and title correct	
MEMO (CTM)	Commitment(s) quoted verbatim (& Clarifications made if needed)	JM
	Tracking Document - AR/AE or NCR Action number	
	Assigned To - Name & Organization Code	
	Commitment Type - Firm or Target & Due Date	~
	Outage Commitment - Y or N indicator & Applicable Outage	-
	PCD Commitment - Y or N indicator & Implementing Documents	-
•	Duplicate of NCR Commitment in NCR - Y or N indicator & PCD number	-
	An individual from all departments assigned commitments was a Cross-	-
	Discipline Reviewer (Ref. XI1.ID1, Step 5.2.3.a.4.a)	
	LER number correct, consistent with cover letter	
	Title consistent with equal latter & CTM	
	Dates correct on first page header (manth day, 8 year)	
	Dates & times consistent with 10 CER 50 ENS reports made	
······································	Dates & times consistent with other source documente	
	Dates & times consistent between abstract percetive & Casties E	**
	Page numbers correct & all pages accounted for	
	Abstract word count <1400 characters (including characters)	
	IEEE 803 codes entered and correct	
		~
PROCEDURE	Procedure revision numbers current using EDMS (e.g., EPIP)	
SUBMITTALS		· .
ROR CHECKLIST	Record of Review Checklist completed and signed	
FINAL DRAFT	All discrepancies resolved with Lead Submittal Engineer	2m

I have reviewed this submittal for the items initialed above. This submittal is ready for the signatory.

Smis Performed by

8 0 Date

10/05/00

RS-4