

**From:** Chris Miller  
**To:** Michael Parker  
**Date:** Tue, Jul 11, 2000 12:02 PM  
**Subject:** 5 &6 racks

Mike,  
Tim Hanley from ops informs me there is no ops recovery procedure for those racks and no bypass switches. Any damage to those racks would have to be assessed case by case to determine a repair plan. On a side note, the only other controls for the ADS valves from a remote manual mode are right next to those racks. Those switches or the accessibility of those ADS controls would be questionable if subjected to similar damage as the racks to which they are adjacent.  
chris

On another issue-Chuck Peterson of reg affairs informs me the SSMP package still has to have a Krich review before they intend to share it with us.

**CC:** Mark Ring; rkw

