

September 6, 1977

Docket Nos. 50-280 ✓  
and 50-281

Virginia Electric & Power Company  
ATTN: Mr. W. L. Proffitt  
Senior Vice President - Power  
P. O. Box 26666  
Richmond, Virginia 23261

Gentlemen:

The Commission has requested the Office of the Federal Register to publish the enclosed "Notice of Proposed Issuance of Amendments to Facility Operating Licenses" for the Surry Power Station Units Nos. 1 and 2 in response to your request dated August 9, as supplemented August 26, 1977, regarding proposed Technical Specification Change No. 57.

The amendments would revise the Technical Specifications relating to the transient and accident analysis as affected by an increase in steam generator tube plugging levels from the current 20% to 25%.

Sincerely,

Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Operating Reactors

Enclosure:  
Notice

cc w/enclosure:  
See next page

DISTRIBUTION:

- Docket (2)
- NRC PDR (2)
- L PDR (2)
- ORB#4 Rdg.
- VStello
- KRGoller
- RIngram
- MFairtile
- OELD
- OI&E(2)
- BScharf(2)
- DEisenhut
- OPA, Clare Miles
- ACRS(16)
- TBAbernathy
- JRBuchanan
- Gray file

- X Cy - 4
- TCarter
- JBishop, OELD
- ASLAP (4)

OFFICE >	ORB#4:DOR	ORB#4:DOR	OELD	C-ORB#4:DOR		
SURNAME >	RIngram	MFairtile:dn	ARMA	RWReid		
DATE >	8/2/77	8/3/77	9/2/77	9/6/77		

Virginia Electric & Power Company

cc w/enclosure(s):  
Michael W. Maupin, Esq.  
Hunton, Williams, Gay & Gibson  
P. O. Box 1535  
Richmond, Virginia 23213

Swem Library  
College of William & Mary  
Williamsburg, Virginia 23185

Mr. Sherlock Holmes, Chairman  
Board of Supervisors of Surry County  
Surry County Courthouse  
Surry, Virginia 23683

Chief, Energy Systems  
Analyses Branch (AW-459)  
Office of Radiation Programs  
U. S. Environmental Protection Agency  
Room 645, East Tower  
401 M Street, S.W.  
Washington, D.C. 20460

U. S. Environmental Protection Agency  
Region III Office  
ATTN: EIS COORDINATOR  
Curtis Building (Sixth Floor)  
6th and Walnut Streets  
Philadelphia, Pennsylvania 19106

Mr. James C. Dunstan  
State Corporation Commission  
Commonwealth of Virginia  
Blandon Building  
Richmond, Virginia 23209

cc w/enclosures and incoming  
dtd: 8/9 & 8/26/77  
Commonwealth of Virginia  
Council on the Environment  
903 9th Street Office Building  
Richmond, Virginia 23219

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NOS. 50-280 AND 50-281

VIRGINIA ELECTRIC & POWER COMPANY

NOTICE OF PROPOSED ISSUANCE OF AMENDMENTS  
TO FACILITY OPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating Licenses Nos. DPR-32 and DPR-37 issued to Virginia Electric and Power Company (the licensee), for operation of the Surry Power Station Units Nos. 1 and 2, located in Surry County, Virginia.

In accordance with the licensee's application for amendment dated August 9, as supplemented August 26, 1977, the amendments would revise the provisions in the Technical Specifications relating to the transient and accident analysis as affected by an increase in steam generator tube plugging levels from the current 20% to 25%.

Prior to issuance of the proposed license amendments, the Commission will have made the findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations.

By October 17, 1977, the licensee may file a request for a hearing and any person whose interest may be affected by this proceeding may file a request for a hearing in the form of a petition for leave to intervene with respect to the issuance of the amendments to the subject facility operating licenses. Petitions for leave to intervene

must be filed under oath or affirmation in accordance with the provisions of Section 2.714 of 10 CFR Part 2 of the Commission's regulations. A petition for leave to intervene must set forth the interest of the petitioner in the proceeding, how that interest may be affected by the results of the proceeding, and the petitioners contentions with respect to the proposed licensing action. Such petitions must be filed in accordance with the provisions of this FEDERAL REGISTER notice and Section 2.714, and must be filed with the Secretary of the Commission, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Docketing and Service Section, by the above date. A copy of the petition and/or request for a hearing should be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to Mr. Michael W. Maupin, Esquire, Hunton, Williams, Gay & Gibson, P. O. Box 1535, Richmond, Virginia 23213, the attorney for the licensee.

A petition for leave to intervene must be accompanied by a supporting affidavit which identifies the specific aspect or aspects of the proceeding as to which intervention is desired and specifies with particularity the facts on which the petitioner relies as to both his interest and his contentions with regard to each aspect on which intervention is requested. Petitions stating contentions relating only to matters outside the Commission's jurisdiction will be denied.


All petitions will be acted upon by the Commission or licensing board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel. Timely petitions will be considered to determine whether a hearing should be noticed or another appropriate order issued regarding the disposition of the petitions.

In the event that a hearing is held and a person is permitted to intervene, he becomes a party to the proceeding and has a right to participate fully in the conduct of the hearing. For example, he may present evidence and examine and cross-examine witnesses.

For further details with respect to this action, see the application for amendment dated August 9, as supplemented August 26, 1977, which is available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. and at the Swem Library, College of William and Mary, Williamsburg, Virginia.

Dated at Bethesda, Maryland, this 6th day of September 1977.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Operating Reactors