

Docket

FEB 06 1976

Distribution

Docket VSTELLO  
 NRC PDR  
 Local PDR  
 ORB4 Rdg  
 KRGoller/TJCarter  
 RIngram  
 MFairtile  
 RWReid  
 Attorney, OELD  
 OI&E (3)  
 BJones (4) (8)  
 ACRS (16)  
 BScharf (10)  
 OPA CMiles  
 TAbernathy  
 JBuchanan  
 file

Dockets Nos. 50-280  
and 50-281

Virginia Electric & Power Company  
 ATTN: Mr. Stanley Ragone  
 Senior Vice President  
 P. O. Box 26666  
 Richmond, Virginia 23261

Gentlemen:

In our Amendment No. 14 to Facility License Nos. DPR-32 and DPR-37 for the Surry Power Station, Units 1 and 2, we inadvertently excluded minor, editorial corrections required to Technical Specification pages ii and 6.2-1. Please replace these pages with the enclosed revised pages.

Sincerely,

Original signed by

Robert W. Reid, Chief  
 Operating Reactors Branch #4  
 Division of Operating Reactors

Enclosure:  
 Pages TS ii and 6.2-1

cc:  
 See next page

OFFICE	ORB4 <i>ji</i>	ORB4 <i>MRJ</i>	ORB4 <i>RW</i>			
SURNAME	RIngram	MFairtile:mt	RWReid			
DATE	2/6/76	2/6/76	2/6/76			



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

February 6, 1976

Dockets Nos. 50-280  
and 50-281

Virginia Electric & Power Company  
ATTN: Mr. Stanley Ragone  
Senior Vice President  
P. O. Box 26666  
Richmond, Virginia 23261

Gentlemen:

In our Amendment No. 14 to Facility License Nos. DPR-32 and DPR-37 for the Surry Power Station, Units 1 and 2, we inadvertently excluded minor, editorial corrections required to Technical Specification pages ii and 6.2-1. Please replace these pages with the enclosed revised pages.

Sincerely,

A handwritten signature in cursive script, appearing to read "Robert W. Reid".

Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Operating Reactors

Enclosure:  
Pages TS ii and 6.2-1

cc:  
See next page

February 6, 1976

cc: Michael W. Maupin, Esquire  
Hunton, Williams, Gay & Gibson  
P. O. Box 1535  
Richmond, Virginia 23213

Swem Library  
College of William & Mary  
Williamsburg, Virginia 23185

Mr. Sherlock Holmes, Chairman  
Board of Supervisors of Surry County  
Surry County Courthouse  
Surry, Virginia 23683

Ms. Susan T. Wilburn  
Commonwealth of Virginia  
Council on the Environment  
P. O. Box 790  
Richmond, Virginia 23206

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
3.15	CONTAINMENT VACUUM SYSTEM	TS 3.15-1
3.16	EMERGENCY POWER SYSTEM	TS 3.16-1
3.17	LOOP STOP VALVE OPERATION	TS 3.17-1
3.18	MOVEABLE INCORE INSTRUMENTATION	TS 3.18-1
3.19	MAIN CONTROL ROOM VENTILATION SYSTEM	TS 3.19-1
4.0	<u>SURVEILLANCE REQUIREMENTS</u>	TS 4.0-1
4.1	OPERATIONAL SAFETY REVIEW	TS 4.1-1
4.2	REACTOR COOLANT SYSTEM COMPONENT TESTS	TS 4.2-1
4.3	REACTOR COOLANT SYSTEM INTEGRITY TESTING FOLLOWING OPENING	TS 4.3-1
4.4	CONTAINMENT TESTS	TS 4.4-1
4.5	SPRAY SYSTEMS TESTS	TS 4.5-1
4.6	EMERGENCY POWER SYSTEM PERIODIC TESTING	TS 4.6-1
4.7	MAIN STEAM LINE TRIP VALVES	TS 4.7-1
4.8	AUXILIARY FEEDWATER SYSTEM	TS 4.8-1
4.9	EFFLUENT SAMPLING AND RADIATION MONITORING SYSTEM	TS 4.9-1
4.10	REACTIVITY ANOMALIES	TS 4.10-1
4.11	SAFETY INJECTION SYSTEM TESTS	TS 4.11-1
4.12	VENTILATION FILTER TESTS	TS 4.12-1
4.13	NONRADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM	TS 4.13-1
4.14	TEMPERATURE LIMITATIONS ON CONDENSER COOLING WATER DISCHARGE	TS 4.14-1
4.15	AUGMENTED INSERVICE INSPECTION PROGRAM FOR HIGH ENERGY LINES OUTSIDE OF CONTAINMENT	TS 4.15-1
4.16	LEAKAGE TESTING OF MISCELLANEOUS RADIOACTIVE MATERIALS SOURCES	TS 4.16-1
5.0	<u>DESIGN FEATURES</u>	TS 5.1-1
5.1	SITE	TS 5.1-1
5.2	CONTAINMENT	TS 5.2-1
5.3	REACTOR	TS 5.3-1
5.4	FUEL STORAGE	TS 5.4-1
6.0	<u>ADMINISTRATIVE CONTROLS</u>	TS 6.1-1
6.1	ORGANIZATION, SAFETY AND OPERATION REVIEW	TS 6.1-1
6.2	ACTION TO BE TAKEN IN THE EVENT OF A REPORTABLE OCCURRENCE IN STATION OPERATION	TS 6.2-1

6.2 ACTION TO BE TAKEN IN THE EVENT OF A REPORTABLE OCCURRENCE IN STATION OPERATION

Specification

- A. Any reportable occurrence shall be reported immediately to and promptly reviewed by the Chairman-Station Nuclear Safety and Operating Committee or his designee, Director - Nuclear Operation and the Chairman-System Nuclear Safety and Operating Committee. Prompt corrective action shall be taken to correct the anomaly.
- B. A qualified individual shall prepare a written report for each reportable occurrence for submittal to the NRC. This report shall include an evaluation of the cause of the occurrence and also recommendations for appropriate action to prevent or reduce the probability of a recurrence.
- C. Copies of all such reports shall be submitted to the Superintendent-Station Operations, the Station Manager, who also serves as the Chairman-Station Nuclear Safety and Operating Committee, Director - Nuclear Operation, and to the Chairman-System Nuclear Safety and Operating Committee for review and approval of any recommendation.
- D. A duly authorized executive of the Company, or designee, shall report the circumstances of any reportable occurrence to the NRC as specified in Section 6.6.2 of these Specifications.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

February 6, 1976

Dockets Nos. 50-280  
and 50-281

Virginia Electric & Power Company  
ATTN: Mr. Stanley Ragone  
Senior Vice President  
P. O. Box 26666  
Richmond, Virginia 23261

Gentlemen:

In our Amendment No. 14 to Facility License Nos. DPR-32 and DPR-37 for the Surry Power Station, Units 1 and 2, we inadvertently excluded minor, editorial corrections required to Technical Specification pages ii and 6.2-1. Please replace these pages with the enclosed revised pages.

Sincerely,

A handwritten signature in cursive script, appearing to read "Robert W. Reid".

Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Operating Reactors

Enclosure:  
Pages TS ii and 6.2-1

cc:  
See next page

February 6, 1976

cc: Michael W. Maupin, Esquire  
Hunton, Williams, Gay & Gibson  
P. O. Box 1535  
Richmond, Virginia 23213

Swem Library  
College of William & Mary  
Williamsburg, Virginia 23185

Mr. Sherlock Holmes, Chairman  
Board of Supervisors of Surry County  
Surry County Courthouse  
Surry, Virginia 23683

Ms. Susan T. Wilburn  
Commonwealth of Virginia  
Council on the Environment  
P. O. Box 790  
Richmond, Virginia 23206

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
3.15	CONTAINMENT VACUUM SYSTEM	TS 3.15-1
3.16	EMERGENCY POWER SYSTEM	TS 3.16-1
3.17	LOOP STOP VALVE OPERATION	TS 3.17-1
3.18	MOVEABLE INCORE INSTRUMENTATION	TS 3.18-1
3.19	MAIN CONTROL ROOM VENTILATION SYSTEM	TS 3.19-1
4.0	<u>SURVEILLANCE REQUIREMENTS</u>	TS 4.0-1
4.1	OPERATIONAL SAFETY REVIEW	TS 4.1-1
4.2	REACTOR COOLANT SYSTEM COMPONENT TESTS	TS 4.2-1
4.3	REACTOR COOLANT SYSTEM INTEGRITY TESTING FOLLOWING OPENING	TS 4.3-1
4.4	CONTAINMENT TESTS	TS 4.4-1
4.5	SPRAY SYSTEMS TESTS	TS 4.5-1
4.6	EMERGENCY POWER SYSTEM PERIODIC TESTING	TS 4.6-1
4.7	MAIN STEAM LINE TRIP VALVES	TS 4.7-1
4.8	AUXILIARY FEEDWATER SYSTEM	TS 4.8-1
4.9	EFFLUENT SAMPLING AND RADIATION MONITORING SYSTEM	TS 4.9-1
4.10	REACTIVITY ANOMALIES	TS 4.10-1
4.11	SAFETY INJECTION SYSTEM TESTS	TS 4.11-1
4.12	VENTILATION FILTER TESTS	TS 4.12-1
4.13	NONRADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM	TS 4.13-1
4.14	TEMPERATURE LIMITATIONS ON CONDENSER COOLING WATER DISCHARGE	TS 4.14-1
4.15	AUGMENTED INSERVICE INSPECTION PROGRAM FOR HIGH ENERGY LINES OUTSIDE OF CONTAINMENT	TS 4.15-1
4.16	LEAKAGE TESTING OF MISCELLANEOUS RADIOACTIVE MATERIALS SOURCES	TS 4.16-1
5.0	<u>DESIGN FEATURES</u>	TS 5.1-1
5.1	SITE	TS 5.1-1
5.2	CONTAINMENT	TS 5.2-1
5.3	REACTOR	TS 5.3-1
5.4	FUEL STORAGE	TS 5.4-1
6.0	<u>ADMINISTRATIVE CONTROLS</u>	TS 6.1-1
6.1	ORGANIZATION, SAFETY AND OPERATION REVIEW	TS 6.1-1
6.2	ACTION TO BE TAKEN IN THE EVENT OF A REPORTABLE OCCURRENCE IN STATION OPERATION	TS 6.2-1

6.2 ACTION TO BE TAKEN IN THE EVENT OF A REPORTABLE OCCURRENCE IN  
STATION OPERATION

Specification

- A. Any reportable occurrence shall be reported immediately to and promptly reviewed by the Chairman-Station Nuclear Safety and Operating Committee or his designee, Director - Nuclear Operation and the Chairman-System Nuclear Safety and Operating Committee. Prompt corrective action shall be taken to correct the anomaly.
- B. A qualified individual shall prepare a written report for each reportable occurrence for submittal to the NRC. This report shall include an evaluation of the cause of the occurrence and also recommendations for appropriate action to prevent or reduce the probability of a recurrence.
- C. Copies of all such reports shall be submitted to the Superintendent-Station Operations, the Station Manager, who also serves as the Chairman-Station Nuclear Safety and Operating Committee, Director - Nuclear Operation, and to the Chairman-System Nuclear Safety and Operating Committee for review and approval of any recommendation.
- D. A duly authorized executive of the Company, or designee, shall report the circumstances of any reportable occurrence to the NRC as specified in Section 6.6.2 of these Specifications.