

Docket No. 50-280

October 31, 1984

DISTRIBUTION

~~SECRET FILE~~ NRC PDR
L PDR Gray 4
DEisenhut CParrish
ORAB HDenton
OELD (BURNS) JPartlow
JNGrace EJordan
ACRS 10 TBarnhart 4
SECY CMiles
Knight RDiggs
JDNeighbors GLainas

Mr. W. L. Stewart
Vice President - Nuclear Operations
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Dear Mr. Stewart:

By letter dated January 10, 1984, you informed the NRC that all piping and pipe support analyses associated with the Order to Show Cause dated March 13, 1979, and all modifications resulting from these analyses have been completed.

Because certain safety related piping systems at the facility had been designed and analyzed with a computer code which summed earthquake loads algebraically, the potential existed for compromising the basic defense-in-depth provided by redundant safety systems in the event of an earthquake. The potential compromising resulted from the possibility that an earthquake of the type for which the plant must be designed could cause a pipe rupture as well as degrade the emergency cooling system designed to mitigate such an accident. Therefore, by Order of the Director of Nuclear Reactor Regulation (the Director) for the Nuclear Regulatory Commission (NRC), dated March 13, 1979 (44 FR 16511, March 19, 1979), you were ordered to show cause:

- (1) Why the licensee should not reanalyze the facility piping systems for seismic loads on all potentially affected safety systems using an appropriate piping analysis computer code which does not combine loads algebraically;
- (2) Why the licensee should not make any modifications to the facility piping systems indicated by such reanalysis to be necessary; and
- (3) Why facility operation should not be suspended pending such reanalysis and completion of any required modifications.

In view of the importance to safety of this matter, the Order was made immediately effective and the facility was required to be placed in cold shutdown condition and remain in that mode until further Order of the Commission.

By Order dated August 22, 1979, the suspension of facility operation required by the Order to Show Cause of March 13, 1979 was lifted and the

8411270519 841031
PDR ADOCK 05000280
PDR

show cause proceeding was terminated on the basis of certain conditions. The lifting of the suspension of operation was based on the completion of all pipe stress analyses for the Design Basis Earthquake (DBE), the completion of all modifications to the supports inside containment, and a commitment to complete the analyses of pipe supports inside containment, and a commitment to complete the analyses of pipe supports outside containment within 60 days from the date of plant startup. The Safety Evaluation attached to the August 22, 1979 Order provided the basis for accepting the analysis performed by you.

Since at the time the Order was issued, analyses and modifications of pipe supports outside containment were not completed, the Order required that the facility be shut down if a seismic event occurred which resulted in accelerations greater than 0.01 g and that you inspect those safety and related piping systems which had not been reanalyzed and shown to be acceptable at the 0.07 g level of the Operating Basis Earthquake (OBE). The commitment to shut down for seismic events greater than 0.01 g was required only until such time that the reanalysis for the OBE loading condition, and any necessary modifications, were completed.

Since all of the analyses and modifications have now been completed, you have fulfilled the requirements of the March 13, and August 22, 1979 Orders and the remaining requirements to shut down the plant for certain seismic events can be rescinded as provided in the August 22 Order. Further operation will be in accordance with the Technical Specifications.

Accordingly, condition IV.5 of the Order dated August 22, 1979, is hereby rescinded.

Sincerely,

/s/SVarga

Steven A. Varga, Branch Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

ORB#1:DL
CParrish
10/3/84

ORB#1:DL
DNeighbors;ps
10/30/84

G-ORB#1:DL
SVarga
10/1/84

AD/CSE
Knight
10/1/84

OELD
10/1/84

AD:OR:DL
GLainas
10/1/84

D:DL
DEisenhut
10/1/84

Docket No. 50-280

DISTRIBUTION

Docket File	NRC PDR
L PDR	Gray 4
ORB#1 Rdg	CParrish
DEisenhut	HDenton
ORAB	JPartlow
OELD (BURNS)	EJordan
JNGrace	TBarnhart 4
ACRS 10	CMiles
SECY	RDiggs
Knight	GLainas

Mr. W. L. Stewart
Vice President - Nuclear Operations
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Dear Mr. Stewart:

The Commission today has issued the enclosed Order terminating the Order to Show Cause dated March 13, 1979, and the Order dated August 22, 1979.

This Order is issued because you have completed all piping and pipe support analyses associated with the Order to Show Cause dated March 13, 1979, and, all modifications resulting from these analyses have been completed.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Harold R. Denton, Director
Office of Nuclear Reactor Regulation

Enclosure:
Order

cc w/enclosure:
See next page

ORB#1:DL
CParrish
10/8/84

ORB#1:DL
JD...;ps
10/9/84

C-ORB#1:DL
SVarga
10/8/84

ADV/CSE
Knight
10/ /84

OELD
10/ /84

AD:OR:DL
GLainas
10/ /84

D:DL D:NRR
DEisenhut HDenton
10/ /84 10/ /84

*D/ENG
VOLLNER
10/3/84*

*- see note by
Steve Burns
10/15/84*

3

Mr. W. L. Stewart
Virginia Electric and Power Company

Surry Power Station
Units 1 and 2

cc: Mr. Michael W. Maupin
Hunton and Williams
Post Office Box 1535
Richmond, Virginia 23213

Attorney General
1101 East Broad Street
Richmond, Virginia 05602

Mr. J. L. Wilson, Manager
Post Office Box 315
Surry, Virginia 23883

Donald J. Burke, Resident Inspector
Surry Power Station
U.S. Nuclear Regulatory Commission
Post Office Box 166, Route 1
Surry, Virginia 23883

Mr. Sherlock Holmes, Chairman
Board of Supervisors of Surry County
Surry County Courthouse
Surry, Virginia 23683

W. T. Lough
Virginia Corporation Commission
Division of Energy Regulation
Post Office Box 1197
Richmond, Virginia 23209

Regional Radiation Representative
EPA Region III
Curtis Building - 6th Floor
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

Mr. J. H. Ferguson
Executive Vice President - Power
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

James P. O'Reilly
Regional Administrator - Region II
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

James B. Kenley, M.D., Commissioner
Department of Health
109 Governor Street
Richmond, Virginia 23219