

APR 27 1983

DISTRIBUTION
Dockets RDiggs
NRC PDR ASLAB
L PDR Gray
NSIC
ORB#1 Rdg
DEisenhut
OELD
JMTaylor
ELJordan
LJHarmon
ACRS-10
CParrish
DNeighbors
TBarnhart-8
LSchneider
DBrinkman
OPA

Docket Nos. 50-280
and 50-281

Mr. W. L. Stewart
Vice President - Nuclear Operations
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Dear Mr. Stewart:

The Commission has issued the enclosed Amendment No. 88 to Facility Operating License No. DPR-32 and Amendment No. 88 to Facility Operating License No. DPR-37 for the Surry Power Station, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications in response to your application transmitted by letter dated March 8, 1983.

These amendments revise the Technical Specifications to change the schedule requirements for functional testing of the 50 KIPS and above category snubbers. The functional testing is rescheduled when an engineering evaluation determines the failure mode to be non-generic.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

ORIGINAL SIGNED

Joseph D. Neighbors, Project Manager
Operating Reactors Branch #1
Division of Licensing

Enclosures:

1. Amendment No. 88 to DPR-32
2. Amendment No. 88 to DPR-37
3. Safety Evaluation
4. Notice of Issuance

cc w/enclosures:
See next page

8305090045 830427
PDR ADDCK 05000280
PDR

No legal objection to this amendment for PDR notice since SER review has not requested.

| | | | | | | | |
|---------|----------|---------------|----------|----------|----------|----------|--|
| OFFICE | ORB#1:DL | ORB#1:DL | ORB#1:DL | ADMOR:DL | OELD | AD/CSE | |
| SURNAME | CParrish | DNeighbors:dm | SVarga | GLatnas | LUTCHIN | KNIGHT | |
| DATE | 04/21/83 | 04/21/83 | 04/21/83 | 04/21/83 | 04/21/83 | 04/27/83 | |

Mr. W. L. Stewart
Virginia Electric and Power Company

cc: Mr. Michael W. Maupin
Hunton and Williams
Post Office Box 1535
Richmond, Virginia 23213

Mr. J. L. Wilson, Manager
P. O. Box 315
Surry, Virginia 23883

Donald J. Burke, Resident Inspector
Surry Power Station
U. S. Nuclear Regulatory Commission
Post Office Box 166
Route 1
Surry, Virginia 23883

Mr. Sherlock Holmes, Chairman
Board of Supervisors of Surry County
Surry County Courthouse, Virginia 23683

Attorney General
1101 East Broad Street
Richmond, Virginia 23219

Mr. James R. Wittine
Commonwealth of Virginia
State Corporation Commission
Post Office Box 1197
Richmond, Virginia 23209

Regional Radiation Representative
EPA Region III
Curtis Building - 6th Floor
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

Mr. J. H. Ferguson
Executive Vice President - Power
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

James P. O'Reilly
Regional Administrator - Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

DOCKET NO. 50-280

SURRY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 88
License No. DPR-32

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated March 8, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8305090051 830427
PDR ADCK 05000280
PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-32 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 88, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 27, 1983



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

DOCKET NO. 50-281

SURRY POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 88
License No. DPR-37

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated March 8, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-37 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 88, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications . . .

Date of Issuance: April 27, 1983

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 88 TO FACILITY OPERATING LICENSE NO. DPR-32

AMENDMENT NO. 88 TO FACILITY OPERATING LICENSE NO. DPR-37

DOCKET NOS. 50-280 AND 50-281

Revise Appendix A as follows:

Remove Pages

Insert Pages

4.17-3

4.17-3

4.17-4

4.17-4

4.17-5

4.17-5

2. Snubbers which appear inoperable as a result of visual inspections may be determined operable for the purpose of establishing the next visual inspection interval, providing that the cause of the rejection is clearly established and remedied for that particular snubber and for other snubbers that may be generically susceptible and the affected snubber is functionally tested in the as found condition and determined operable per Specification 4.17-D or 4.17-E, as applicable.
3. When the fluid port of a hydraulic snubber is found to be uncovered, the snubber shall be determined inoperable and cannot be determined operable via functional testing for the purpose of establishing the next visual inspection interval. All snubbers connected to an inoperable common hydraulic fluid reservoir shall be counted as inoperable snubbers:

C. Functional Tests

1. At least once per 18 months during shutdown, a representative sample of 10% of the total of each type of snubber used in the plant shall be functionally tested either in place or in a bench test.
2. The representative sample selected for functional testing shall include the various configurations, operating environments and the range of size and capacity of snubbers. This representative sample shall not, to the extent practicable, include those snubbers tested in a previous representative sample.
3. At least 25% of the snubbers in the representative sample shall include snubbers from the following three categories:
 - a. The first snubber away from each reactor vessel nozzle
 - b. Snubbers within 5 feet of heavy equipment (valve, pump, turbine, motor, etc.)

- c. Snubbers within 10 feet of the discharge from a safety relief valve.
4. Snubbers identified in Tables 4.17-1 and 4.17-2 as "Especially Difficult to Remove" or in "High Radiation Zones During Shutdown" shall also be included in the representative sample.*
 5. In addition to the regular sample, snubbers which failed the previous functional test shall be retested during the next test period. If a spare snubber has been installed in place of a failed snubber, then both the failed snubber (if it is repaired and installed in another position) and the spare snubber shall be retested. Test results of these snubbers may not be included for the re-sampling.
 6. For each snubber that does not meet the functional acceptance criteria of Specifications 4.17-D or 4.17-E, an additional 10% of that type of snubber shall be functionally tested.
 7. For snubbers of 50 kips and above that are extremely difficult to remove or in high radiation zones that fail the functional testing, an engineering evaluation is required to determine the failure mode. If the failure is determined to be non-generic, an additional 10% of that category will be tested during the next functional test period.

*Permanent or other exemptions from functional testing for individual snubbers in these categories may be granted by the Commission only if a justifiable basis for exemption is presented and/or snubber life destructive testing was performed to qualify snubber operability for all design conditions at either the completion of their fabrication or at subsequent date.

8. If any snubber selected for functional testing either fails to lockup or fails to move, i.e., frozen in place, the cause will be evaluated and if caused by manufacturer or design deficiency all snubbers of the same design subject to the same defect shall be functionally tested. This testing requirement shall be independent of the requirements stated above for snubbers not meeting the functional test acceptance criteria.
9. For the snubber(s) found inoperable, an engineering evaluation shall be performed on the components which are supported by snubber(s). The purpose of this engineering evaluation shall be to determine if the components supported by the snubber(s) were adversely affected by the inoperability of the snubber(s) in order to ensure that the supported component remains capable of meeting the designed service.

D. Hydraulic Snubbers Functional Test Acceptance Criteria

1. The hydraulic snubber functional test shall verify that:
 - a. Activity (restraining action) is achieved within the specified range of velocity or acceleration in both tension and compression.
 - b. Snubber bleed, or release rate, where required, is within the specified range in compression and tension. For snubbers specifically required to not displace under continuous load, the ability of the snubber to withstand load without displacement shall be verified.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 88 TO FACILITY OPERATING LICENSE NO. DPR-32
AND AMENDMENT NO. 88 TO FACILITY OPERATING LICENSE NO. DPR-37
VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION, UNIT NOS. 1 AND 2
DOCKET NOS. 50-280 AND 50-281

Introduction

By letter dated March 8, 1983, Virginia Electric and Power Company (the licensee) proposed amendments to Operating License Nos. DPR-32 and DPR-37 for the Surry Power Station, Unit Nos. 1 and 2. The proposal will change several functional test requirements for safety-related snubbers in the Technical Specifications.

Discussion and Evaluation

Eight paragraphs in the Technical Specifications are revised. Under title C. Functional Tests, paragraphs C. 2 through C.9 are rewritten to cover two aspects. The first one is that representative sampling will be used for functional tests. The second one relates to the action to be taken after inoperable snubbers are detected.

For plants with moderate numbers of snubbers (<500), a representative sample for each functional testing is desirable as it will provide a good cross section of the snubbers in service. However, it will be less useful if the same snubbers which were tested in a previous representative sample are to be tested again. Paragraphs C.2 through C.5 are therefore acceptable except that a sentence to prevent the testing of the same snubbers each time has been added. The licensee agrees with this change. Paragraph C.5 delineates that for every inoperable snubber discovered in the test, an additional sample of 10% of the total snubbers of the same type which was found to be inoperable will be tested. Paragraphs C.8 and C.9 state that engineering evaluation should be conducted to assess whether the cause of a snubber which failed to lockup or to move is a generic one, and whether any damage has incurred on the supported components. They are consistent with the present NRC Standard Technical Specifications and are acceptable.

B305090062 B30427
PDR ADOCK 05000280
PDR

Paragraph C.7 states that for the failure of large snubbers (50 kips or more rated capacity) located in extremely difficult to move areas or in high radiation zones an evaluation is required to determine the failure mode. If the cause of failure is determined not to be generic, the required additional 10% of that category to be tested will be performed in the next functional test. If the cause of failure is determined to be generic, the required additional test will be performed immediately. This change does not change the basic NRC position that generic failures are more serious and should be remedied immediately. However, for failures which are not generic, a relaxation of the testing until the next functional test does not pose a significant increase in the probability or consequences of an accident since the failures are specific to the failed snubber. The proposed paragraph is acceptable.

Based on our review of the proposed Technical Specifications, we conclude that the proposal is acceptable.

Environmental Consideration

We have determined that the amendments do not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendments involve an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of these amendments.

Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendments do not involve a significant increase in the probability or consequences of an accident previously evaluated, do not create the possibility of an accident of a type different from any evaluated previously, and do not involve a significant reduction in a margin of safety, the amendments do not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Date: April 27, 1983

Principal Contributor:
H. Shaw

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NOS. 50-280 AND 50-281VIRGINIA ELECTRIC AND POWER COMPANYNOTICE OF ISSUANCE OF AMENDMENTS TO FACILITY
OPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 88 to Facility Operating License No. DPR-32 and Amendment No. 88 to Facility Operating License No. DPR-37 issued to Virginia Electric and Power Company (the licensee), which revised Technical Specifications for operation of the Surry Power Station, Unit Nos. 1 and 2, respectively, (the facilities), located in Surry County, Virginia. The amendments are effective as of the date of issuance.

The amendments revise the Technical Specifications to change the schedule requirements for functional testing of the 50 KIPS and above category snubbers. The functional testing is rescheduled when an engineering evaluation determines the failure mode to be non-generic.

The application for the amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice was not required since these amendments do not involve a significant hazards consideration.

- 2 -

The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of these amendments.

For further details with respect to this action, see (1) the application for amendments dated March 8, 1983, (2) Amendment Nos. 88 and 88 to License Nos. DPR-32 and DPR-37, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Swem Library, College of William and Mary, Williamsburg, Virginia 23185. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 27th day of April, 1983.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing