


APR 12 1982

DISTRIBUTION
 Docket
 NRC PDR
 L PDR
 NSIC
 ORB#1 Rdg
 DEisenhut
 OELD
 IE
 ACRS-10
 TBarnhart
 DBrinkman
 LSchneider
 OPA
 RDiggs
 CParrish
 DNeighbors
 ASLAB
 Gray File

Docket Nos. 50-280
and 50-281

Mr. R. H. Leasburg
 Vice President - Nuclear Operations
 Virginia Electric and Gas Company
 Post Office Box 26666
 Richmond, Virginia 23261



Dear Mr. Leasburg:

On February 2, 1982, we issued Amendment Nos. 74 and 75 to Surry Power Station, Unit Nos. 1 and 2, respectively. These amendments revised Technical Specification 3.12 but contained an error. The word "detectors" should have been "thimbles" on pages 3.12-15 and 3.12-16. The word thimbles is consistent with the Safety Evaluation Report issued at that time.

Enclosed are corrected pages which should be substituted for those issued on February 2, 1982.

Sincerely,

Original signed by:
 S. A. Varga

Steven A. Varga, Chief
 Operating Reactors Branch #1
 Division of Licensing

Enclosures:
 Corrected Technical Specification
 Pages 3.12-15 and 3.12-16

cc w/enclosures:
 See next page

8204300070

OFFICE	ORB#1;DL CP	ORB#2;DL	ORB#T;DL				
SURNAME	CParrish	DNeighbors	SVarga				
DATE	04/9/82	04/12/82:ds	04/12/82				

Mr. R. H. Leasburg
Virginia Electric and Power Company

cc: Mr. Michael W. Maupin
Hunton and Williams
Post Office Box 1535
Richmond, Virginia 23213

Mr. J. L. Wilson, Manager
P. O. Box 315
Surry, Virginia 23883

Swem Library
College of William and Mary
Williamsburg, Virginia 23185

Donald J. Burke, Resident Inspector
Surry Power Station
U. S. Nuclear Regulatory Commission
Post Office Box 166
Route 1
Surry, Virginia 23883

Mr. Sherlock Holmes, Chairman
Board of Supervisors of Surry County
Surry County Courthouse, Virginia 23683

Commonwealth of Virginia
Council on the Environment
903 Ninth Street Office Building
Richmond, Virginia 23219

Attorney General
1101 East Broad Street
Richmond, Virginia 23219

Mr. James R. Wittine
Commonwealth of Virginia
State Corporation Commission
Post Office Box 1197
Richmond, Virginia 23209

Regional Radiation Representative
EPA Region III
Curtis Building - 6th Floor
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

Mr. J. H. Ferguson
Executive Vice President - Power
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

James P. O'Reilly
Regional Administrator - Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

It should be noted that the enthalpy rise factors are based on integrals and are used as such in the DNB and LOCA calculations. Local heat fluxes are obtained by using hot channel and adjacent channel explicit power shapes which take into account variations in radial (x-y) power shapes throughout the core. Thus, the radial power shape at the point of maximum heat flux is not necessarily directly related to the enthalpy rise factors. The results of the loss of coolant accident analyses are conservative with respect to the ECCS acceptance criteria as specified in 10 CFR 50.46 using an upper bound envelope of 2.18 times the hot channel factor normalized operating envelope given by TS Figure 3.12-8.

When an F_Q measurement is taken, measurement error, manufacturing tolerances, and the effects of rod bow must be allowed for. Five percent is the appropriate allowance for measurement error for a full core map (≥ 38 thimbles, including a minimum of 2 thimbles per core quadrant, monitored) taken with the movable incore detector flux mapping system, three percent is the appropriate allowance for manufacturing tolerances, and five percent is the appropriate allowance for rod bow. These uncertainties are statistically combined and result in a net increase of 1.08 that is applied to the measured value of F_Q .

In the specified limit of $F_{\Delta H}^N$ there is an eight percent allowance for uncertainties, which means that normal operation of the core is expected to result in $F_{\Delta H}^N \leq 1.55 (1+0.2 (1-P))/1.08$. The logic behind the larger uncertainty in this case is that (a) normal perturbations in the radial power shape (e.g., rod misalignment) affect $F_{\Delta H}^N$, in most cases without necessarily affecting F_Q , (b) the operator has a direct influence on F_Q through movement of rods and can limit it to the desired value; he has no direct control over $F_{\Delta H}^N$, and (c) an error in the predictions for radial power shape, which may be detected during startup physics tests and which may influence F_Q , can

be compensated for by tighter axial control. Four percent is the appropriate allowance for measurement uncertainty for $F_{\Delta H}^N$ obtained from a full core map (≥ 38 thimbles, including a minimum of 2 thimbles per core quadrant, monitored) taken with the movable incore detector flux mapping system.

Measurement of the hot channel factors are required as part of startup physics tests, during each effective full power month of operation, and whenever abnormal power distribution conditions require a reduction of core power to a level based on measured hot channel factors. The incore map taken following core loading provides confirmation of the basic nuclear design bases including proper fuel loading patterns. The periodic incore mapping provides additional assurance that the nuclear design bases remain inviolate and identify operational anomalies which would, otherwise, affect these bases.

For normal operation, it has been determined that, provided certain conditions are observed, the enthalpy rise hot channel factor $F_{\Delta H}^N$ limit will be met. These conditions are as follows:

1. Control rods in a single bank move together with no individual rod insertion differing by more than 15 inches from the bank demand position. An indicated misalignment limit of 13 steps precludes a rod misalignment no greater than 15 inches with consideration of maximum instrumentation error.
2. Control rod banks are sequenced with overlapping banks as shown in TS Figures 3.12-1A, 3.12-1B, and 3.12-2.
3. The full length control bank insertion limits are not violated.
4. Axial power distribution control procedures, which are given in terms of flux difference control and control bank insertion limits are observed. Flux difference refers to the difference