


PMB 016

Docket Nos. 50-280
and 50-281

JUL 10 1981

DISTRIBUTION

Dockets RDiggs
NRC PDR JHeltemes, AEOD
L PDR Gray File-4
TERA
NSIC
ORB#1 Rdg
DEisenhut
JOlshinski
CParrish
DNeighbors
OELD
IE-3
GDeegan-8
ACRS-10
OPA
SECY



Mr. J. H. Ferguson
Executive Vice President - Power
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Dear Mr. Ferguson:

The Commission has issued the enclosed Order confirming your commitments for TMI related requirements for the Surry Power Station. This Order is based on your letters dated December 15, 1980, December 31, 1980, January 19, February 27, May 29, and July 6, 1981, and the references stated therein to implement those requirements set forth in NUREG-0737 for which the staff requested completion before June 30, 1981. Explicit statements of these requirements are set forth in the Attachment to the Order.

It is the Commission's intent in issuing this Order to encourage completion of items consistent with the staff's recommended schedule. However, certain of your proposed schedule exceptions are acceptable. Therefore, you should proceed with implementation of these items in accordance with your proposed schedule. Your proposed technical and schedule exceptions for other items contained in NUREG-0737 will be the subject of future correspondence.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

AUG 5 1981

Original signed by:
S. A. Varga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
Order

cc w/enclosure:
See next page

8107290116 810710
PDR ADOCK 05000280
PDR

*Previous concurrences see next page

OFFICE	ORB#1:DL*	ORB#1:DL*	ORAB*	ORB#1:DL*	AD/OR:DI	OELD	D/D
SURNAME	CParrish	DNeighbors	JOlshinski	SVarga	TMovak		DEisenhut
DATE	7/ /81	7/ /81:ds	7/ /81	7/ /81	7/ /81	7/ /81	7/ /81

DISTRIBUTION
 Dockets JHeltemes, AEOD
 NRC PDR
 L PDR
 TERA
 NSIC
 ORB#1 Rdg
 DEisenhut
 JOlshinski
 CParrish
 DNeighbors
 OELD
 IE-3
 GDeegan-8
 ACRS-10
 OPA
 SECY
 RDiggs

Docket Nos. 50-280
 and 50-281

Mr. J. H. Ferguson
 Executive Vice President - Power
 Virginia Electric and Power Company
 Post Office Box 26666
 Richmond, Virginia 23261

Dear Mr. Ferguson:

The Commission has issued the enclosed Order for the Surry Power Station, Unit Nos. 1 and 2, confirming your commitments on TMI related requirements. This order is based on your letters dated December 15, 1980, December 31, 1980, January 19, 1981, February 27, and May 29, 1981 committing to implement those requirements set forth in NUREG-0737 for which the staff requested completion before June 30, 1981. Explicit statements of these requirements are set forth in the Attachment to the Order.

It is the Commission's intent in issuing this Order to encourage completion of items consistent with the staff's recommended schedule. However, certain of your proposed schedule exceptions are acceptable. Therefore, you should proceed with implementation of these items in accordance with your proposed schedule. Your proposed technical and schedule exceptions for other items contained in NUREG-0737 will be the subject of future correspondence.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Steven A. Varga, Chief
 Operating Reactors Branch #1
 Division of Licensing

Enclosure:
 Order

cc: Service List

OFFICE	ORB#1:DL	ORB#1:DL	ORAB	ORB#1:DL	AD/OR:DL	OELD	D/DL
SURNAME	CParrish	DNeighbors	JOlshinski	Syan	TNovak		DEisenhut
DATE	6/22/81	6/22/81:ds	6/ /81	6/22/81	6/ /81	6/ /81	6/ /81

Mr. J. H. Ferguson
Virginia Electric and Power Company

cc: Mr. Michael W. Maupin
Hunton and Williams
Post Office Box 1535
Richmond, Virginia 23213

Mr. J. L. Wilson, Manager
P. O. Box 315
Surry, Virginia 23883

Swem Library
College of William and Mary
Williamsburg, Virginia 23185

Donald J. Burke, Resident Inspector
Surry Power Station
U. S. Nuclear Regulatory Commission
Post Office Box 166
Route 1
Surry, Virginia 23883

Mr. Sherlock Holmes, Chairman
Board of Supervisors of Surry County
Surry County Courthouse, Virginia 23683

Commonwealth of Virginia
Council on the Environment
903 Ninth Street Office Building
Richmond, Virginia 23219

Attorney General
1101 East Broad Street
Richmond, Virginia 23219

Mr. James R. Wittine
Commonwealth of Virginia
State Corporation Commission
Post Office Box 1197
Richmond, Virginia 23209

U. S. Environmental Protection Agency
Region III Office
ATTN: EIS COORDINATOR
Curtis Building - 6th Floor
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

UNITED STATES OF AMERICANUCLEAR REGULATORY COMMISSION

In the Matter of)

VIRGINIA ELECTRIC AND POWER COMPANY)

(Surry Power Station,
Unit Nos. 1 and 2))Docket Nos. 50-280
and 50-281ORDER CONFIRMING LICENSEE COMMITMENTS ON
POST-TMI RELATED ISSUES

I.

The Virginia Electric and Power Company (the licensee) is the holder of Facility Operating License Nos. DPR-32 and DPR-37, which authorize the operation of the Surry Power Station, Unit Nos. 1 and 2 (the facilities) at steady-state power levels not in excess of 2441 megawatts thermal for each unit. The facilities consist of pressurized water reactors (PWRs) located at the licensee's site in Surry County, Virginia.

II.

Following the accident at Three Mile Island Unit No. 2 (TMI-2) on March 28, 1979, the Nuclear Regulatory Commission (NRC) staff developed a number of proposed requirements to be implemented on operating reactors and on plants under construction. These requirements include Operational Safety, Siting and Design, and Emergency Preparedness and are intended to provide substantial additional protection for the operation of nuclear facilities based on the

experience from the accident at TMI-2 and the official studies and investigations of the accident. The staff's proposed requirements and schedule for implementation are set forth in NUREG-0737, "Clarification of TMI Action Plan Requirements." Among these requirements are a number of items, consisting of hardware modifications, administrative procedure implementation and specific information to be submitted by the licensee, scheduled to be completed on or before June 30, 1981 (see the Attachment to this Order). NUREG-0737 was transmitted to each licensee and applicant by an NRC letter from my office dated October 31, 1980, which is hereby incorporated by reference. In that letter, it was indicated that although the NRC staff expected each requirement to be implemented in accordance with the schedule set forth in NUREG-0737, the staff would consider licensee requests for relief from staff proposed requirements and their associated implementation dates.

III.

The licensee's submittals dated December 15, 1980, December 30, 1980, January 19, February 27, May 29, and July 6, 1981, and the references stated therein, which are incorporated herein by reference, committed to complete each of the actions specified in the Attachment. The licensee's submittals included a modified schedule for submittal of certain information. The staff has reviewed the licensee's submittals and determined that the licensee's modified schedule is acceptable based on the following:

ATTACHMENT

NUREG 0737 REQUIREMENTS

<u>Item</u>	<u>Title</u>	<u>Applicability</u>	<u>Specific Requirement</u>	<u>Impl/Doc Subm Due Dates</u>
I.A.1.1	STA	ALL	(a) Provide STA coverage by degreed individuals (or equivalent), trained to licensee's program.	1/1/81
			(b) Submit description of current training program and demonstrate compliance with 10-30-79 letter.	1/1/81
			(c) Submit description of long term training program.	1/1/81
I.A.2.1	Reactor Operator Qualification	ALL	Submit description of and implement Upgraded Training Program.	8/1/80
I.C.1	Accident Procedures	ALL	(a) Submit reanalyses of inadequate core cooling and propose guidelines for emergency procedures, OR propose schedule and justify delays.	1/1/81
			(b) Submit reanalysis of transients and accidents for emergency procedures, OR propose schedule and justify delays.	1/1/81
I.C.5	Feedback of Operating Experience	ALL	Implement procedures for feedback of operating experience (no documentation submittal is required).	1/1/81
I.C.6	Correct Performance or Operating Activities	ALL	Implement procedures to verify correct performance of operating activities (no documentation submittal is required).	1/1/81

<u>Item</u>	<u>Title</u>	<u>Applicability</u>	<u>Specific Requirement</u>	<u>Impl/Doc Subm Due Dates</u>
II.B.2	Shielding	ALL	(a) Have available design details for vital area modifications.	1/1/81
			(b) Submit technical deviations to staff positions.	1/1/81
II.B.3	Post-Accident Sampling	ALL	Submit description of deviations from staff positions.	1/1/81
II.B.4	Training to Mitigate Core Damage	ALL	(a) Have available for review a training program for mitigating core damage (no documentation submittal required)	1/1/81
			(b) Implement training program (no documentation submittal required).	4/1/81
II.D.1	Performance Testing of RV/SRV's	ALL	(a) Submit test program (both BWR/PWR's).	7/1/80 (PWRs) 10/1/80 (BWRs)
			(b) Submit qualification program for PWR's block valve.	1/1/81 (PWRs)
II.E.1.2	Aux Feed Initiation and Flow	PWRs	(a) Submit final design and documentation on safety grade flow indication.	1/1/81
			(b) Submit final design and documentation on safety grade flow initiation.	1/1/81
II.E.4.2	Containment Isolation	ALL	(a) Submit documentation justifying minimum containment pressure setpoint for isolation of non-essential penetrations.	1/1/81
			(b) Submit statement that purge valves not meeting CSB 6-4 (or interim position) are sealed and verification is performed every 31 days.	1/1/81

<u>Item</u>	<u>Title</u>	<u>Applicability</u>	<u>Specific Requirement</u>	<u>Impl/Doc Subm Due Dates</u>
II.F.1	Post-Accident Monitoring	ALL	a. For noble gas monitor and Iodine/particulate sampling and analysis submit description and justification for deviations from staff requirements.	1/1/81
			b. Have available the final design information for noble gas monitor and iodine/particulate sampling and analysis.	1/1/81
II.F.2	Inst. for Inadequate Core Cooling	ALL	Submit a report detailing the planned instrumentation system for monitoring inadequate core cooling.	1/1/81
II.K.2.10	Antic. Trip on LOFW and TT	B&W	Submit final design for anticipatory trip as described in NUREG 0737.	1/1/81
II.K.2.13	Thermal Mechanical Report	B&W	Submit report on effects of Hi Pressure Injection on vessel integrity for SB LOCA with no Aux Feedwater.	1/1/81
II.K.3.2	PORV/SV Failures	PWR	Submit report on SB LOCA and probability of failure of PORV/SV/RV.	1/1/81
II.K.3.3	SRV/SV Failures & Challenges	ALL	Submit report (historical and annually thereafter) of SRV/SV failures and challenges.	1/1/81
II.K.3.7	PORV Opening Probability	B&W	Submit report on the probability of a PORV opening during an over-pressurization transient.	1/1/81
II.K.3.9	PID Controller Modification	Selected <u>W</u> plants	Modify the Proportional Integral Derivative Controller (as recommended by W). Advise NRC when modification is completed.	12/1/80
II.K.3.12	Anticipatory Trip on Turbine Trip	<u>W</u>	Submit confirmation of Anticipatory Trip. If not currently implemented, submit modification design and schedule for implementation.	1/1/81

<u>Item</u>	<u>Title</u>	<u>Applicability</u>	<u>Specific Requirement</u>	<u>Impl/Doc Subm Dates</u>
II.K.3.13	Separation of HPCI/RCIC Initiation Levels; Auto Restart of RCIC	BWRs w/HPCI/RCIC	Submit results of evaluation and proposed modification as appropriate.	1/1/81
II.K.3.16	Reduce Challenges to RV's	BWR	Submit report on actions planned to reduce RV challenges.	4/1/81
II.K.3.17	ECCS System Outages	ALL	Submit report on ECCS outages and propose changes to reduce outages.	1/1/81
II.K.3.18	ADS Logic Modifications	BWR	Submit report of feasibility of ADS system logic changes to eliminate need for manual actuation.	4/1/81
II.K.3.21	CSS/CPCI Restart	BWR	Submit report of evaluation, proposed modifications and analysis to satisfy staff positions.	1/1/81
II.K.3.22	RCIC Suction	BWR w/RCIC	Implement procedures and document verification of this change.	1/1/81
II.K.3.27	Common Reference for H ₂ O Level Instruments	BWR	Implement change and submit documentation of changes.	1/1/81
II.K.3.29	Isolation Condensor Performance	BWR w/ICs	Submit evaluation of I.C. performance.	4/1/81
II.K.3.30	SB LOCA Methods	ALL	Submit outline of program for model.	11/15/80
II.K.3.44	Fuel Failure	BWR	Submit evaluation to verify no fuel failure.	1/1/81
II.K.3.45	Manual Depressurization	BWR	Submit evaluation on other than ADS method for depressurization.	1/1/81

<u>Item</u>	<u>Title</u>	<u>Applicability</u>	<u>Specific Requirement</u>	<u>Impl/Doc Subm Due Dates</u>
III.D.3.3	Improved Inplant Iodine Monitoring	ALL	Have available means to accurately measure airborne radioiodine inplant during an accident.	1/1/81
III.D.3.4	Control Room Habitability	ALL	a. Submit control room habitability evaluation information.	1/1/81
			b. Submit modifications necessary to assure CR habitability with a schedule for completion.	1/1/81

Static Control Systems 3M

223-2SW 3M Center
St. Paul, Minnesota 55144
612/733 9420

PDR

RECEIVED
USNRC

'81 JUL 17 P3:47

OFFICE OF
INTERNATIONAL
PROGRAMS
3M

July 14, 1981

XB001082

11001034

Amendment No. 01

Mr. Marvin R. Peterson
Assistant Director
Export/Import & International Safeguards
Office of International Programs
United States Nuclear Regulatory Commission
Washington, D.C. 20555

REFERENCE: XB001082

Dear Mr. Peterson:

RECEIVED
JUL 21 1981
U.S. NUCLEAR REGULATORY
COMMISSION

Pursuant to our recent telephone conversation this letter constitutes our request for an amendment of Export License XB001082. This license authorizes us to export H-3 contained in metal foils, assembled in static electricity monitors. Each device contains approximately 0.2 ci of tritium (H-3). This license presently expires on October 1, 1981.

We would request that the following changes be made in the license as listed below:

1. The licensee remains 3M Company, Static Control Systems. However, change the zip code from 55101 to 55144.
2. The ultimate consignee in the foreign country should be changed to allow export to any country except those embargoed under 10 CFR 110.28. Per our telephone conversation, you indicated this would be acceptable.
3. The total quantity allowed should be increased to 200 ci of tritium (H-3). At our present rate of export, this will cover us for several more years.

All other terms and conditions of the license as presently written are acceptable.

*Copy to PDR and ACC

7-20-81

8107290109 810714
PDR XPORT
XB-1082

PDR

Mr. Marvin R. Peterson
Page 2
July 14, 1981

You also indicated that there would be an amendment to Part 110 of 10 CFR which will establish a general license for the export of these products in the reasonably near future. We look forward to that since the level of control presently established for these devices is beyond that for similar products such as accelerator targets, luminous paints, etc.

If you need any further information or require any additional paperwork to act on this request, please contact me personally at any time. I can be reached at (612) 733-3964.

Very truly yours,



T. N. Lahr
Regulatory Affairs Manager


TNL/sam/B

CC:
R. G. Wissinck
J. P. Ryan

This request for information was approved by OMB under clearance number 3150-0065 which expires June 30, 1983. Comments on burden and duplication may be directed to the Office of Management and Budget, Reports Management, Room 3208, New Executive Office Building, Washington, D. C.

This Order is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Purple, Deputy Director
Division of Licensing
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland
this 10th day of July,
1981

Attachment:
NUREG-0737 Requirements

V.

Any person who has an interest affected by this Order may request a hearing within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555. A copy shall also be sent to the Executive Legal Director at the same address. If a hearing is requested by a person other than the licensee, that person shall describe, in accordance with 10 CFR 2.714(a)(2), the nature of the person's interest and the manner in which the interest is affected by this Order. A REQUEST FOR HEARING SHALL NOT STAY THE IMMEDIATE EFFECTIVENESS OF THIS ORDER.

If a hearing is requested by the licensee or other persons who have an interest affected by this Order, the Commission will issue an Order designating the time and place of any such hearing.

If a hearing is held concerning this Order, the issue to be considered at the hearing shall be whether, on the basis of the information set forth in Sections II and III of this Order, the licensee should comply with the conditions set forth in Section IV of this Order.

The licensee's schedule for submittal of information in some instances does not meet the staff's specified submittal dates. Most of the information requested by the staff describes how the licensee is meeting the guidance of NUREG-0737. Therefore, this deferral of the licensee submittal will not alter the implementation of plant modifications. Therefore, plant safety is not affected by this modification in schedule for the submittal of information.

I have determined that these commitments are required in the interest of public health and safety, and therefore, should be confirmed by ORDER.

IV.

Accordingly, pursuant to Sections 103, 161i, 161o, and 182 of the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS HEREBY ORDERED EFFECTIVE IMMEDIATELY THAT the licensee shall comply with the following conditions:

The licensee shall satisfy the specific requirements described in the Attachment to this Order (as appropriate to the licensee's facilities) as early as practicable but no later than 60 days after the effective date of the ORDER.