

Indiana Michigan
Power Company
Cook Nuclear Plant
500 Circle Drive
Buchanan, MI 49107
616-465-5301



August 31, 2001

C0801-14
10 CFR 50.55a

Docket No.: 50-315

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Stop O-P1-17
Washington, DC 20555-0001

Donald C. Cook Nuclear Plant Unit 1
NIS-1 REPORT FOR INSERVICE INSPECTION ACTIVITIES

Reference: Letter from S. A. Greenlee, Indiana Michigan Power Company, to Nuclear Regulatory Commission Document Control Desk, "Donald C. Cook Nuclear Plant Unit 1, NIS-1 Report for Inservice Inspection Activities," submittal C0301-04, dated March 22, 2001.

In the referenced letter, Indiana Michigan Power Company (I&M) submitted the summary report for Unit 1 inservice inspection activities. At the time of the submittal, I&M was unable to locate the documentation required to complete the NIS-2 forms (Owner's Report for Repair or Replacements) for three components, 1-SV-45A, 1-SV-45B, and 1-SV-45C, and I&M committed to provide the NIS-2 forms for these components by September 30, 2001. The attachment to this letter provides the NIS-2 forms for the components.

This letter contains no new commitments. Should you have any questions, please contact Mr. Ronald W. Gaston, Manager of Regulatory Affairs, at (616) 697-5020.

Sincerely,

S. A. Greenlee
Director of Design Engineering and Regulatory Affairs

/bjb

Attachment

A047

c: J. E. Dyer
MDEQ - DW & RPD, w/o attachment
NRC Resident Inspector
R. Whale, w/o attachment

ATTACHMENT TO C0801-14

NIS-2 FORMS FOR 1-SV-45A, 1-SV-45B, AND 1-SV-45C

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions for the ASME Code Section XI

1. Owner: AMERICAN ELECTRIC POWER Date Performed: 10-09-98
P.O. Box 60 Fort Wayne IN 46801 Unit# 1
2. Plant: D.C.Cook Nuclear Power Plant Job Order# R72608-06
One Cook Place, Bridgman, MI 49106 Component# 1-SV-45A
3. Work Performed by: AEP/D.C. COOK Maintenance Department
4. Identification of System: Reactor Coolant System
5. (a) Applicable Construction Code: ANSI-B31.1 1983 _____, Code Case: _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1989, No Addenda
6. **Identification of Components Repaired or Replaced and Replacement Components**

Name of Component	ASME,ASTM or AISI designation:	Name of Manufacture	Material Identification: M&E# ASP# P.O.#	Year built	Repaired Or Replaced	ASME Code Stamped Yes/No
1-SV-45A	EXISTING		M&E 30-036392 ASP 20615	N/A	Repaired	NO
1"x 8 UNC Rod	ASME SA 453 GR 660		M&E 30-212309 ASP 18713	N/A	Replaced	NO

7. Hydrostatic N/A Pneumatic N/A Nominal Operating Pressure _____
 NDE: PT/VT-1, 2 & 3 Pressure: psi N/A Test Temperature N/A F.

Description of work: **Change out of the SV-45's (each outage)**

Job Order/File: R 72608-06 ISI Class 1

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair and/or replacement conforms to the rules of the ASME Code, Section XI repair or replacement.

Type Code Symbol Stamp NA

Certificate of Authorization No. NA Expiration Date NA

Signed: *Dewayne Timmons* Date 8-8-01
Dewayne Timmons, welding supervisor
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler Pressure Vessel Inspectors and the State or Providence of Michigan and employed by FMIC of Johnston R I.

have inspected the components described in this Owner's Report during the period 2-10-99 to 12-15-00, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or of loss of any kind arising from or connected with this inspection.

M. J. Minterbaugh Commissions Mich 00055, EN D N&I
Inspector's Signature National Board, State, Province, Endorsements

Date: AUGUST 8 2001

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions for the ASME Code Section XI

1. Owner: AMERICAN ELECTRIC POWER Date Performed: 10-09-98

P.O. Box 60 Fort Wayne IN 46801

Unit# 1

2. Plant: D.C.Cook Nuclear Power Plant

Job Order# R72609-06

One Cook Place, Bridgman, MI 49106

Component# 1-SV-45B

3. Work Performed by: AEP/D.C. COOK Maintenance Department

4. Identification of System: Reactor Coolant System

5. (a) Applicable Construction Code: ANSI-B31.1 1983 _____, Code Case: _____

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1989, No Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	ASME,ASTM or AISI designation:	Name of Manufacture	Material Identification: M&E# ASP# P.O.#	Year built	Repaired Or Replaced	ASME Code Stamped Yes/No
1-SV-45B	EXISTING		M&E 30-036392 ASP 20615	N/A	Repaired	NO
1"x 8 UNC Rod	ASME SA 453 GR 660		M&E 30-212309 ASP 18713	N/A	Replaced	NO

7. Hydrostatic N/A Pneumatic N/A Nominal Operating Pressure _____

NDE: PT/VT-1, 2 & 3 Pressure: psi N/A Test Temperature N/A F.

Description of work: Change out of the SV-45's (each outage)

Job Order/File: R 72609-06 / ISI Class 1

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair and/or replacement conforms to the rules of the ASME Code, Section XI repair or replacement.

Type Code Symbol Stamp NA

Certificate of Authorization No. NA Expiration Date NA

Signed: Dewayne Timmons, Welding supervisor Date 8-8-01
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler Pressure Vessel Inspectors and the State of Providence of Michigan and employed by FMIC of Johnston R I.

have inspected the components described in this Owner's Report during the period 2-10-99 to 2-15-00, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or of loss of any kind arising from or connected with this inspection.

M. J. M... Commissions Michigan, E.I.P. N.I.
Inspector's Signature National Board, State, Province, Endorsements

Date: August 8 20 01

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions for the ASME Code Section XI

1. Owner: AMERICAN ELECTRIC POWER Date Performed: 10-09-98
P.O. Box 60 Fort Wayne IN 46801 Unit# 1
2. Plant: D.C.Cook Nuclear Power Plant Job Order# R72610-06
One Cook Place, Bridgman, MI 49106 Component# 1-SV-45C
3. Work Performed by: AEP/D.C. COOK Maintenance Department
4. Identification of System: Reactor Coolant System
5. (a) Applicable Construction Code: ANSI-B31.1 1983 _____, Code Case: _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1989, No Addenda
6. **Identification of Components Repaired or Replaced and Replacement Components**

Name of Component	ASME,ASTM or AISI designation:	Name of Manufacture	Material Identification: M&E# ASP# P.O.#	Year built	Repaired Or Replaced	ASME Code Stamped Yes/No
1-SV-45C	EXISTING		M&E 30-036392 ASP 20615	N/A	Repaired	NO
1"x 8 UNC Rod	ASME SA 453 GR 660		M&E 30-212309 ASP 18713	N/A	Replaced	NO
1 3/8" x 8 UNC Rod	ASME SA 453 GR 660		M&E 30-212317 ASP 15984	N/A	Replaced	NO

7. Hydrostatic N/A Pneumatic N/A Nominal Operating Pressure _____
 NDE: PT/VT-1, 2 & 3 Pressure: psi N/A Test Temperature N/A F.

Description of work: Change out of the SV-45's (each outage)

Job Order/File: R 72610-06 ISI Class 1

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair and/or replacement conforms to the rules of the ASME Code, Section XI repair or replacement.

Type Code Symbol Stamp NA

Certificate of Authorization No. NA Expiration Date NA

Signed: Dewayne Timmons, welding supervisor Date 8-8-01
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler Pressure Vessel Inspectors and the State of Providence of Michigan and employed by FMIC of Johnston R I.

have inspected the components described in this Owner's Report during the period 2-10-99 to 12-15-00, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or of loss of any kind arising from or connected with this inspection.

MA [Signature] Commissions MICHIGAN, ENDS IF
Inspector's Signature National Board, State, Province, Endorsements

Date: AUGUST 8 2001