Control Rod OPERABILITY 3.1.3

107	т т.	~	
ΔI		ŧΠ	\sim
110		v	10

I

	CONDITION	REQUIRED ACTION	COMPLETION TIME
C.	(continued)	C.2 Disarm the associated CRD.	4 hours
D.	NOTE Not applicable when THERMAL POWER > 10% RTP.	D.1 Restore compliance with BPWS. <u>OR</u>	4 hours
	Two or more inoperable control rods not in compliance with banked position withdrawal sequence (BPWS) and not separated by two or more OPERABLE control rods.	D.2 Restore control rod to OPERABLE status.	4 hours
E.	Required Action and associated Completion Time of Condition A, C, or D not met. <u>OR</u>	E.1 Be in MODE 3.	12 hours
	Nine or more control rods inoperable.		

3.1 REACTIVITY CONTROL SYSTEMS

3.1.6 Control Rod Pattern

- LCO 3.1.6 OPERABLE control rods shall comply with the requirements of the banked position withdrawal sequence (BPWS).
- | APPLICABILITY: MODES 1 and 2 with THERMAL POWER \leq 10% RTP.

ACTIONS

	CONDITION		REQUIRED ACTION	COMPLETION TIME
Α.	One or more OPERABLE control rods not in compliance with BPWS.	A.1	Affected control rods may be bypassed in Rod Action Control System (RACS) in accordance with SR 3.3.2.1.9. Move associated control rod(s) to correct position.	8 hours
		<u>OR</u> A.2	Declare associated control rod(s) inoperable.	8 hours

(continued)

.

Control Rod Block Instrumentation 3.3.2.1 `

-

SURVEILLANCE REQUIREMENTS (continued)

			FREQUENCY	
ł	SR	3.3.2.1.4	Not required to be performed until 1 hour after THERMAL POWER is ≤ 10% RTP in MODE 1.	
			Perform CHANNEL FUNCTIONAL TEST.	92 days
1	SR	3.3.2.1.5	Calibrate the low power setpoint trip units. The Allowable Value shall be > 10% RTP and \leq 35% RTP.	92 days
	SR	3.3.2.1.6	Verify the RWL high power Function is not bypassed when THERMAL POWER is > 68.2% RTP.	92 days
	SR	3.3.2.1.7	Perform CHANNEL CALIBRATION.	184 days
	SR	3.3.2.1.8	Not required to be performed until 1 hour after reactor mode switch is in the shutdown position.	
			Perform CHANNEL FUNCTIONAL TEST.	18 months
	SR	3.3.2.1.9	Verify the bypassing and movement of control rods required to be bypassed in Rod Action Control System (RACS) is in conformance with applicable analyses by a second licensed operator or other qualified member of the technical staff.	Prior to and during the movement of control rods bypassed in RALS

Control Rod Block Instrumentation 3.3.2.1

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	SURVE ILLANCE REQUIREMENTS
1. Rod Pattern Control System			
a. Rod withdrawal limiter	(a)	2	SR 3.3.2.1.1 SR 3.3.2.1.6 SR 3.2.2.1.2
	(b)	2	SR 3.3.2.1.2 SR 3.3.2.1.5 SR 3.3.2.1.7 SR 3.3.2.1.9
b. Rod pattern controller	1 ^(c) .2	2	SR 3.3.2.1.3 SR 3.3.2.1.4 SR 3.3.2.1.5 SR 3.3.2.1.7 SR 3.3.2.1.9
2. Reactor Mode Switch – Shutdown Position	(d)	2	SR 3.3.2.1.8

Table 3.3.2.1-1 (page 1 of 1) Control Rod Block Instrumentation

(a) THERMAL POWER greater than the HPSP.

(b) THERMAL POWER > 35% RTP and less than or equal to the HPSP.

(c) With THERMAL POWER \leq 10% RTP.

(d) Reactor mode switch in the shutdown position.