

- a. Surveillance Requirement 4.1.A.2 - RPS Logic System Functional Test
- b. Surveillance Requirement 4.2.A.2 - Primary & Secondary Containment Logic System Functional Test
- c. Surveillance Requirement 4.2.J.2 - Feedwater Pump Trip Logic System Functional Test
- d. Surveillance Requirement 4.6.F.1.b - Relief Valve Logic System Functional Test
- e. Surveillance Requirement 4.9.A.9 - Simultaneous Diesel Generator Start
- f. Surveillance Requirement 4.9.A.10 - Diesel Storage Tank Cleaning (Unit 3 and Unit 2/3 only)

Each of the above Surveillance Requirements shall be successfully demonstrated prior to entering into MODE 2 on the first plant startup following the fifteenth refueling outage (D2R15).

(7) Additional Conditions

The Additional Conditions contained in Appendix B, as revised through Amendment No. 163, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Additional Conditions.

(8) Pressure-Temperature Limit Curves

The pressure-temperature (P/T) limit curves issued by Amendment No. 179 are approved for use until December 31, 2003, unless Exelon Generation Company, LLC, the licensee, obtains approval from the Nuclear Regulatory Commission staff for use beyond December 31, 2003.

(9) Fuel Burnup

The maximum rod average burnup for any rod shall be limited to 60 GWD/MTU until the completion of an NRC environmental assessment supporting an increased limit.