

**From:** Lawrence Rossbach  
**To:** Allan.haeger@Exeloncorp.com  
**Date:** 5/9/01 4:15PM  
**Subject:** EPU Materials question

Al,  
There is only one question in this area. Please let me know if you would like a call to discuss it.

**CC:** Anthony Mendiola; Stewart Bailey

*Docket Nos. 50-237, 50-249, 50-254, 50-265*

DRESDEN AND QUAD CITIES EXTENDED POWER UPRATE

REQUEST FOR ADDITIONAL INFORMATION - MATERIALS ENGINEERING

- 1) Flow Accelerated Corrosion - (Paragraphs 3.5.2.3, 3.5.3.3, 3.5.4.3) Specify which parameters, affecting flow accelerated corrosion (FAC), are expected to change after power uprate and what effect this change may have on wall thinning in the components subjected to FAC in the main steam and associated piping system, the feedwater system, and the other RCPB piping systems.