

From: Lawrence Rossbach
To: Allan.haeger@Exeloncorp.com
Date: 5/14/01 5:48PM
Subject: EPU I&C questions

The I&C section has two questions on the extended power uprate amendment request. They are attached. Please let me know if you would like a call to discuss them.

CC: Anthony Mendiola; Hukam Garg; Stewart Bailey

Docket Nos. 50-237, 50-249, 50-254, 50-265

DRESDEN/QUAD CITIES EPU: Instrumentation & Controls

1. Table 5.1 of NEDC-32962P and NEDC-32961P provide changes in the analytical limit for certain plant parameters for the current and power uprate condition. The justification for these changes is based on the assumption that they do not increase the probability and consequences of postulated accidents, or reduce significantly the margin of safety. In order for the staff to complete their review, provide instrument setpoints and allowable values at both the current and uprate power conditions for the instrumentation identified in Table 5-1.

2. Attachment G for both Dresden and Quad Cities states that "various instruments will require scaling/setpoint changes."

A) List the instruments which will require scaling changes;

B) Confirm that all the instruments which require setpoint changes are included in the submittal;

C) List the instruments which will be replaced to accommodate the extended power uprate.