

August 31, 2001

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555-0001

Gentlemen:

ULNRC-4519



**DOCKET NO. 50-483  
CALLAWAY PLANT  
UNION ELECTRIC COMPANY**  
**Response to NRC Bulletin 2001-01, "Circumferential Cracking  
of Reactor Pressure Vessel Head Penetration Nozzles"**

Attached is the Callaway Plant response to U.S. Nuclear Regulatory Commission (NRC) Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles," dated August 3, 2001. NRC Bulletin 2001-01 requested information relative to the Reactor Pressure Vessel (RPV) head penetration nozzle configuration, previous RPV head inspections, and plans for future RPV head inspections. Callaway Plant is participating in the Electric Power Research Institute, Inc., Materials Reliability Program associated with the issue. Callaway Plant is in the category of plants with low susceptibility to circumferential cracking of the reactor pressure vessel head penetration nozzles. Callaway Plant also coordinated preparation of this response with the other participants in the Strategic Teaming and Resource Sharing (STARS) group.

If you should have any questions regarding this submittal, please contact us.

Very truly yours,

A handwritten signature in black ink, appearing to read "Blosser".

John D. Blosser  
Manager - Regulatory Affairs

blm/bfh/jdg

Attachments: I - Affidavit  
II - Response to NRC Bulletin 2001-01  
III - List of Commitments

*Acoss*  
11

cc: M. H. Fletcher  
Professional Nuclear Consulting, Inc.  
19041 Raines Drive  
Derwood, MD 20855-2432

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive  
Suite 400  
Arlington, TX 76011-8064

Senior Resident Inspector  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
8201 NRC Road  
Steedman, MO 65077

Mr. Jack Donohew (2)- **OPEN BY ADDRESSEE ONLY**  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
1 White Flint, North, Mail Stop OWFN 7E1  
11555 Rockville Pike  
Rockville, MD 20852-2738

Manager, Electric Department  
Missouri Public Service Commission  
P.O. Box 360  
Jefferson City, MO 65102

Ron Kucera  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, MO 65102

Denny Buschbaum  
TU Electric  
P.O. Box 1002  
Glen Rose, TX 76043

Pat Nugent  
Pacific Gas & Electric  
Regulatory Services  
P.O. Box 56  
Avila Beach, CA 93424

Nuclear Energy Institute  
1776 I Street N.W.  
Suite 400  
Washington, DC 20006-3708

STATE OF MISSOURI )  
 ) S S  
COUNTY OF CALLAWAY )

John D. Blosser, of lawful age, being first duly sworn upon oath says that he is Manager, Regulatory Affairs for Union Electric Company; that he has read the foregoing document and knows the content thereof; that he has executed the same for and on behalf of said company with full power and authority to do so; and that the facts therein stated are true and correct to the best of his knowledge, information and belief.

By *Blosser*  
John D. Blosser  
Manager, Regulatory Affairs

SUBSCRIBED and sworn to before me this 31<sup>st</sup> day  
of August, 2001.

*Gloria J Taylor*

GLORIA J. TAYLOR  
NOTARY PUBLIC  
STATE OF MISSOURI - CALLAWAY COUNTY  
NOTARY SEAL  
MY COMMISSION EXPIRES JUNE 21, 2003

## **Response to NRC Bulletin 2001-01 Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles**

Below is the Callaway Plant response to Nuclear Regulatory Commission (NRC) Bulletin 2001-01, Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles, dated August 3, 2001 (Reference 1). The Bulletin's "Requested Information" is shown in bold.

Callaway Plant is participating in the Electric Power Research Institute, Inc. (EPRI) Materials Reliability Program (MRP) associated with this issue. Information associated with the MRP efforts are compiled in "PWR Materials Reliability Program Response to NRC Bulletin 2001-01 (MRP-48), EPRI, Palo Alto, CA: 2001: TP-1006284," (Reference 2). This report was transmitted to the NRC by Nuclear Energy Institute (NEI) letter, "Generic Information for Use by Licensees in Response to NRC Bulletin 2001-01," dated August 21, 2001 (Reference 3). Reference to the MRP report is made, where appropriate.

### **Requested Information**

1. **All addressees are requested to provide the following information:**
  - a. **the plant-specific susceptibility ranking for your plant(s) (including all data used to determine each ranking) using the PWSCC [Primary Water Stress Corrosion Cracking] susceptibility model described in Appendix B to the MRP-44, Part 2, report;**

### **Response**

As shown in Table 2-1 of Reference 2, Callaway Plant has been evaluated for relative susceptibility to PWSCC of the Reactor Pressure Vessel (RPV) head penetration nozzles. The evaluation indicates it would take approximately 119 Effective Full Power Years (EFPYs) of additional operation to reach the same time-at-temperature as Oconee Nuclear Station Unit 3 (ONS3). The 114 EFPY is based from March 1, 2001. March 2001 is when leaking nozzles were discovered at ONS3. As described in Reference 2, the evaluation used the same time-at-temperature model as described in Appendix B to MRP-44, Part 2 (Reference 4).

Using the criteria stated in NRC Bulletin 2001-01, Callaway Plant can be considered as having a low susceptibility to circumferential cracking of the reactor pressure vessel head penetration nozzles.

### **Requested Information**

1. **All addressees are requested to provide the following information:**
  - b. **a description of the VHP [vessel head penetration] nozzles in your plant(s), including the number, type, inside and outside diameter, materials of construction, and the minimum distance between VHP nozzles;**

### **Response**

Reference 2, Table 2-3, provides the requested nozzle information.

**Requested Information**

1. **All addressees are requested to provide the following information:**
  - c. **a description of the RPV head insulation type and configuration;**

**Response**

The Callaway Plant RPV head insulation type and configuration are briefly described in Reference 2, Table 2-1. The RPV head insulation is a reflective (mirror) insulation constructed to be permanent, yet removable and reusable. The main portion of the insulation is installed horizontally above the dome of the RPV with outer portions stepped down to accommodate the circular vessel configuration. The insulation is positioned between the top of the vessel and the head penetration flanges, which connect to the Control Rod Drive Mechanism (CRDM) housings. The insulation is provided in individual panels that fit together in a specific arrangement and are fastened by buckles.

**Requested Information**

1. **All addressees are requested to provide the following information:**
  - d. **a description of the VHP nozzle and RPV head inspections (type, scope, qualification requirements, and acceptance criteria) that have been performed at your plant(s) in the past 4 years, and the findings. Include a description of any limitations (insulation or other impediments) to accessibility of the bare metal of the RPV head for visual examinations;**

**Response**

Callaway Plant has not performed RPV head and nozzle inspections within the past four years. Accessibility limitations to the RPV head bare metal for visual examinations include the dose and time associated with removal of the insulation and CRDM cooling shroud.

**Requested Information**

1. **All addressees are requested to provide the following information:**
  - e. **a description of the configuration of the missile shield, the CRDM housings and their support/restraint system, and all components, structures, and cabling from the top of the RPV head up to the missile shield. Include the elevations of these items relative to the bottom of the missile shield.**

**Response**

Table 1 provides relative elevation of various significant components to the missile shield. Callaway Plant Updated Safety Analysis Report (FSAR) Figure 1.2-15 shows an elevation view general arrangement of equipment, including the RPV and the missile shield.

Reactor Missile Shield	The Reactor Missile Shield is a reinforced concrete slab supported by the refueling pool walls and is located above the RPV to provide protection against postulated CRDM missiles. The slab is moveable to allow access to the RPV during refueling. During normal plant operation, the missile shield is restrained laterally for seismic loads.
Seismic Support Platform	The seismic support platform is located between the bottom of the missile shield and the top of the CRDMs and serves to provide support for the CRDM cables as they transition from the top of the CRDMs to the cable trays which run to the 2047' level of containment. Power and instrumentation cables traverse upward from the top of the CRDMs through the platform and across to the cable trays. The platform also provides support for the reactor vessel head vents and associated piping.
CRDM Cooling Shroud	The CRDM Cooling Shroud is a generally cylindrical steel structure which directs forced air cooling flow over the CRDM coils to maintain them in a suitable operating environment. The CRDM cooling shroud encircles the RPV head insulation and impedes access to the insulation panels.
RPV Head Penetrations	Of the seventy-eight four-inch diameter RPV head penetrations, fifty-three are used for the CRDMs (described below). Twenty penetrations are capped, four penetrations contain temperature monitoring instrumentation, and one penetration is used for the Reactor Vessel Level Instrumentation System (RVLIS). There is an additional one-inch head penetration, which is used for venting the RPV Head.
CRDMs	The CRDMs are located on the dome of the reactor vessel. The CRDM consists of four separate subassemblies. They are the pressure vessel, coil stack assembly, latch assembly, and the drive rod assembly. The CRDM pressure vessel is connected by a welded threaded connection to the CRDM RPV head penetration and restrained at the top by Rod Position Indicator (RPI) top plates, which are an integral part of the seismic support platform. The other CRDM subassemblies are external to the CRDM pressure vessel and provide for withdrawal or insertion of the rod control cluster assemblies (RCCAs), and for RCCA position indication. The CRDM power and instrumentation cables are contained in conduit from the applicable subassemblies to the RPI top plates.
RPV Head Insulation	See response to 1.c.
CRDM RPV Head Penetrations	The CRDM RPV head penetrations provide a pressure boundary from the RPV to the threaded welded connection for the CRDMs. The penetrations are structured to provide a uniform height transition from the round RPV dome to the CRDM housing.

**2. If your plant has previously experienced either leakage from or cracking in VHP nozzles, addressees are requested to provide the following information:**

- a. a description of the extent of VHP nozzle leakage and cracking detected at your plant, including the number, location, size, and nature of each crack detected;
- b. a description of the additional or supplemental inspections (type, scope, qualification requirements, and acceptance criteria), repairs, and other corrective actions you have taken in response to identified cracking to satisfy applicable regulatory requirements;
- c. your plans for future inspections (type, scope, qualification requirements, and acceptance criteria) and the schedule;
- d. your basis for concluding that the inspections identified in 2.c will assure that regulatory requirements are met (see Applicable Regulatory Requirements section). Include the following specific information in this discussion:
  - (1) If your future inspection plans do not include performing inspections before December 31, 2001, provide your basis for concluding that the regulatory requirements discussed in the Applicable Regulatory Requirements section will continue to be met until the inspections are performed.
  - (2) If your future inspection plans do not include volumetric examination of all VHP nozzles, provide your basis for concluding that the regulatory requirements discussed in the Applicable Regulatory Requirements section will be satisfied.

### **Response**

Callaway Plant has not previously experienced either leakage from or cracking in VHP nozzles. Therefore, this section is not applicable.

### **Requested Information**

3. If the susceptibility ranking for your plant is within 5 EFPY of ONS3, addressees are requested to provide the following information:
  - a. your plans for future inspections (type, scope, qualification requirements, and acceptance criteria) and the schedule;
  - b. your basis for concluding that the inspections identified in 3.a. will assure that regulatory requirements are met (see Applicable Regulatory Requirements section). Include the following specific information in this discussion:
    - (1) If your future inspection plans do not include performing inspections before December 31, 2001, provide your basis for concluding that the regulatory requirements discussed in the Applicable Regulatory Requirements section will continue to be met until the inspections are performed.

- (2) If your future inspection plans include only visual inspections, discuss the corrective actions that will be taken, including alternative inspection methods (for example, volumetric examination), if leakage is detected.

**Response**

Callaway Plant's susceptibility ranking is not within 5 EFPY of ONS3. Therefore, this section is not applicable.

**Requested Information**

4. If the susceptibility ranking for your plant is greater than 5 EFPY and less than 30 EFPY of ONS3, addressees are requested to provide the following information:
- a. your plans for future inspections (type, scope, qualification requirements, and acceptance criteria) and the schedule;
  - b. your basis for concluding that the inspections identified in 4.a will assure that regulatory requirements are met (see Applicable Regulatory Requirements section). Include the following specific information in this discussion:
    - (1) If your future inspection plans do not include a qualified visual examination at the next scheduled refueling outage, provide your basis for concluding that the regulatory requirements discussed in the Applicable Regulatory Requirements section will continue to be met until the inspections are performed.
    - (2) The corrective actions that will be taken, including alternative inspection methods (for example, volumetric examination), if leakage is detected.

**Response**

Callaway Plant's susceptibility ranking is not within the band of greater than 5 EFPY and less than 30 EFPY of ONS3. Therefore, this section is not applicable.

**Requested Information**

5. Addressees are requested to provide the following information within 30 days after plant restart following the next refueling outage:
- a. a description of the extent of VHP nozzle leakage and cracking detected at your plant, including the number, location, size, and nature of each crack detected;
  - b. if cracking is identified, a description of the inspections (type, scope, qualification requirements, and acceptance criteria), repairs, and other corrective actions you have taken to satisfy applicable regulatory requirements. This information is requested only if there are any changes from prior information submitted in accordance with this bulletin.

**Response**

Callaway Plant will provide the requested information or indicate that no leakage was identified within 30 days after plant restart following the next refueling outage.

**References**

1. NRC Bulletin 2001-01, Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles, dated August 3, 2001.
2. PWR Materials Reliability Program Response to NRC Bulletin 2001-01 (MRP-48), EPRI, Palo Alto, CA: 2001: TP-1006284
3. NEI letter from Alexander Marion to Dr. Brian W. Sheron (NRC), Generic Information for Use by Licensees in Response to NRC Bulletin 2001-01, dated August 21, 2001.
4. PWR Materials Reliability Program, Interim Alloy 600 Safety Assessments for US PWR Plants (MRP-44): Part 2: Reactor Vessel Top Head Penetrations, EPRI, Palo Alto, CA: 2001.

**Table 1**  
Callaway Plant  
Relative Elevation of Significant Components

<u>Elevation</u>	<u>Distance from Missile Shield</u>	<u>Component</u>
2051'	0'	Bottom of Missile Shield
2047'	4'	Seismic Support Platform
2047	4'	Top of CRDMS
2030' 8"	20' 4"	CRDM Penetration Flanges
2029' 4"	21' 8"	Head Insulation (Upper Horizontal Step)
2029' 2"	21' 10"	Top of RPV Head
2028' 4"	22' 8"	Center of 32" Duct for CRDM Cooling Air
2021' 8"	29' 4"	RPV Flange

### LIST OF COMMITMENTS

The following table identifies those actions committed to by Callaway Plant in this document. Any other statements in this submittal are provided for information purposes and are not considered to be commitments. Please direct questions regarding these commitments to Mr. Dave E. Shafer, Superintendent Licensing (314) 554-3104.

COMMITMENT	Due Date/Event
Callaway Plant will provide the requested information (NRC Bulletin 2001-01, Request 5) or indicate that no leakage was identified.	Within 30 days after plant restart following the next refueling outage.