

September 14, 2001
EN 01-031

OFFICE OF ENFORCEMENT
NOTIFICATION OF SIGNIFICANT ENFORCEMENT ACTION

Licensee: Calvert Cliffs Nuclear Power Plant, Inc. (SDP/EA-01-206)
Calvert Cliffs Unit 1 (Docket No. 50-317)

Subject: ISSUANCE OF THE FINAL SIGNIFICANCE DETERMINATION FOR A
YELLOW FINDING AND NOTICE OF VIOLATION

This is to inform the Commission that a Notice of Violation associated with a Yellow Significance Determination Process (SDP) finding will be issued on or about September 19, 2001, to Calvert Cliffs Nuclear Power Plant, Inc. This Yellow finding was due to inadequate adherence to maintenance instructions during reassembly of the No. 11 auxiliary feedwater pump turbine bearing. As a result of applying excessive sealant to the bearing housing, there was a loss of lubrication to the bearing and the bearing failed on May 16, 2001. The failure to follow the maintenance work instruction was determined to be a violation of 10 CFR 50, Appendix B, Criterion V, "Instructions, Procedures, and Drawings."

It should be noted that the licensee has not yet been specifically informed of the enforcement action. The schedule of issuance and notification is:

Mailing of Notice
Telephone Notification of licensee

September 19, 2001
September 19, 2001

The State of Maryland will be notified.

Contacts: Jennifer Dixon-Herrity, OE, 301-415-1980; James Luehman, OE, 301-415-2741

Distribution:

OWFN _____	OWFN _____	TWFN _____	Regional Offices
Chairman Meserve	EDO	OCFO	RI
Comm. Dicus	DEDR	OP CTR	RII
Comm. Diaz	DEDMRS	NMSS	RIII
Comm. McGaffigan	OE	OCIO	RIV
Comm. Merrifield	STP	OIG	
OGC	NRR	RES	MAIL
SECY	OI	ACRS	ADAMS/PUBLIC
OCA	IP		
PA			

ADAMS ACCESSION # ML012570010

Filename: G\OECASES\EN01-031.jld.wpd

OFFICE	OE	OE:DD
NAME	JDixon-Herrity	JLuehman
DATE	09/14/01	09/14/01

**PRELIMINARY INFORMATION - NOT FOR PUBLIC DISCLOSURE UNTIL
VERIFICATION THAT LICENSEE HAS RECEIVED ACTION**