(13) Partial Feedwater Heating (Section 15.1, SER)

During power operation, the facility shall not be operated with a feedwater heating capacity which would result in a rated thermal power feedwater temperature less than 326 °F.

(14) Emergency Response Capabilities (Generic Letter 82-33, Supplement <u>1 to NUREG-0737, Section 7.5.2.4, SER and SSER 3, Section 18,</u> <u>SER, SSER 2 and SSER 3)</u>

EOI shall complete the requirements of NUREG-0737 Supplement #1 as specified in Attachment 5. Attachment 5 is hereby incorporated into this license.

(15) Salem ATWS Events, Generic Letter 83-28 (Section 7.2.2.5, SSEP 3)

EOI shall submit responses to and implement the requirements of Generic Letter 83-28 on a schedule which is consistent with that given in its letters dated August 3, 1984 and May 30, 1985.

(16) Merger Related Reports

Entergy Gulf States, Inc. shall inform the Director, NRR:

- a. Sixty days prior to a transfer (excluding grants of security interests or liens) from Entergy Gulf States, Inc. to Entergy or any other entity of facilities for the production, transmission or distribution of electric energy having a depreciated book value exceeding one percent (1 %) of Entergy Gulf States, Inc.'s consolidated net utility plant, as recorded on Entergy Gulf States, Inc.'s books of account.
- b. Of an award of damages in litigation initiated against Entergy Gulf States, Inc. by Cajun Electric Power Cooperative regarding River Bend within 30 days of the award.

(17) DELETED

- D. The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, guard training and qualification, and safeguards contingency plans including amendments made pursuant to the provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The plans, which contain Safeguards Information protected under 10 CFR 73.21, are entitled: "River Bend Station Security Plan," with revisions submitted through May 25, 1995; "River Bend Station Guard Training and Qualification Plan," with revisions submitted through December 3, 1993; and "River Bend Station Contingency Plan," with revisions submitted through August 17, 1990. Changes made in accordance with 10 CFR 73.00 shall be implemented in accordance with the schedule set forth therein.
- E. Except as otherwise provided in the Technical Specifications or Environmental Protection Plan, EOI shall report any violations of the requirements contained in Section 2.C of this license in the following manner: initial notification shall be made within 24 hours to the NRC Operations Center via the Emergency Notification System with written followup within thirty days in accordance with the procedures described in 10 CFR 50.73(b), (c) and (e).
- F. The licensee shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.
- G. This license is effective as of the date of issuance and shall expire at midnight on August 29, 2025.

FOR THE NUCLEAR REGULATORY COMMISSION

Original Signed By

Harold R. Denton, Director Office of Nuclear Reactor Regulation

Enclosures: 1. Attachments 1-5 2. Appendix A - Technical Specifications (NUREG-1172) 3. Appendix B - Environmental Protection Plan

4. Appendix C - Antitrust Conditions

Date of Issuance: November 20, 1985

Revised: December 16, 1993

CRFA System Instrumentation 3.3.7.1

and the second sec

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1.	Reactor Vessel Water Level - Low Low,Level 2	1.2.3	2	В	SR 3.3.7.1.1 SR 3.3.7.1.2 SR 3.3.7.1.3 SR 3.3.7.1.4 SR 3.3.7.1.5	≥ -47 inches
2.	Drywell Pressure - High	1.2.3	2	С	SR 3.3.7.1.1 SR 3.3.7.1.2 SR 3.3.7.1.3 SR 3.3.7.1.4 SR 3.3.7.1.5	≤ 1.88 psid
3.	Control Room Local Intake Ventilation Radiation Monitors	1.2.3 (a),(b)	1	D	SR 3.3.7.1.1 SR 3.3.7.1.2 SR 3.3.7.1.4 SR 3.3.7.1.5	≤0,97 × 10 ⁻⁵ µC1/cc

Table 3.3.7.1-1 (page 1 of 1) Control Room Fresh Air System Instrumentation

(a) During operations with a potential for draining the reactor vessel.

(b) During movement of irradiated fuel assemblies in the primary containment or fuel building.

•

Primary Containment-Shutdown 3.6.1.10

3.6 CONTAINMENT SYSTEMS

- 3.6.1.10 Primary Containment-Shutdown
- LCO 3.6.1.10 Primary containment shall be OPERABLE.

APPLICABILITY: During movement of recently irradiated fuel assemblies in the primary containment,

During operations with a potential for draining the reactor vessel (OPDRVs).

ACTIONS

T

CONDITION		REQUIRED ACTION		COMPLETION TIME
Α.	Primary containment inoperable.	A.1	Suspend movement of recently irradiated fuel assemblies in the primary containment.	Immediately
		AND	Initiate action to suspend	Immediately
		A.2	OPDRVs.	

3.7 PLANT SYSTEM

3.7.2 Control Room Fresh Air (CRFA) System

LCO 3.7.2 Two CRFA subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3, During movement of irradiated fuel assemblies in the primary containment or fuel building. During operations with a potential for draining the reactor vessel (OPDRVs).

ACTIONS

I

I

CONDITION		REQUIRED ACTION	COMPLETION TIME
Α.	One CRFA subsystem inoperable.	A.1 Restore CRFA subsystem to OPERABLE status.	7 days
Β.	Required Action and Associated Completion Time of Condition A not met in MODE 1, 2, or 3.	B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 4.	12 hours 36 hours

(continued)

Amendment No. 81- 119

CRFA System 3.7.2

ACTIONS (continued)

I 1

T Ì

1

ACT	ACTIONS (continued)					
CONDITION			REQUIRED ACTION	COMPLETION TIME		
C.	Required Action and associated Completion Time of Condition A not met during	LCO 3.0.3 is not applicable.				
	movement of irradiated fuel assemblies in the primary containment or fuel building or during OPDRVs.	C.1 OR	Place OPERABLE CRFA subsystem in emergency mode.	lmmediately		
		C.2.1	Suspend movement of irradiated fuel assemblies in the primary containment and fuel building.	Immediately		
		AND	<u>)</u>			
		C.2.2	Initiate action to suspend OPDRVs.	Immediately		
D.	Two CRFA subsystems inoperable in MODE 1, 2, or 3.	D.1	Enter LCO 3.0.3.	Immediately		

ACTIONS (continued)

T

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. Two CRFA subsystems inoperable during movement of irradiated fuel assemblies in the primary containment or fuel building, or during OPDRVs.	 E.1 Suspend movement of irradiated fuel assemblies in the primary containment and fuel building. <u>AND</u> E.2 Initiate action to suspend OPDRVs. 	Immediately Immediately

SURVEILLANCE REQUIREMENTS

		SURVEILLANCE	FREQUENCY
SR	3.7.2.1	Operate each CRFA subsystem for \ge 10 continuous hours with the heaters operating.	31 days
SR	3.7.2.2	Perform required CRFA filter testing in accordance with the Ventilation Filter Testing Program (VFTP).	In accordance with the VFTP
SR	3.7.2.3	Verify each CRFA subsystem actuates on an actual or simulated initiation signal.	18 months

Control Room AC System 3.7.3

3.7 PLANT SYSTEMS

3.7.3 Control Room Air Conditioning (AC) System

LCO 3.7.3 Two control room AC subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3, During movement of irradiated fuel assemblies in the primary containment or fuel building, During operations with a potential for draining the reactor vessel (OPDRVs).

ACTIONS

ł

	CONDITION	REQUIRED ACTION	COMPLETION TIME
Α.	One control room AC subsystem inoperable.	A.1 Restore control room AC subsystem to OPERABLE status.	30 days
Β.	Two control room AC subsystems inoperable.	 B.1 Verify control room area temperature ≤ 104°F. AND B.2 Restore one control room AC subsystem to OPERABLE status. 	Once per 4 hours 7 days
C.	Required Action and Associated Completion Time of Condition A or B not met in MODE 1, 2, or 3.	C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4.	12 hours 36 hours

(continued)

RIVER BEND

:

Amendment No. 81- 119

ACTIONS (continued)

	CONDITION			REQUIRED ACTION	COMPLETION TIME
	D.	Required Action and associated Completion Time of Condition A not met during movement of irradiated fuel assemblies in the primary containment or fuel building, or during OPDRVs	LCO 3.0. D.1 Plac . AC s	3 is not applicable. Ce OPERABLE control room subsystem in operation.	Immediately
 		OF DICUS .	D.2.1	Suspend movement of irradiated fuel assemblies in the primary containment and fuel building.	Immediately
			AND		
1			D.2.2	Initiate action to suspend OPDRVs.	Immediately

Control Room AC System 3.7.3

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
 E. Required Action and associated Completion Time of Condition B not met during movement of irradiated fuel assemblies in the primary containment or fuel building, or during OPDRVs. 	 E.1 Suspend movement of irradiated fuel assemblies in the primary containment and fuel building. <u>AND</u> E.2 Initiate action to suspend OPDRVs. 	Immediately Immediately

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.7.3.1	Verify each control room AC subsystem has the capability to remove the assumed heat load.	18 months

5.5 Programs and Manuals

5.5.1 <u>Offsite Dose Calculation Manual (ODCM)</u> (continued)

c. Shall be submitted to the NRC in the form of a complete, legible copy of the entire ODCM as a part of, or concurrent with, the Radioactive Effluent Release Report for the period of the report in which any change in the ODCM was made. Each change shall be identified by markings in the margin of the affected pages, clearly indicating the area of the page that was changed, and shall indicate the date (i.e., month and year) the change was implemented.

5.5.2 Primary Coolant Sources Outside Containment

This program provides controls to minimize leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to levels as low as practicable. The systems include the Low Pressure Core Spray, High Pressure Core Spray, Residual Heat Removal, Reactor Core Isolation Cooling, and process sampling. The program shall include the following:

- a. Preventive maintenance and periodic visual inspection requirements; and
- b. Integrated leak test requirements for each system at refueling cycle intervals or less.

5.5.3 Post Accident Sampling

This program provides controls that ensure the capability to obtain and analyze reactor coolant, radioactive gases, and particulates in plant gaseous effluents and containment atmosphere samples under accident conditions. The program shall include the following:

- a. Training of personnel;
- b. Procedures for sampling and analysis; and
- c. Provisions for maintenance of sampling and analysis equipment.