ARB MEETING December 19, 1996

WARNING
THIS DOCUMENT CONTAINS
SENSITIVE ALLEGATION INFORMATION
IT CAN NOT BE DISSEMINATED
OUTSIDE THE NRC

RII-96-A-0249

12/16/96

WATTS BAR

- 1. ALLEGER STATED HE WAS RECENTLY LAYED OFF BECAUSE THE SYSTEM ENGINEER FUNCTION HE WAS PERFORMING ON THE ICE CONDENSER DID NOT REQUIRE A FULL TIME POSITION. HE STATED THAT THE SYSTEM DID REQUIRE FULL TIME ATTENTION DUE TO THE MANY CHALLENGES THE SYSTEM PRESENTS BASED ON HIS MANY YEARS OF EXPERIENCE WITH IT. HE IS CONCERNED THE SYSTEM MAY DEGRADE AND NOT RECEIVE SUFFICIENT ATTENTION. THE CURRENTLY ASSIGNED PERSON (RESERVED) HAS TWO OTHER SYSTEMS ALSO.
- 2. ALLEGER EXPRESSED CONCERN ABOUT BROKEN SCREWS WERE FOUND IN THE ICE CONDENSER IN 1995. A PER WAS INITIATED TO PERFORM AN EVALUATION. TVA INITIALLY PERFORMED A METALLURGICAL ANALYSIS. SUBSEQUENT TO THAT REPORT, THE ISSUE WAS GIVEN TO WESTINGHOUSE TO ANALYZE. THE ISSUE WAS VERY QUICKLY ANALYZED AWAY AND THE FIRST REPORT WAS NOT USED TO SUPPORT THE ANALYSIS. HE IS CONCERNED WHETHER THE ANALYSIS WAS ADEQUATE. THE CI CALLED DUKE POWER TO ASK IF THEY HAD EXPERIENCED A SIMILAR PROBLEM. THEY STATED THAT THEY FIND BROKEN SCREWS REGULARLY DURING OUTAGES AND REPLACE THEM WITH STAINLESS STEEL SCREWS. THEY IMPLIED TO HIM THAT THEY HAD PERFORMED AN INFORMAL INTERNAL ANALYSIS OF THE ISSUE AND DID NOT INVOLVE WESTINGHOUSE NOR DID THEY HIGHLIGHT THE ISSUE AS AN INDUSTRY PROBLEM.
 - AP: RESIDENT INSPECTOR TO OBTAIN A COPY OF TVA'S PER AND METALLURGICAL ANALYSIS AND FORWARD TO DRS/MAINTENANCE BRANCH FOR REVIEW. ARB STATED THAT DURING DRS REVIEW OF TVA'S REPORT. THE INSPECTOR MAY NEED TO CHECK WITH DUKE POWER COMPANY'S DISPOSITION OF A SIMILAR PROBLEM AND THEIR REASON WHY THEY CHOSE TO REPLACE THE SCREWS WITH STAINLESS STEEL TYPE.

LEAD DIVISION/BRANCH: DRS/MB

LICENSEE REFERRAL: NO

OI/AP: NONE DOL/AP: NONE

COMPLETION DATE: RESIDENT INSPECTOR TO OBTAIN TVA'S REPORT BY DECEMBER 27, 1996.

DRS CLOSE ALLEGATION BY MARCH 20, 1997

ARB ATTENDERS						
ORA	DRP	DRS	DNMS			
[/]IGNATONIS	[/]MERSCHOFF [/]JULIAN	[✓]JAUDON [✓]VERRELLI [✓]BARR	OI O			
			[/]McNULTY			

ARB MEETING

MINUTES

DECEMBER 19, 1996

WARNING
THIS DOCUMENT CONTAINS
SENSITIVE ALLEGATION INFORMATION
IT CANNOT BE DISSEMINATED
OUTSIDE THE NRC

4/20/95

RII-96-A-0244 RII-96-A-0245 RII-96-A-0246 RII-96-A-0247 RII-96-A-0249 RII-96-A-0250 RII-96-A-0251 RII-96-A-0252 RII-96-A-0253 RII-96-A-0255 RII-96-A-0255	12/10/96 12/11/96 11/27/96 12/17/96 12/10/96 12/16/96 10/21/96 12/09/96 12/17/96 12/17/96 12/17/96	CARDIOVASCULAR ASSOCIATES TURKEY POINT INTERSTATE NUCLEAR SERVICES SEQUOYAH ST. LUCIE WATTS BAR USDA FACILITY IN NORTH CAROLINA ST. LUCIE CRYSTAL RIVER CRYSTAL RIVER CRYSTAL RIVER OCONEE CRYSTAL RIVER
11.22 20 11 0020	***************************************	orrional transmit

DISTRIBUTION

ORA	DRP	DRS .	DNMS
[/] REYES [/] MERSCHOFF [/] EVANS [/] URYC [/] DEMIRANDA [/] IGNATONIS [/] SLACK [] TROJANOWSKI	[/] JOHNSON [/] CRLENJAK [] BELISLE [/] WERT [/] LANDIS [/] LESSER [] SHYMLOCK [] SKINNER [/] JULIAN	[/] JAUDON [/] COLLINS [/] FREDRICKSON [/] BARR [] CASTO [] CHRISTENSEN [] PEEBLES [/] VERRELLI [] RANKIN	[/] MALLETT [/] WOODRUFF [] OI
			[/] McNULTY

ARB MEETING MINUTES PREPARED BY: Al Ignatonis

ARB MEETING MINUTES APPROVED BY: Johns Jaudon

ARB MEETING MINUTES APPROVED BY: Bruce Mallett

01 cl 145 85m