

September 26, 2001

Mr. Oliver D. Kingsley, President
Exelon Nuclear
Exelon Generation Company, LLC
1400 Opus Place, Suite 500
Downers Grove, IL 60515

SUBJECT: ISOLATION OF A THERMAL BARRIER COOLER RETURN LINE - BYRON
STATION, UNITS 1 AND 2 (TAC NOS. MB2907 AND MB2908)

Dear Mr. Kingsley:

During an inspection of Byron Station, Nuclear Regulatory Commission (NRC), Region III inspectors identified an Unresolved Item related to the isolation of a thermal barrier cooler return line. The finding is documented in NRC Inspection Report 50-454/01-03(DRS); 50-455/01-03(DRS), dated March 8, 2001. Specifically, the inspectors questioned the change to the updated final safety analysis report (UFSAR), in which the performance requirement for one of the motor-operated valves in the component cooling water return line from the reactor coolant pump thermal barrier cooler was changed such that it did not have to be capable of closing against full reactor differential pressure that may result from a reactor coolant pump thermal barrier leak.

The inspectors reviewed an UFSAR change developed and implemented in 1998 at Byron to provide editorial clarification in UFSAR Section 9.2.2.4.4. The inspectors reviewed the UFSAR change package, the associated 10 CFR 50.59 evaluation (GG-98-0200) and other related documents. Based on the information included in the documents, the inspectors were not able to conclude that the UFSAR change did not represent an unreviewed safety question. Criterion 55 (10 CFR Part 50, Appendix A) specifies the requirements for isolation of reactor coolant pressure boundary penetrating containment. Criterion 44 specifies, in part, that isolation capabilities of cooling systems be provided to assure that the safety function be accomplished assuming a single failure.

In consideration of the above, please provide the basis upon which it was concluded that the changes to the isolation capability of the thermal barrier cooler return line and the associated UFSAR change could be done without submitting a license amendment to the NRC in

Mr. O. Kingsley

-2-

accordance with 10 CFR 50.59 and 50.90. This request has been discussed with representatives of Exelon and it was agreed that the NRC would receive a response within 45 days of receipt of this letter.

Sincerely,

/RA/

George F. Dick, Jr., Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-454 and STN 50-455

cc: See next page

O. Kingsley
Exelon Generation Company

Byron Station
Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Mrs. Phillip B. Johnson
1907 Stratford Lane
Rockford, Illinois 61107

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Attorney General
500 S. Second Street
Springfield, Illinois 62701

Document Control Desk-Licensing
Exelon Generation Company, LLC
1400 Opus Place, Suite 400
Downers Grove, Illinois 60515

Exelon Generation Company, LLC
Byron Station Manager
4450 N. German Church Road
Byron, Illinois 61010-9794

Ms. C. Sue Hauser, Project Manager
Westinghouse Electric Corporation
Energy Systems Business Unit
Post Office Box 355
Pittsburgh, Pennsylvania 15230

Exelon Generation Company, LLC
Site Vice President - Byron
4450 N. German Church Road
Byron, Illinois 61010-9794

Joseph Gallo
Gallo & Ross
1025 Connecticut Ave., NW, Suite 1014
Washington, DC 20036

Mr. William Bohlke
Senior Vice President, Nuclear Services
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Howard A. Learner
Environmental Law and Policy
Center of the Midwest
35 East Wacker Drive
Suite 1300
Chicago, Illinois 60601-2110

Mr. H. Gene Stanley
Vice President
Mid-West Regional Operating Group
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

U.S. Nuclear Regulatory Commission
Byron Resident Inspectors Office
4448 North German Church Road
Byron, Illinois 61010-9750

Mr. Christopher Crane
Senior Vice President
Mid-West Regional Operating Group
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Ms. Lorraine Creek
RR 1, Box 182
Manteno, Illinois 60950

Chairman, Ogle County Board
Post Office Box 357
Oregon, Illinois 61061

O. Kingsley
Exelon Generation Company

- 2 -

Byron Station
Units 1 and 2

Mr. R. M. Krich
Director - Licensing
Mid-West Regional Operating Group
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Exelon Generation Company, LLC
Regulatory Assurance Supervisor - Byron
4450 N. German Church Road
Byron, Illinois 61010-9794

Mr. Robert Helfrich
Senior Counsel, Nuclear
Mid-West Regional Operating Group
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Mr. Jeffrey Benjamin
Vice President
Licensing and Regulatory Affairs
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Mr. John Skolds
Chief Operating Officer
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Mr. John Cotton
Senior Vice President - Operations Support
Exelon Generation Company, LLC
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Mr. O. Kingsley

-2-

accordance with 10 CFR 50.59 and 50.90. This request has been discussed with representatives of Exelon and it was agreed that the NRC would receive a response within 45 days of receipt of this letter.

Sincerely,

/RA/

George F. Dick, Jr., Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-454 and STN 50-455

cc: See next page

Distribution:

PUBLIC
PDIII/2 r/f
AMendiola
CRosenberg
GDick
OGC
ACRS
AStone, RIII
KO'Brien, RIII
JJacobson, RIII

ADAMS ACCESSION NO.: **ML012610488** *See previous concurrence

OFFICE	PM:PDIII/2	LA:PDIII/2	SPLB	SC:PDIII/2
NAME	GDick	CRosenberg	GHubbard*	AMendiola
DATE	09/24/01	09/24/01	09/21/01	09/25/01

OFFICIAL RECORD COPY