



SEP 1 2 2001

SERIAL: BSEP 01-0106

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324/LICENSE NOS. DPR-71 AND DPR-62
AUGUST 2001 MONTHLY OPERATING REPORTS

Ladies and Gentlemen:

In accordance with Technical Specification (TS) 5.6.4 for the Brunswick Steam Electric Plant (BSEP), Unit Nos. 1 and 2, Carolina Power & Light (CP&L) Company is submitting the enclosed Monthly Operating Reports for August 2001. These reports are being submitted to the NRC by the 15th day of the month following the calendar month covered by the reports, as specified in TS 5.6.4.

There are no regulatory commitments being made in this submittal. Please refer questions regarding this submittal to Mr. Leonard R. Beller, Supervisor – Licensing/Regulatory Programs, at (910) 457-2073.

Sincerely,

David C. DiCello
Manager - Regulatory Affairs
Brunswick Steam Electric Plant

WRM/wrm

Enclosures:

1. BSEP, Unit No. 1 Monthly Operating Report August 2001
2. BSEP, Unit No. 2 Monthly Operating Report August 2001

IE24

Document Control Desk
BSEP 01-0106 / Page 2

cc (with enclosures):

U. S. Nuclear Regulatory Commission, Region II
ATTN: Mr. Luis A. Reyes, Regional Administrator
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, GA 30303-8931

U. S. Nuclear Regulatory Commission
ATTN: Mr. Theodore A. Easlick, NRC Senior Resident Inspector
8470 River Road
Southport, NC 28461-8869

U. S. Nuclear Regulatory Commission
ATTN: Mr. Donnie J. Ashley (Mail Stop OWFN 8G9)
11555 Rockville Pike
Rockville, MD 20852-2738

Ms. Jo A. Sanford
Chair - North Carolina Utilities Commission
P.O. Box 29510
Raleigh, NC 27626-0510

Electricities of N. C., Inc.
ATTN: Mr. Clarence C. Wells
P. O. Box 29513
Raleigh, NC 27626-0513

ENCLOSURE 1

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324 / LICENSE NOS. DPR-71 AND DPR-62

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
MONTHLY OPERATING REPORT
AUGUST 2001

**APPENDIX A
OPERATING DATA REPORT**

DOCKET NO. 50-325
UNIT NAME Brunswick Steam Electric Plant, Unit No. 1
DATE September 10, 2001
COMPLETED BY Kester M. Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD August 2001
(Month/Year)

	MONTH	YEAR TO DATE	CUMULATIVE
1. Design Electrical Rating: (MWe-Net)	867	N/A	N/A
2. Maximum Dependable Capacity: (MWe-Net)	820	N/A	N/A
3. Number of Hours the Reactor Was Critical:	744	5,831	150,047
4. Number of Hours the Generator Was On Line:	744	5,831	145,647.7
5. Unit Reserve Shutdown Hours:	0	0	0
6. Net Electrical Energy (MWH):	611,083	4,860,981	106,907,956

**APPENDIX B
UNIT SHUTDOWNS**

DOCKET NO. 50-325
UNIT NAME Brunswick Steam Electric Plant, Unit No. 1
DATE September 10, 2001
COMPLETED BY Kester M. Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD August 2001
(Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
						Unit No. 1 was not required to shut down during the month of August 2001.

SUMMARY:

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

ENCLOSURE 2

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324 / LICENSE NOS. DPR-71 AND DPR-62

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
MONTHLY OPERATING REPORT
AUGUST 2001

**APPENDIX A
OPERATING DATA REPORT**

DOCKET NO. 50-324
UNIT NAME Brunswick Steam Electric Plant, Unit No. 2
DATE September 10, 2001
COMPLETED BY Kester M. Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD August 2001
 (Month/Year)

	MONTH	YEAR TO DATE	CUMULATIVE
1. Design Electrical Rating: (MWe-Net)	867	N/A	N/A
2. Maximum Dependable Capacity: (MWe-Net)	811	N/A	N/A
3. Number of Hours the Reactor Was Critical:	744	5,099.9	158,740.3
4. Number of Hours the Generator Was On Line:	744	5,067.7	152,774.2
5. Unit Reserve Shutdown Hours:	0	0	0
6. Net Electrical Energy (MWH):	610,791	4,116,983	107,523,350

**APPENDIX B
UNIT SHUTDOWNS**

DOCKET NO. 50-324
UNIT NAME Brunswick Steam Electric Plant, Unit No. 2
DATE September 10, 2001
COMPLETED BY Kester M. Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD August 2001
(Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
						Unit No. 2 was not required to shut down during the month of August 2001.

SUMMARY:

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)