

September 13, 2001

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

**DOCKET 50-255 - LICENSE DPR-20 - PALISADES PLANT**  
**LICENSEE REPORT OF MONTHLY OPERATING DATA**

Attached is the Monthly Operating Data and Summary of Operating Experience for the Palisades Nuclear Plant for the month of August 2001.

If you have any questions or concerns, please contact Mr. Scott Hawn at (616) 764-3179.

Sincerely,



Daniel G. Malone  
Director, Licensing and Performance Assessment (Acting)

CC Regional Administrator, USNRC, Region III  
NRC Resident Inspector, Palisades  
LBrandon, Michigan Department of Environmental Quality  
BWJorgensen, Michigan Department of Labor  
RDWhale, Michigan Public Service Commission  
Records Center, INPO  
SMMcIntyre, P-26-204

Attachment

IE24

**ATTACHMENT**

**NUCLEAR MANAGEMENT COMPANY  
PALISADES PLANT  
DOCKET 50-255**

**September 13, 2001**

**LICENSEE REPORT OF MONTHLY OPERATING DATA  
August 2001**

**5 Pages**

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO 50-255  
UNIT Palisades  
DATE 9/05/01  
COMPLETED BY SFPierce  
TELEPHONE (616)764-2239

MONTH August 2001

DAY AVERAGE DAILY POWER LEVEL  
(MWe Net)

1.	<u>0</u>
2.	<u>0</u>
3.	<u>0</u>
4.	<u>0</u>
5.	<u>0</u>
6.	<u>0</u>
7.	<u>0</u>
8.	<u>0</u>
9.	<u>0</u>
10.	<u>0</u>
11.	<u>0</u>
12.	<u>0</u>
13.	<u>0</u>
14.	<u>0</u>
15.	<u>0</u>
16.	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL  
(MWe Net)

17.	<u>0</u>
18.	<u>0</u>
19.	<u>0</u>
20.	<u>0</u>
21.	<u>0</u>
22.	<u>0</u>
23.	<u>0</u>
24.	<u>0</u>
25.	<u>0</u>
26.	<u>0</u>
27.	<u>0</u>
28.	<u>0</u>
29.	<u>0</u>
30.	<u>0</u>
31.	<u>0</u>

## INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-NET for each day in the reporting month.  
Compute to the nearest whole megawatt.

### SUMMARY OF OPERATING EXPERIENCE FOR AUGUST, 2001

The Plant began the month of August, 2001 in mode 5, cold shutdown, to complete repairs to the primary coolant system at the control rod drive housings.

The plant remained in mode 5 through the end of the month, pending repair completion.

# OPERATING DATA REPORT

DOCKET NO: 50-255  
 DATE (Mo-Da-Yr): 9-05-01  
 COMPLETED BY: SFPierce  
 TELEPHONE (616) 764-2239  
 NOTES:

## OPERATING STATUS:

1. UNIT NAME Palisades
2. REPORTING PERIOD (YrMoDa-YrMoDa): 010801-010831
3. LICENSED THERMAL POWER (Mwt) 2530
4. NAMEPLATE RATING (GROSS Mwe) 811.7
5. DESIGN ELECTRICAL RATING (NET Mwe) 805
6. MAXIMUM DEPENDABLE CAPACITY (GROSS Mwe) 770 \*\*
7. MAXIMUM DEPENDABLE CAPACITY (NET Mwe) 730 \*\*
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEM NUMBERS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWe):
10. REASONS FOR RESTRICTIONS, IF ANY:

	This Month	Yr-to-Date	Cumulative
11. HOURS IN REPORTING PERIOD	744.0	5831.0	260366.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	0.0	3184.1	161226.7
13. REACTOR RESERVE SHUTDOWN HOURS	----	----	----
14. HOURS GENERATOR ON-LINE	0.0	3120.0	155790.5
15. UNIT RESERVE SHUTDOWN HOURS	----	----	----
16. GROSS THERMAL ENERGY GENERATED (MWH)	0	7547698	351124577
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	0	2475668	111759028
18. NET ELECTRICAL ENERGY GENERATED (MWH)	0	2355631	105693815
19. UNIT SERVICE FACTOR	0.0%	53.5%	59.8%
20. UNIT AVAILABILITY FACTOR	0.0%	53.5%	59.8%
21. UNIT CAPACITY FACTOR (USING MDC NET)	0.0%	55.3%	58.7%
22. UNIT CAPACITY FACTOR (USING DER NET)	0.0%	50.2%	50.4%
23. UNIT FORCED OUTAGE RATE	100.0%	35.7%	25.1%
24. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE AND DURATION OF EACH):			

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

\*\* Based on condenser backpressure

\* Weighted Average (635 MWe used as MDC Net prior to October 1985)

## REPORT MONTH

August, 2001DOCKET NO 50-255UNIT PalisadesDATE 09/05/01COMPLETED BY SFPierceTELEPHONE 616-764-2239

## UNIT SHUTDOWNS AND POWER REDUCTIONS

No.	Date (YrMoDa)	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
8	01/08/01	F	744 hrs	A	1	LER 01-004	AA	DRIV	Primary Coolant System leakage, repairs to be determined

1.	2.	3.	4.	5.
F: Forced	Reason:	Method:	Exhibit G - Instructions	Exhibit I - Same Source
S: Scheduled	A-Equipment Failure (Explain)	1-Manual	for Preparation of Data	
	B-Maintenance or Test	2-Manual Scram	Entry Sheets for Licensee	
	C-Refueling	3-Automatic Scram	Event Report (LER) File	
	D-Regulatory Restriction	4-Other (Explain)	(NUREG-0161)	
	E-Operator Training & License Examination			
	F-Administrative			
	G-Operational Error (Explain)			
	H-Other (Explain)			