

SEP 14 2001

LRN-01-0296



PSEG
Nuclear LLC

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT
HOPE CREEK GENERATING STATION UNIT 1
DOCKET NO. 50-354**

In compliance with Section 6.9, Reporting Requirements for the Hope Creek Technical Specifications, the operating statistics for **August 2001** are being forwarded.

Sincerely,

D. F. Garchow
Vice President - Operations

RAR
Attachments

C Distribution

IE24

INDEX

<u>SECTION</u>	<u>NUMBER OF PAGES</u>
Operating Data Report	1
Monthly Operating Summary	1

DOCKET NO.: 50-354
 UNIT: Hope Creek
 DATE: 09/07/01
 COMPLETED BY: F. Todd
 TELEPHONE: (856) 339-1316

Reporting Period August 2001

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)
 Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical
 No. of hours generator was on line (service hours)
 Unit reserve shutdown hours
 Net Electrical Energy (MWH)

1083		
1049		
Month	Year-to-date	Cumulative
744	5675	110122
744	5641	108047
0	0	0
779626	5874359	109444694

UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-354
UNIT: Hope Creek
DATE: 09/10/01
COMPLETED BY: R. Ritzman
TELEPHONE: (856) 339-1445

Summary Of Monthly Operating Experience

- Hope Creek started the month at approximately 100% power.
- On August 12, Hope Creek reduced power to approximately 63% to perform Scheduled Deep Shallow Rod adjustments and Control Valve testing. Power was restored to approximately 100% on August 13.
- At the end of August, Hope Creek completed 107 days of continuous on-line operation.