

NLS2001079
Enclosure 1

COOPER NUCLEAR STATION
NON-PROPRIETARY REPORT
GE NE-E1200141-04,
“Decay Heat Evaluation for CNS”



GE Nuclear Energy

General Electric Company
175 Curtner Avenue, San Jose, CA 95125

GE-NE-E1200141-04R2
Class III
July 2001

Decay Heat Evaluation
for
Cooper Nuclear Station

Prepared by: *C. L. Martin*
C. L. Martin
Principal Engineer
GE Nuclear Energy

IMPORTANT NOTICE REGARDING
CONTENTS OF THIS REPORT

Please Read Carefully

The only undertakings of the General Electric company (GE) respecting information in this document are contained in the contract between *Nebraska Public Power District* and GE, "*Containment Performance with Two Sigma Decay Heat Cooper Nuclear Station GE Proposal Number 523-1JHY7-HP1*", effective *January 26, 1999*, as amended to the date of transmittal of this document, and nothing contained in this document shall be construed as changing the contract. The use of this information by anyone other than *Nebraska Public Power District*, or for any purpose other than that for which it is intended is not authorized: and with respect to any unauthorized use, GE makes no representation or warranty, express or implied, and assumes no liability as to the completeness, accuracy or usefulness of the information contained in this document, or that its use may not infringe privately owned rights.

PROPRIETARY INFORMATION NOTICE

This document contains proprietary information of the General Electric Company (GE) and is furnished to *Nebraska Public Power District* in confidence solely for the purpose or purposes stated in the transmittal letter. No other use, direct or indirect, of the document or the information it contains is authorized. *Nebraska Public Power District* shall not publish or otherwise disclose it or the information to others without consent of GE, and shall return the document at request of GE.

Stand-alone GE proprietary information is identified by sidebars in the right margin next to the affected text, tables and figures containing stand-alone proprietary information. This paragraph has a sidebar as an example. Specific information that is not so marked, when taken out of the context of this report, is not GE proprietary.

CONTENTS

1. INTRODUCTION.....	5
2. FUEL CYCLE INPUT PARAMETERS AND ASSUMPTIONS.....	6
3. FUEL DEPENDENT PARAMETERS.....	7
4. EVALUATION OF THE NEUTRON CAPTURE EFFECT (NCE)	8
5. CALCULATION OF THE TOTAL DECAY HEAT.....	9
6. CONCLUSIONS	10
REFERENCES.....	11

1. Introduction

A new evaluation of the relative decay power has been made for Cooper Nuclear Station based upon the ANSI/ANS-5.1-1979 Decay Heat Standard (reference 1). Since the previous evaluation of decay heat (revision 0 of this document), the methodology has been improved. The purpose of the improvement was to include two new small terms to account for miscellaneous actinides and activation products consistent with the recommendations of SIL 636 (Reference 8). The ANSI/ANS-5.1-1979 standard explicitly accounts for the two most prominent actinides, U239 and Np239, but requires the User to evaluate and include the effects of all other actinides as well as the effects of miscellaneous structural activation products. Individually these actinides are negligible, but many together can add up to a non-negligible amount of decay heat. Likewise, there are a number of structural (Zirconium) and fuel isotopes (including Gadolinium) which together are non-negligible.

* Proprietary information to the General Electric Company has been deleted.

In section 2 of this document, the fuel cycle parameters and assumptions which provide a basis for the decay power evaluation are provided. Based on these inputs, the fuel dependent parameters utilized by the standard are identified and listed in section 3. Section 4 contains a description of the model used in evaluating the neutron capture effect and a discussion of the methods used to qualify and verify the model. In section 5, the calculation of the relative decay power is described and the results tabulated. Additional sources of heat after shutdown, namely fuel relaxation energy and metal-water reaction are not considered in this document (although they were evaluated in revision 0 of this report). Appropriate values consistent with this document may be found in Reference 9. It is understood that these additional sources of heat after shutdown are to be included by the User, as appropriate. Finally, in section 6, the conclusions are presented.

NRC Information Notice IN96-39 (reference 7), concerning the wide variation in decay heat estimates throughout the industry, was considered in the preparation of this report. It is believed that the wide variation which was observed was due either to misapplication of the ANS standard or to extremely conservative interpretation. To avoid the former situation, the methods and procedures used herein, have been carefully design reviewed and the calculations verified. The later situation has been avoided by very careful application of the standard to Cooper Nuclear Station, while still retaining an appropriate degree of conservatism.

2. Fuel Cycle Input Parameters and Assumptions

The decay heat table was based on the following fuel cycle assumptions, which were derived from the material in reference 2:

The decay heat table is also applicable to other fuel product lines, since decay heat evaluations are not very sensitive to the specific fuel type involved. However, this information is required in order to determine the input parameters to the decay heat standard.

As a guide to understanding the impact of these parameters, it should be noted that increasing the average exposure will increase decay heat, although at a slow rate (less than 1% increased heat for every 10,000 MWd/T of additional exposure). Likewise, an increase in the core average time at power (irradiation time) also results in an increase in decay heat. For irradiation periods greater than 4 years, this increase is very slight (less than 1% for each additional year).

3. Fuel Dependent Parameters

Fissions in materials other than Pu²³⁹ and U²³⁸ are included with U²³⁵ as required by the standard.

4. Evaluation of the Neutron Capture Effect (NCE)

5. Calculation of the Total Decay Heat

The decay heat table based on these inputs and the ANSI/ANS-5.1-1979 decay heat standard is shown in . The first column in the table is the shutdown or cooling time. The second column shows the unadjusted decay heat for the given cooling time and the third column the uncertainty. In the fourth column, the decay heat is shown with two sigma of uncertainty added. The final column is the integral of the decay heat (including the two sigma uncertainty) from time zero up to the cooling time. The trapezoidal rule of integration was used, thus producing a conservative, upper bound on the integral.

6. Conclusions

References

1. "American National Standard for Decay Heat Power in Light Water Reactors", ANSI/ANS-5.1-1979.
- 2.
- 3.
- 4.
5. Croff, A. G., "A User's Manual for the ORIGEN2 Computer Code", ORNL/TM-7175, July 1980.
6. Ludwig, S. B. and Renier, J. P., "Standard and Extended Burnup PWR and BWR Reactor Models for the ORIGEN2 Computer Code", ORNL/TM—11018, December 1989.
7. "Estimates of Decay Heat Using ANS 5.1 Decay Heat Standard May Vary Significantly", NRC Information Notice, IN96-39.
8. GE Nuclear Energy Services Information Letter (SIL) Number 636, Revision 1, June 6, 2001.
- 9.
- 10.