

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

September 20, 2001

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 01-328A
NL&OS/ETS R0
Docket No. 50-339
License No. NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT 2
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION
THIRD INTERVAL INSERVICE INSPECTION PROGRAM - NDE-9


In a letter dated June 13, 2001 (Serial No. 01-328), Virginia Electric and Power Company (Dominion) submitted the inservice inspection (ISI) program for the third interval for North Anna Unit 2, including the associated relief requests.

In a September 12, 2001 telephone conference call with the NRC Staff, regarding Relief Request NDE-9, the application of Code case N-513 and the basis for the 18-month time limit on service water system repairs were discussed. These two items were resolved during the call. The NRC requested that the specific regulation applicable to the request for relief be identified on the docket.

The relief being requested in NDE-9 is made pursuant to 10 CFR 50.55a (3)(ii), which provides for proposed alternatives where the specified Code requirement would result in a hardship or unusual difficulty without a compensating increase in the level of quality and safety.

If you have any questions or require additional information, please contact us.

Very truly yours,



Stephen P. Sarver
Director – Nuclear Licensing and Operations Support

Commitments made in this letter:

1. None

A047

cc: U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW
Suite 23T85
Atlanta, Georgia 30303

Mr. M. J. Morgan
NRC Senior Resident Inspector
North Anna Power Station

Mr. J. E. Reasor, Jr.
Old Dominion Electric Cooperative
Innsbrook Corporate Center
4201 Dominion Blvd.
Suite 300
Glen Allen, Virginia 23060