

July 15, 1998

Mr. J.P. O'Hanlon  
Senior Vice President - Nuclear  
Virginia Electric and Power Company  
Innsbrook Technical Center  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

SUBJECT: ISSUANCE OF REVISED EXEMPTION FROM THE REQUIREMENTS OF 10  
CFR 70.24(a) - SURRY POWER STATION (TAC NOS. MA0657 AND MA0658)

Dear Mr. O'Hanlon:

By letter dated January 14, 1998, you requested a revised exemption from the requirements of 10 CFR 70.24(a) concerning criticality monitors as pertaining to unirradiated fuel and other forms of special nuclear materials to reflect your use of 4.3 weight percent enriched U235 fuel. Your exemption previously granted August 21, 1997, reflected the use of fuel enriched to 4.1 weight percent U235.

Based upon the information provided, there is reasonable assurance that irradiated and unirradiated fuel will remain subcritical during handling and storage; furthermore, you maintain radiation monitors in accordance with General Design Criterion (GDC) 63. The low probability of a criticality together with your adherence to GDC 63 constitute good cause for granting a revised exemption from 10 CFR 70.24(a).

The Commission, pursuant to 10 CFR 70.14, has issued the enclosed revised exemption for Surry Nuclear Power Station, Unit 1 and Unit 2. The enclosed Safety Evaluation documents the NRC staff's review of this issue. The revised exemption is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by:  
Gordon Edison, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-280  
and 50-281

Enclosures: 1. Exemption  
2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION: See attached list  
DOCUMENT NAME: G:\SURRY\SR97904.EXE  
\*Previously Concurred

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDII-1	E	LA:PDII-1*	E	SRXB*	OGC	AD:PDII-1*
NAME	GEdison		EDunnington		TCollins		PTKuo
DATE	6/23/98		6/23/98		6/15/98	6/23/98	6/15/98
OFFICE	AD:DRPE		AD:ADPR				
NAME	JZwolinski		BBoger		TCollins		
DATE	6/24/98		6/25/98		6/29/98		

Official Record Copy

9807210290 980715  
PDR ADDCK 05000280  
P PDR

#1 6/26

11  
DFO

ENCLOSURE COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

July 15, 1998

Mr. J. P. O'Hanlon  
Senior Vice President - Nuclear  
Virginia Electric and Power Company  
Innsbrook Technical Center  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

SUBJECT: ISSUANCE OF REVISED EXEMPTION FROM THE REQUIREMENTS OF  
10 CFR 70.24(a) - SURRY POWER STATION, UNITS 1 AND 2 (TAC NOS.  
MA0657 AND MA0658)

Dear Mr. O'Hanlon:

By letter dated January 14, 1998, you requested a revised exemption from the requirements of 10 CFR 70.24(a) concerning criticality monitors as pertaining to unirradiated fuel and other forms of special nuclear materials to reflect your use of 4.3 weight percent enriched U235 fuel. Your exemption previously granted August 21, 1997, reflected the use of fuel enriched to 4.1 weight percent U235.

Based upon the information provided, there is reasonable assurance that irradiated and unirradiated fuel will remain subcritical during handling and storage; furthermore, you maintain radiation monitors in accordance with General Design Criterion (GDC) 63. The low probability of a criticality together with your adherence to GDC 63 constitute good cause for granting a revised exemption from 10 CFR 70.24(a).

The Commission, pursuant to 10 CFR 70.14, has issued the enclosed revised exemption for Surry Nuclear Power Station, Unit 1 and Unit 2. The enclosed Safety Evaluation documents the NRC staff's review of this issue. The revised exemption is being forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in black ink that reads "Gordon Edison".

Gordon Edison, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-280  
and 50-281

Enclosures: 1. Exemption  
2. Safety Evaluation

cc w/encls: See next page

Mr. J. P. O'Hanlon  
Virginia Electric and Power Company

Surry Power Station

cc:

Mr. Michael W. Maupin, Esq.  
Hunton and Williams  
Riverfront Plaza, East Tower  
951 E. Byrd Street  
Richmond, Virginia 23219

Office of the Attorney General  
Commonwealth of Virginia  
900 East Main Street  
Richmond, Virginia 23219

Mr. Eugene S. Grecheck, Manager  
Surry Power Station  
Virginia Electric and Power Company  
5570 Hog Island Road  
Surry, Virginia 23883

Mr. J. H. McCarthy, Manager  
Nuclear Licensing & Operations  
Support  
Innsbrook Technical Center  
Virginia Electric and Power Company  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Senior Resident Inspector  
Surry Power Station  
U. S. Nuclear Regulatory Commission  
5850 Hog Island Road  
Surry, Virginia 23883

Mr. R. C. Haag  
U.S. Nuclear Regulatory Commission  
Atlanta Federal Center  
61 Forsyth St., SW, Suite 23T85  
Atlanta, Georgia 30303

Chairman  
Board of Supervisors of Surry County  
Surry County Courthouse  
Surry, Virginia 23683

Mr. W. R. Matthews, Manager  
North Anna Power Station  
P. O. Box 402  
Mineral, Virginia 23117

Dr. W. T. Lough  
Virginia State Corporation  
Commission  
Division of Energy Regulation  
P. O. Box 1197  
Richmond, Virginia 23209

Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
Atlanta Federal Center  
61 Forsyth Street, SW, Suite 23T85  
Atlanta, Georgia 30303

Robert B. Strobe, M.D., M.P.H.  
State Health Commissioner  
Office of the Commissioner  
Virginia Department of Health  
P.O. Box 2448  
Richmond, Virginia 23218

**DISTRIBUTION:**

Docket File

PUBLIC

PDII-1 Reading

J. Zwolinski

E. Dunnington

G. Edison

P. T. Kuo

T. Harris (e-mail only, TLH3) SE

OGC

ACRS

G. Hill (4)

L. Plisco, RII

M. Boyle

M. Tschiltz, EDO

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
 )  
VIRGINIA ELECTRIC AND POWER ) Docket Nos. 50-280 and 50-281  
COMPANY )  
 )  
Surry Power Station, Units 1 and 2 )

EXEMPTION

I.

The Virginia Electric and Power Company (VEPCO, the licensee) is the holder of Facility Operating License No. DPR-32 and Facility Operating License No. DPR-37, which authorize operation of the Surry Power Station, Units 1 and 2. The licenses provide that the licensee is subject to all rules, regulations, and orders of the U.S. Nuclear Regulatory Commission (NRC or the Commission) now or hereafter in effect.

The facility consists of two pressurized-water reactors at the licensee's site located in Surry County, Virginia.

II.

Title 10 of the Code of Federal Regulations (10 CFR) Section 70.24, "Criticality Accident Requirements," requires that each licensee authorized to possess special nuclear material shall maintain a criticality accident monitoring system in each area in which such material is handled, used, or stored. Sections 70.24 (a)(1) and (a)(2) specify detection and sensitivity requirements that these monitors must meet. Section 70.24(a)(1) also specifies that all areas subject to criticality accident monitoring must be covered by two detectors. Section 70.24(a)(3) requires licensees to maintain emergency procedures for each area in which this licensed special

nuclear material is handled, used, or stored, and provides (1) that the procedures ensure that all personnel withdraw to an area of safety upon the sounding of a criticality accident monitor alarm, (2) that the procedures must include drills to familiarize personnel with the evacuation plan, and (3) that the procedures designate responsible individuals for determining the cause of the alarm and placement of radiation survey instruments in accessible locations for use in such an emergency. Section 70.24(b)(1) requires licensees to have a means by which to quickly identify personnel who have received a dose of 10 rads or more. Section 70.24(b)(2) requires licensees to maintain personnel decontamination facilities, to maintain arrangements for a physician and other medical personnel qualified to handle radiation emergencies, and to maintain arrangements for the transportation of contaminated individuals to treatment facilities outside the site boundary. Section 70.24(c) exempts Part 50 licensees from the requirements of 10 CFR 70.24(c) for special nuclear material used or to be used in the reactor. Subsection 70.24(d) states that any licensee who believes that there is good cause why he should be granted an exemption from all or part of 10 CFR 70.24 may apply to the Commission for such an exemption and shall specify the reasons for the relief requested.

### III.

On August 21, 1997, the NRC granted an exemption from the requirements of 10 CFR 70.24 reflecting the licensee's use of fuel enriched to 4.1 weight percent U235. By letter dated January 14, 1998, VEPCO requested a revised exemption from 10 CFR 70.24(a) based on the use of fuel enriched to 4.3 weight percent U235. The Commission has reviewed the licensee's submittal and has determined that inadvertent criticality is not likely to occur in special nuclear materials handling or storage areas at Surry Power Station, Units 1 and 2. The quantity of special nuclear material other than fuel that is stored on site is small enough to preclude achieving a critical mass.

The purpose of the criticality monitors required by 10 CFR 70.24 is to ensure that if a criticality were to occur during the handling of special nuclear material, personnel would be alerted to that fact and would take appropriate action. Although the staff has determined that such an accident is not likely to occur, the licensee has radiation monitors, as required by General Design Criteria 63, in fuel storage and handling areas. These monitors will alert personnel to excessive radiation levels and allow them to initiate appropriate safety actions. The low probability of an inadvertent criticality together with the licensee's adherence to General Design Criterion 63 constitute good cause for granting an exemption to the requirements of 10 CFR 70.24(a).

## IV.

The Commission has determined that, pursuant to 10 CFR 70.14, this exemption as revised is authorized by law, will not endanger life or property or the common defense and security, and is otherwise in the public interest; therefore, the Commission hereby grants the following revised exemption:

The Virginia Electric and Power Company is exempt from the requirements of 10 CFR 70.24(a) for the Surry Nuclear Power Station, Unit 1 and Unit 2.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this revised exemption will have no significant impact on the quality of the human environment (63 FR 38196 ).

This revised exemption is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Samuel J. Collins, Director  
Office of Nuclear Reactor Regulation

Dated at Rockville, Maryland  
this 15th day of July 1998.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATING TO REQUEST FOR REVISED EXEMPTION FROM 10 CFR 70.24(a)

VIRGINIA ELECTRIC AND POWER COMPANY

SURRY POWER STATION, UNITS 1 AND 2

DOCKET NO. 50-280 & 50-281

1.0 INTRODUCTION

By letter dated January 14, 1998, Virginia Electric and Power Company, (the licensee) requested a revised exemption from the requirements of 10 CFR 70.24(a) to reflect the use of 4.3 weight percent enriched U235 fuel. An exemption previously granted August 21, 1997, reflected the use of fuel enriched to 4.1 weight percent U235. The Commission has reviewed the licensee's submittal and has determined that procedures and design features make an inadvertent criticality in special nuclear materials handling or storage at the Surry Power Station unlikely, in accordance with General Design Criterion 62, as described below.

2.0 EVALUATION

Title 10 of the Code of Federal Regulations (10 CFR) Section 70.24, "Criticality Accident Requirements," at subsection (a) requires that each licensee authorized to possess special nuclear material shall maintain in each area where such material is handled, used, or stored, a criticality accident monitoring system "using gamma- or neutron-sensitive radiation detectors which will energize clearly audible alarm signals if accidental criticality occurs." Subsection (a)(1) and (a)(2) of 10 CFR 70.24 specify the detection, sensitivity, and coverage capabilities of the monitors required by 10 CFR 70.24(a). Subsection (a)(3) of 10 CFR 70.24 requires that the licensee shall maintain emergency procedures for each area in which this licensed special nuclear material is handled, used, or stored and provides (1) that the procedures ensure that all personnel withdraw to an area of safety upon the sounding of a criticality monitor alarm, (2) that the procedures must include drills to familiarize personnel with the evacuation plan, and (3) that the procedures designate responsible individuals for determining the cause of the alarm and placement of radiation survey instruments in accessible locations for use in such an emergency. Subsection (b)(1) of 10 CFR 70.24 requires licensees to have a means to identify quickly personnel who have received a dose of 10 rads or more. Subsection (b)(2) of 10 CFR 70.24 requires licensees to maintain personnel decontamination facilities, to maintain arrangements for a physician and other medical personnel qualified to handle radiation emergencies, and to maintain arrangements for the transportation of contaminated individuals to treatment facilities outside the site boundary. Paragraph (c) of 10 CFR 70.24 exempts Part 50 licensees from the requirements of paragraph (b) of 10 CFR 70.24 for special nuclear material used or to be used in the reactor. Subsection (d) of 10 CFR 70.24 states that any



licensee who believes that there is good cause why he should be granted an exemption from all or part of 10 CFR 70.24 may apply to the Commission for such an exemption and shall specify the reasons for the relief requested.

The purpose of 10 CFR 70.24(a), (a)(2), and (a)(3) is to ensure that any inadvertent criticality is detected and that action is taken to protect personnel and correct the problem. By letter dated January 14, 1998, the licensee requested a revised exemption from the requirements of 10 CFR 70.24(a). The licensee proposes to handle and store the unirradiated fuel and other special nuclear material without having either the criticality monitoring system or the emergency procedures specified in 10 CFR 70.24(a). The licensee believes that procedures and design features make an inadvertent criticality unlikely, in accordance with General Design Criterion 62.

Special nuclear material, as nuclear fuel, is stored in the spent fuel pool and the new fuel storage area. The spent fuel pool is used to store irradiated fuel under water after its discharge from the reactor, and new fuel prior to loading into the reactor. New fuel is stored dry (in air) in the new fuel storage area.

Special nuclear material is also present in the form of fissile material incorporated into nuclear instrumentation. The small quantity of special nuclear material present in these items precludes an inadvertent criticality.

Consistent with Technical Specification Section 5.4, the spent fuel pool is designed to store the fuel in a geometric array that precludes criticality. The spent fuel racks are designed such that the effective neutron multiplication factor,  $k_{\text{eff}}$ , will remain less than or equal to 0.95 under all normal and accident conditions for fuel of maximum nominal enrichment of 4.3 weight percent U235. The staff has found this design adequate.

The new fuel storage area is used to receive and store new fuel in a dry condition upon arrival on site and prior to loading in the reactor or spent fuel pool. The spacing between new fuel assemblies in the storage racks is sufficient to maintain the array in a subcritical condition even under accident conditions assuming the presence of moderator. The maximum nominal enrichment of 4.3 weight percent U235 for the new fuel assemblies results in a maximum  $k_{\text{eff}}$  less than or equal to 0.95 under conditions of accidental flooding by unborated water, and  $k_{\text{eff}}$  less than or equal to 0.98 under conditions of low-density optimum moderation. The staff has found the design of the licensee's new fuel storage racks to be adequate to store fuel enriched to 4.3 weight percent U235.

Nuclear fuel is moved between the shipping container, the new fuel storage racks, the reactor vessel, and the spent fuel pool to accommodate refueling operations. In all cases, fuel movements are procedurally controlled and designed to preclude conditions involving criticality concerns. The fuel handling equipment used to unload and transfer the new fuel assemblies from the shipping containers to the storage racks precludes handling more than one fuel assembly at a time.

Procedures and controls prevent an inadvertent criticality during fuel handling; nevertheless, radiation monitoring, as required by General Design Criterion 63, is provided in the new fuel storage area. An area radiation monitor is provided in the new fuel storage area and a second radiation monitor is provided on the fuel pit bridge crane. These required radiation monitors have associated area alarms and control room annunciators and would detect excessive radiation levels.

Training is required of all nuclear employees prior to receiving a badge to enter the nuclear power station. Nuclear employee retraining is provided annually to nuclear workers thereafter. This training provides those individuals having access to the Radiological Control Area direction regarding their required response upon hearing an alarm associated with an area radiation monitor.

The purpose of 10 CFR 70.24 is to ensure that if a criticality were to occur during the handling of special nuclear material, personnel would be alerted to that fact and would take appropriate action. Although the staff has determined that reasonable and satisfactory precautions exist to preclude a nuclear criticality accident, thereby meeting the requirements of General Design Criterion 62, the licensee has radiation monitors, as required by General Design Criterion 63, in fuel storage and handling areas. These monitors will alert personnel to excessive radiation levels and allow them to initiate appropriate safety actions. The low probability of an inadvertent criticality together with the licensee's adherence to General Design Criterion 63 and radiation worker training constitute good cause for granting a revised exemption to the requirements of 10 CFR 70.24(a).

### 3.0 CONCLUSION

Based upon the information provided, there is reasonable assurance that irradiated and unirradiated fuel will remain subcritical during handling and storage. The circumstances for granting a revised exemption to 10 CFR 70.24(a) are met because criticality is extremely unlikely with the present design configuration, TS requirements, administrative controls, and the fuel handling equipment and procedures. Therefore, the staff concludes that the licensee's request for a revised exemption from the requirements of 10 CFR 70.24(a) is acceptable and should be granted.

Principal Contributor: L. Kopp

Dated: July 15, 1998