

5.5 Programs and Manuals

---

5.5.1 Offsite Dose Calculation Manual (ODCM) (continued)

the affected pages, clearly indicating the area of the page that was changed, and shall indicate the date (i.e., month and year) the change was implemented.

5.5.2 Primary Coolant Sources Outside Containment

This program provides controls to minimize leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to levels as low as practicable. The systems include recirculation portion of the high pressure injection system, the shutdown cooling portion of the low pressure safety injection system, the post-accident sampling subsystem of the reactor coolant sampling system (until such time as a modification eliminates the PASS penetration as a potential leakage path), the containment spray system, and the post-accident containment atmosphere sampling piping of the hydrogen monitoring subsystem (until such time as a modification eliminates the PASS penetration as a potential leakage path). The program shall include the following:

- a. Preventive maintenance and periodic visual inspection requirements; and
- b. Integrated leak test requirements for each system at refueling cycle intervals or less.

5.5.3 Deleted

(continued)