



*Pacific Gas and  
Electric Company*

**James R. Becker**  
Station Director

Diablo Canyon Power Plant  
Mail Code 104/5/504  
P.O. Box 56  
Avila Beach, CA 93424

805.545.3462  
Fax: 805.545.4234

September 14, 2001

PG&E Letter DCL-01-097

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Docket No. 50-275, DPR-80  
Docket No. 50-323, DPR-82  
Diablo Canyon Units 1 and 2  
Monthly Operating Report for August 2001

Dear Commissioners and Staff:

Attached is the Monthly Operating Report for Diablo Canyon Power Plant, Units 1 and 2, for August 2001. This report is submitted in accordance with Technical Specification 5.6.4 and NRC Generic Letter 97-02.

Sincerely,

James R. Becker

cc: Robert D. Glynn, Jr.  
Kurt Larson  
Barbara Lewis  
Ellis W. Merschoff  
David L. Proulx  
Girija S. Shukla  
Gregory M. Rueger  
INPO Record Center

Enclosures

LMP/1713/R0224327

JE24

**AUGUST 2001, OPERATION SUMMARIES  
DIABLO CANYON POWER PLANT  
UNITS 1 AND 2**

Summary of Unit 1 Operation

Unit 1 began August in Mode 1 (Power Operation), at approximately 100 percent power. There were no significant operational activities.

Summary of Unit 2 Operation

Unit 2 began August in Mode 1 at approximately 100 percent power. There were no significant operational activities.

Actuations of Steam Generator Safety or Pressurizer Power Operated Relief Valves

There were no challenges to the pressurizer power operated relief valves, or steam generator safety valves.

### OPERATING DATA REPORT

DOCKET NO.: 50-275  
UNIT NAME: Diablo Canyon Unit 1  
DATE: 09/01/2001  
COMPLETED BY: L. Parker  
TELEPHONE: (805) 545-3386

REPORT MONTH: August 2001

1.	Design Electrical Rating (MWe - Net):	1103
2.	Maximum Dependable Capacity (MWe - Net):	1087

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	5831.0	124492.4
4.	Number of Hours Generator On-Line:	744.0	5823.1	123166.2
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH):	826438	6384495	127037998

**UNIT SHUTDOWNS**

DOCKET NO.: 50-275  
 UNIT NAME: Diablo Canyon Unit 1  
 DATE: 09/01/2001  
 COMPLETED BY: L. Parker  
 TELEPHONE: (805) 545-3386

REPORT MONTH: August 2001

NO.	DATE	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON <sup>1</sup>	METHOD OF SHUTTING DOWN <sup>2</sup>	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F- Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

2. Method

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation from Previous Month
- 5-Other

### OPERATING DATA REPORT

DOCKET NO.: 50-323  
UNIT NAME: Diablo Canyon Unit 2  
DATE: 09/01/2001  
COMPLETED BY: L. Parker  
TELEPHONE: (805) 545-3386

REPORT MONTH: August 2001

1.	Design Electrical Rating (MWe - Net):	1119
2.	Maximum Dependable Capacity (MWe - Net):	1087

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	5193.0	119729.8
4.	Number of Hours Generator On-Line:	744.0	5123.6	118267.2
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH):	814295	5501293	124248853

**UNIT SHUTDOWNS**

DOCKET NO.: 50-323  
 UNIT NAME: Diablo Canyon Unit 2  
 DATE: 09/01/2001  
 COMPLETED BY: L. Parker  
 TELEPHONE: (805) 545-3386

REPORT MONTH: August 2001

NO.	DATE	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON <sup>1</sup>	METHOD OF SHUTTING DOWN <sup>2</sup>	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F- Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

2. Method

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation from Previous Month
- 5-Other