

Mr. J. P. O'Hanlon
 Senior Vice President Nuclear
 Virginia Electric and Power Company
 5000 Dominion Blvd.
 Glen Allen, Virginia 23060

June 19, 1995

SUBJECT: ENVIRONMENTAL ASSESSMENT OF EXEMPTION REQUEST FROM 10 CFR PART 50,
 APPENDIX J - SURRY POWER STATION, UNIT NO. 1

Dear Mr. O'Hanlon:

Enclosed is a copy of the Environmental Assessment and Finding of No Significant Impact related to your application for exemption dated April 28, 1995. The proposed exemption would provide a one-time interval extension for the Type A test (containment integrated leak rate test) from the October 1995 refueling outage to the February 1997 refueling outage.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

(Original Signed By)

Bart C. Buckley, Sr. Project Manager
 Project Directorate II-1
 Division of Reactor Projects - I/II
 Office of Nuclear Reactor Regulation

Docket No. 50-280

Enclosure: Environmental Assessment

cc w/enclosure:
 See next page

Distribution
 Docket File
 PUBLIC
 PDII-2
 S. Varga
 J. Zwolinski
 OGC
 E. Jordan
 ACRS(4)
 OPA
 D. Verrelli, RII

DOCUMENT NAME: A:\IP290463.ENV

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDII-1	E	PM:PDII-1	E	D:PDII-1	SCSB	JCP	E	OGC	Stb	N
NAME	EDunnington	ED	BBuckley	BCB	DMatthews	RBarrett	for		EHoller		
DATE	5/31/95		5/31/95		6/19/95	6/18/95			6/16/95		

OFFICIAL RECORD COPY

220029

9506300226 950619
 PDR ADOCK 05000280
 P PDR

INFO FILE CENTER COPY

EF01
 11

Mr. J. P. O'Hanlon
Virginia Electric and Power Company

Surry Power Station
Units 1 and 2

cc:

Michael W. Maupin, Esq.
Hunton and Williams
Riverfront Plaza, East Tower
951 E. Byrd Street
Richmond, Virginia 23219

Attorney General
Supreme Court Building
101 North 8th Street
Richmond, Virginia 23219

Mr. David Christian, Manager
Surry Power Station
Post Office Box 315
Surry, Virginia 23883

Mr. M. L. Bowling, Manager
Nuclear Licensing & Programs
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Senior Resident Inspector
Surry Power Station
U.S. Nuclear Regulatory Commission
5850 Hog Island Road
Surry, Virginia 23883

Roy Denmark (5 copies)
Environmental Review Coordinator
841 Chestnut Street
Philadelphia, PA 19107

Chairman
Board of Supervisors of Surry County
Surry County Courthouse
Surry, Virginia 23683

Dr. W. T. Lough
Virginia State Corporation
Commission
Division of Energy Regulation
Post Office Box 1197
Richmond, Virginia 23209

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

Robert B. Strobe, M.D., M.P.H.
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
P.O. Box 2448
Richmond, Virginia 23218

UNITED STATES NUCLEAR REGULATORY COMMISSION
VIRGINIA ELECTRIC AND POWER COMPANY
DOCKET NO. 50-280
SURRY POWER STATION, UNIT NO. 1
ENVIRONMENTAL ASSESSMENT AND FINDING OF
NO SIGNIFICANT IMPACT

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an exemption from Facility Operating License No. DPR-32, issued to Virginia Electric and Power Company (the licensee), for operation of the Surry Power Station, Unit No. 1 (SPS1) located in Surry County, Virginia.

ENVIRONMENTAL ASSESSMENT

Identification of the Proposed Action:

This Environmental Assessment has been prepared to address potential environmental issues related to the licensee's application of April 28, 1995. The proposed action would exempt the licensee from the requirements of 10 CFR Part 50, Appendix J, Paragraph III.D.1.(a), to the extent that a one-time interval extension for the Type A test (containment integrated leak rate test) by approximately 18 months from the October 1995 refueling outage to the February 1997 refueling outage would be granted.

The Need for the Proposed Action:

The proposed action is needed to permit the licensee to defer the Type A test from the October 1995 refueling outage to the February 1997 refueling outage, thereby saving the cost of performing the test and eliminating the test period from the critical path time of the outage.

Environmental Impacts of the Proposed Action:

The Commission has completed its evaluation of the proposed action and concludes that the proposed one-time exemption would not increase the probability or consequences of accidents previously analyzed and the proposed one-time exemption would not affect facility radiation levels or facility radiological effluents. The licensee will continue to be required to conduct the Type B and C local leak rate tests which historically have been shown to be the principal means of detecting containment leakage paths with the Type A tests confirming the Type B and C test results. It is also noted that the licensee, as a condition of the proposed exemption, will perform the visual containment inspection although it is only required by Appendix J to be conducted in conjunction with Type A tests. The NRC staff considers that these inspections, though limited in scope, provide an important added level of confidence in the continued integrity of the containment boundary. The NRC staff also notes that the containment is maintained at a subatmospheric pressure which provides a means for continuously monitoring potential containment leakage paths during power operation. The change will not increase the probability or consequences of accidents, no changes are being made in the types of any effluents that may be released offsite, and there is no significant increase in the allowable individual or cumulative occupational radiation exposure. Accordingly, the Commission concludes that there are no significant radiological environmental impacts associated with the proposed action.

With regard to potential nonradiological impacts, the proposed action does involve features located entirely within the restricted area as defined in 10 CFR Part 20. It does not affect nonradiological plant effluents and has

no other environmental impact. Accordingly, the Commission concludes that there are no significant nonradiological environmental impacts associated with the proposed action.

Alternatives to the Proposed Action:

Since the Commission has concluded there is no measurable environmental impact associated with the proposed action, any alternatives with equal or greater environmental impact need not be evaluated. As an alternative to the proposed action, the NRC staff considered denial of the proposed action. Denial of the application would result in no change in current environmental impacts.

Alternative Use of Resources:

This action does not involve the use of any resources not previously considered in the Final Environmental Statement for the Surry Power Station, Unit No. 1.

Agencies and Persons Consulted:

In accordance with its stated policy, on May 16, 1995 the NRC staff consulted with the Virginia State official, L. Foldesi of the State Health Department, regarding the environmental impact of the proposed action. The State official had no comments.

FINDING OF NO SIGNIFICANT IMPACT

Based upon the environmental assessment, the Commission concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee's letter dated April 28, 1995, which is available for public

inspection at the Commission's Public Document Room, The Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Swem Library, College of William and Mary, Williamsburg, Virginia 23185.

Dated at Rockville, Maryland, this 19th day of June 1995.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation