

JUN 10 1975

Docket Nos. 50-280  
and 50-281

Virginia Electric & Power Company  
ATTN: Mr. Stanley Ragone  
Senior Vice President  
Post Office Box 26666  
Richmond, Virginia 23261

Gentlemen:

The Commission has issued the enclosed Amendments No. 6 to Facility Licenses No. DPR-32 and DPR-37 for the Surry Power Station, Units 1 and 2. The amendments include Change No. 21 to your Technical Specifications for each license and are in response to your request dated March 12, 1975, as supplemented April 9, 1975.

The amendments revise the provisions in the Technical Specifications relating to the replacement of 84 of 157 fuel assemblies in the reactor core, constituting refueling of the core for second cycle operation of Unit 2. Since the technical specifications related to emergency core cooling system Final Acceptance Criteria for Surry Units 1 and 2 have not yet been approved, the amendments do not permit operation at power levels above those required for low power physics tests.

Copies of the related Safety Evaluation and the Federal Register Notice are also enclosed.

Sincerely,

Original signed by

R. A. Purple

Robert A. Purple, Chief  
Operating Reactors Branch #1  
Division of Reactor Licensing

Enclosures:

1. Amendment No. 6 to DPR-32
2. Amendment No. 6 to DPR-37
3. Safety Evaluation
4. Federal Register Notice

cc w/enclosures: See next page

SEE PREVIOUS YELLOW FOR OTHER CONCURRENCES

OFFICE >	RL:ORB-1	RL:ORB-1	RL:DIR			
x7434 SURNAME >	MFairtile	RAPurple	AGiambusso			
DATE >	6/ /75	6/ /75	6/ /75			

68  
(1)