

Secondary Containment Isolation Instrumentation
3.3.6.2

Table 3.3.6.2-1 (page 1 of 1)
Secondary Containment Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Reactor Vessel Water Level - Low Low, Level 2	1,2,3, (a)	2	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.3 SR 3.3.6.2.4 SR 3.3.6.2.5	≥ 103.8 inches
2. Drywell Pressure - High	1,2,3	2	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.3 SR 3.3.6.2.4 SR 3.3.6.2.5	≤ 1.88 psig
3. Fuel Pool Ventilation Exhaust Radiation - High	1,2,3, (a),(b)	2	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.4 SR 3.3.6.2.5	≤ 6 mR/hr
4. Manual Initiation	1,2,3, (a),(b)	1	SR 3.3.6.2.5	NA

- (a) During operations with a potential for draining the reactor vessel.
- (b) During movement of recently irradiated fuel assemblies in secondary containment.

Table 3.3.7.1-1 (page 1 of 1)
Control Room Emergency Filtration System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION A.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Reactor Vessel Water Level - Low Low, Level 2	1.2.3.(a)	2	B	SR 3.3.7.1.1 SR 3.3.7.1.3 SR 3.3.7.1.4 SR 3.3.7.1.5 SR 3.3.7.1.6	≥ 103.8 inches
2. Drywell Pressure - High	1.2.3	2	B	SR 3.3.7.1.1 SR 3.3.7.1.3 SR 3.3.7.1.4 SR 3.3.7.1.5 SR 3.3.7.1.6	≤ 1.88 psig
3. Fuel Pool Ventilation Exhaust Radiation - High	1.2.3. (a).(b)	2	B	SR 3.3.7.1.1 SR 3.3.7.1.3 SR 3.3.7.1.5 SR 3.3.7.1.6	≤ 6 mR/hr
4. Control Center Normal Makeup Air Radiation - High	1.2.3. (a).(b)	1	C	SR 3.3.7.1.1 SR 3.3.7.1.2 SR 3.3.7.1.5	≤ 5 mR/hr

- (a) During operations with a potential for draining the reactor vessel.
- (b) During movement of recently irradiated fuel assemblies in the secondary containment.

3.6 CONTAINMENT SYSTEMS

3.6.4.1 Secondary Containment

LCO 3.6.4.1 The secondary containment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in
the secondary containment,

During operations with a potential for draining the reactor
vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Secondary Containment inoperable due to one railroad bay access door inoperable.	A.1 Restore railroad bay door to OPERABLE status.	7 days
B. Secondary containment inoperable in MODE 1, 2, or 3 for reasons other than Condition A.	B.1 Restore secondary containment to OPERABLE status.	4 hours
C. Required Action and associated Completion Time of Condition A or B not met.	C.1 Be in MODE 3.	12 hours
	<u>AND</u> C.2 Be in MODE 4.	36 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Secondary containment inoperable during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.	-----NOTE----- LCO 3.0.3 is not applicable. -----	Immediately
	D.1 Suspend movement of recently irradiated fuel assemblies in the secondary containment.	
	AND D.2 Initiate action to suspend OPDRVs.	

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.4.1.1 Verify secondary containment vacuum is ≥ 0.125 inch of vacuum water gauge.	24 hours

(continued)

3.6 CONTAINMENT SYSTEMS

3.6.4.2 Secondary Containment Isolation Valves (SCIVs)

LCO 3.6.4.2 Each SCIV shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in
the secondary containment,

During operations with a potential for draining the reactor
vessel (OPDRVs).

ACTIONS

-----NOTES-----

1. Penetration flow paths may be unisolated intermittently under administrative controls.
 2. Separate Condition entry is allowed for each penetration flow path.
 3. Enter applicable Conditions and Required Actions for systems made inoperable by SCIVs.
-

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more penetration flow paths with one SCIV inoperable.	A.1 Isolate the affected penetration flow path by use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange. AND	8 hours (continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition A or B not met during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.	-----NOTE----- LCO 3.0.3 is not applicable. -----	
	D.1 Suspend movement of recently irradiated fuel assemblies in the secondary containment.	Immediately
	<u>AND</u> D.2 Initiate action to suspend OPDRVs.	Immediately

3.6 CONTAINMENT SYSTEMS

3.6.4.3 Standby Gas Treatment (SGT) System

LCO 3.6.4.3 Two SGT subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in
the secondary containment,

During operations with a potential for draining the reactor
vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One SGT subsystem inoperable.	A.1 Restore SGT subsystem to OPERABLE status.	7 days
B. Required Action and associated Completion Time of Condition A not met in MODE 1, 2, or 3.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. Required Action and associated Completion Time of Condition A not met during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.</p>	<p>.....NOTE..... LCO 3.0.3 is not applicable. </p> <p>C.1 Place OPERABLE SGT subsystem in operation.</p> <p><u>OR</u></p> <p>C.2.1 Suspend movement of recently irradiated fuel assemblies in secondary containment.</p> <p><u>AND</u></p> <p>C.2.2 Initiate action to suspend OPDRVs.</p>	<p>Immediately</p> <p>Immediately</p> <p>Immediately</p>
<p>D. Two SGT subsystems inoperable in MODE 1, 2, or 3.</p>	<p>D.1 Enter LCO 3.0.3.</p>	<p>Immediately</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. Two SGT subsystems inoperable during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.NOTE..... LCO 3.0.3 is not applicable.	
	E.1 Suspend movement of recently irradiated fuel assemblies in secondary containment.	Immediately
	<u>AND</u> E.2 Initiate action to suspend OPDRVs.	Immediately

3.7 PLANT SYSTEMS

3.7.3 Control Room Emergency Filtration (CREF) System

LCO 3.7.3 The CREF System shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
During movement of recently irradiated fuel assemblies in
the secondary containment,

During operations with a potential for draining the reactor
vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CREF subsystem inoperable.	A.1 Restore CREF subsystem to OPERABLE status.	7 days
B. Required Action and associated Completion Time of Condition A not met in MODE 1, 2, or 3.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. Required Action and associated Completion Time of Condition A not met during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.</p>	<p>-----NOTE----- LCO 3.0.3 is not applicable. -----</p>	
	<p>C.1 Place OPERABLE CREF subsystem in recirculation mode.</p>	<p>Immediately</p>
	<p><u>OR</u></p>	
	<p>C.2.1 Initiate action to suspend OPDRVs.</p>	<p>Immediately</p>
	<p><u>AND</u></p>	
	<p>-----NOTE----- Not required for a CREF System or subsystem inoperable for performance of SR 3.7.3.6 due to failure to provide the required filtration efficiency, or due to replacement of charcoal filtration media. -----</p>	
	<p>C.2.2 Suspend movement of recently irradiated fuel assemblies in the secondary containment.</p>	<p>Immediately</p>

(continued)

3.7 PLANT SYSTEMS

3.7.4 Control Center Air Conditioning (AC) System

LCO 3.7.4 Two control center AC subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.
During movement of recently irradiated fuel assemblies in the secondary containment,

During operations with a potential for draining the reactor vessel (OPDRVs).

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One control center AC subsystem inoperable.	A.1 Restore control center AC subsystem to OPERABLE status.	30 days
B. Required Action and associated Completion Time of Condition A not met in MODE 1, 2, or 3.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. Required Action and associated Completion Time of Condition A not met during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.</p>	<p>.....NOTE..... LCO 3.0.3 is not applicable. </p> <p>C.1 Place OPERABLE control center AC subsystem in operation.</p> <p><u>OR</u></p> <p>C.2.1 Suspend movement of recently irradiated fuel assemblies in the secondary containment.</p> <p><u>AND</u></p> <p>C.2.2 Initiate action to suspend OPDRVs.</p>	<p>Immediately</p> <p>Immediately</p> <p>Immediately</p>
<p>D. Two control center AC subsystems inoperable in MODE 1, 2, or 3.</p>	<p>D.1 Enter LCO 3.0.3.</p>	<p>Immediately</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. Two control center AC subsystems inoperable during movement of recently irradiated fuel assemblies in the secondary containment or during OPDRVs.	-----NOTE----- LCO 3.0.3 is not applicable. -----	
	E.1 Suspend movement of recently irradiated fuel assemblies in the secondary containment.	Immediately
	<u>AND</u> E.2 Initiate actions to suspend OPDRVs.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.4.1 Verify the control room air temperature is $\leq 95^{\circ}\text{F}$.	12 hours

3.8 ELECTRICAL POWER SYSTEMS

3.8.2 AC Sources-Shutdown

LCO 3.8.2 The following AC electrical power sources shall be OPERABLE:

- a. One qualified circuit between the offsite transmission network and the onsite Class 1E AC electrical power distribution subsystem(s) required by LCO 3.8.8, "Distribution Systems-Shutdown"; and
- b. Two emergency diesel generators (EDGs) capable of supplying one division of the onsite Class 1E AC electrical power distribution subsystem(s) required by LCO 3.8.8.

APPLICABILITY: MODES 4 and 5,
During movement of recently irradiated fuel assemblies in the secondary containment.

ACTIONS

-----NOTE-----
LCO 3.0.3 is not applicable.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One required offsite circuit inoperable.</p>	<p>-----NOTE----- Enter applicable Condition and Required Actions of LCO 3.8.8, with one required division de-energized as a result of Condition A. -----</p> <p>A.1 Declare affected required feature(s), with no offsite power available, inoperable.</p> <p><u>OR</u></p>	<p>Immediately</p> <p>(continued)</p>

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.1 Suspend CORE ALTERATIONS. <u>AND</u>	Immediately
	A.2.2 Suspend movement of recently irradiated fuel assemblies in the secondary containment. <u>AND</u>	Immediately
	A.2.3 Initiate action to suspend operations with a potential for draining the reactor vessel (OPDRVs). <u>AND</u>	Immediately
	A.2.4 Initiate action to restore required offsite power circuit to OPERABLE status.	Immediately

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. One or both required EDGs inoperable.	B.1 Suspend CORE ALTERATIONS. <u>AND</u>	Immediately
	B.2 Suspend movement of recently irradiated fuel assemblies in secondary containment. <u>AND</u>	Immediately
	B.3 Initiate action to suspend OPDRVs. <u>AND</u>	Immediately
	B.4 Initiate action to restore required EDGs to OPERABLE status.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.8.2.1NOTE..... The following SRs are not required to be performed: SR 3.8.1.2, SR 3.8.1.3, and SR 3.8.1.7 through SR 3.8.1.17. For AC sources required to be OPERABLE SR 3.8.1.1 through SR 3.8.1.17, are applicable.	In accordance with applicable SRs

ACTIONS CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.1 Suspend CORE ALTERATIONS. <u>AND</u>	Immediately
	A.2.2 Suspend movement of recently irradiated fuel assemblies in the secondary containment. <u>AND</u>	Immediately
	A.2.3 Initiate action to suspend operations with a potential for draining the reactor vessel. <u>AND</u>	Immediately
	A.2.4 Initiate action to restore required DC electrical power subsystems to OPERABLE status.	Immediately

3.8 ELECTRICAL POWER SYSTEMS

3.8.8 Distribution Systems-Shutdown

LCO 3.8.8 The necessary portions of the AC and DC electrical power distribution subsystems shall be OPERABLE to support equipment required to be OPERABLE.

APPLICABILITY: MODES 4 and 5,
During movement of recently irradiated fuel assemblies in the secondary containment.

ACTIONS

-----NOTE-----
LCO 3.0.3 is not applicable.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required AC or DC electrical power distribution subsystems inoperable.	A.1 Declare associated supported required feature(s) inoperable.	Immediately
	<u>OR</u>	
	A.2.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	A.2.2 Suspend handling of recently irradiated fuel assemblies in the secondary containment.	Immediately
	<u>AND</u>	(continued)